

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
1/1/98 12:15 AM	141	259	UNKNOWN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
1/1/98 12:18 AM	122	120	PUBLIC - FOREIGN OBJECT	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	NO ACTION NEEDED	NO
1/1/98 12:21 AM	249	36	PUBLIC - FOREIGN OBJECT	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
1/1/98 12:23 AM	294	52	PUBLIC - VANDALISM	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
1/1/98 12:29 AM	309	91	PUBLIC - VANDALISM	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
1/1/98 12:30 AM	534	43	PUBLIC - VANDALISM	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
1/1/98 12:40 AM	438	39	PUBLIC - VANDALISM	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
1/1/98 12:43 AM	127	55	PUBLIC - FOREIGN OBJECT	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
1/1/98 12:57 AM	338	56	PUBLIC - VANDALISM	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
1/1/98 1:05 AM	395	53	PUBLIC - VANDALISM	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
1/1/98 1:26 AM	160	39	PUBLIC - FOREIGN OBJECT	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
1/1/98 1:29 AM	249	35	PUBLIC - VANDALISM	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
1/1/98 4:04 AM	317	56	OTHER	CONNECTOR/SLEEVE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
1/1/98 5:14 AM	426	4936	UNKNOWN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
1/1/98 5:16 AM	89	709	OTHER	PHASE WIRE	REPAIRED EQUIPMENT	FIELD INSPECTION	NO
1/1/98 9:02 AM	89	44	PUBLIC - VANDALISM	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
1/1/98 9:33 AM	240	12	PUBLIC - VANDALISM	METER ENTRANCE	REPAIRED EQUIPMENT	NO ACTION NEEDED	NO
1/1/98 9:37 AM	1653	45	PUBLIC - VANDALISM	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
1/1/98 10:12 AM	1239	67	PUBLIC - VANDALISM	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
1/1/98 10:52 AM	480	38	PUBLIC - FOREIGN OBJECT	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	NO ACTION NEEDED	NO
1/1/98 11:47 AM	170	32	OTHER	CONNECTOR/SLEEVE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
1/1/98 12:23 PM	137	87	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
1/1/98 2:03 PM	41	62	UNKNOWN	FUSE/CUTOUT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
1/1/98 3:25 PM	1357	51	PUBLIC - VANDALISM	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
1/1/98 3:38 PM	1193	45	PUBLIC - VANDALISM	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
1/1/98 3:57 PM	1359	43	OTHER	CONNECTOR/SLEEVE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
1/1/98 4:12 PM	93	3330	PUBLIC - ACCIDENT BY OTHERS	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	NO ACTION NEEDED	NO
1/1/98 7:24 PM	866	56	PUBLIC - VANDALISM	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
1/1/98 7:55 PM	790	17	TREE CONTACT - SECONDARY	NEUTRAL WIRE	REPAIRED EQUIPMENT	TREE TRIMMING	NO
1/2/98 7:50 AM	311	41	OTHER	CONNECTOR/SLEEVE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
1/2/98 8:28 AM	112	1210	UNKNOWN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
1/2/98 9:22 AM	318	29	TREE LIMB BROKEN - SECONDARY	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
1/2/98 9:39 AM	204	42	PUBLIC - VANDALISM	CONNECTOR/SLEEVE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
1/2/98 9:46 AM	64	53	PUBLIC - VANDALISM	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
1/2/98 11:18 AM	160	63	PUBLIC - VANDALISM	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
1/2/98 12:52 PM	94	18	UNKNOWN	ARRESTER	TEMPORARY SWITCHING	FIELD INSPECTION	NO
1/2/98 1:19 PM	131	28	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
1/2/98 5:29 PM	58	363	TREE CONTACT - PRIMARY	PHASE WIRE	TREE REMOVED	TREE TRIMMING	NO
1/2/98 8:35 PM	42	245	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
1/2/98 8:56 PM	124	1784	UNKNOWN	SUBSTATION BREAKER	TEMPORARY SWITCHING	FIELD INSPECTION	NO
1/2/98 10:48 PM	92	66	OTHER	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
1/3/98 3:56 AM	177	1794	PUBLIC - VANDALISM	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
1/3/98 7:35 AM	151	1219	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
1/3/98 8:13 AM	150	79	UNKNOWN	AERIAL CABLE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
1/3/98 10:07 AM	113	387	TRANSMISSION AND SUBSTATION EQUIPMENT - CONTAMINATION	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
1/3/98 11:09 AM	181	75	OTHER	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
1/3/98 7:37 PM	28	2221	UNDERGROUND EQUIPMENT - UG FAILURE	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
1/3/98 8:08 PM	37	46	WEATHER - FLOODING/RAIN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
1/3/98 10:00 PM	85	99	OTHER	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
1/4/98 10:10 AM	215	27	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
1/4/98 12:36 PM	404	56	TREE CONTACT - SECONDARY	PHASE WIRE	REPAIRED EQUIPMENT	TREE TRIMMING	NO
1/4/98 1:09 PM	123	13	TREE CONTACT - SECONDARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
1/4/98 3:08 PM	82	1756	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
1/4/98 3:43 PM	122	34	TREE CONTACT - SECONDARY	PHASE WIRE	REPAIRED OTHER	TREE TRIMMING	NO
1/4/98 6:16 PM	114	81	WEATHER - FLOODING/RAIN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
1/4/98 8:56 PM	224	31	OTHER	DEAD END	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
1/4/98 9:03 PM	805	28	OTHER	CONNECTOR/SLEEVE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
1/5/98 8:31 AM	84	72	OTHER	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
1/5/98 8:32 AM	241	10	OTHER	CONNECTOR/SLEEVE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
1/5/98 11:15 AM	145	36	OTHER	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
1/5/98 3:09 PM	36	2889	CUSTOMER - EQUIPMENT	SUBSTATION BREAKER	OTHER	NO ACTION NEEDED	NO
1/5/98 4:07 PM	63	13	UNDERGROUND EQUIPMENT - UG FAILURE	FUSE/CUTOUT	OTHER	FIELD INSPECTION	NO
1/5/98 5:39 PM	191	221	UNDERGROUND EQUIPMENT - UG FAILURE	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
1/5/98 6:33 PM	25	160	WEATHER - FLOODING/RAIN	CROSS/ALLEY ARM	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
1/6/98 1:33 AM	47	47	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
1/6/98 1:14 PM	1006	17	COMED/CONTRACTOR - DIG-IN BY CONTRACTOR	CABLE	REPAIRED UNDERGROUND MATERIAL	TRAINING	YES
1/6/98 2:45 PM	83	101	PUBLIC - FOREIGN OBJECT	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	NO ACTION NEEDED	NO
1/6/98 4:24 PM	321	28	OTHER	CONNECTOR/SLEEVE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
1/6/98 6:03 PM	312	38	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
1/6/98 6:17 PM	198	56	OTHER	CONNECTOR/SLEEVE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
1/6/98 7:09 PM	54	515	PUBLIC - FOREIGN OBJECT	PHASE WIRE	OTHER	NO ACTION NEEDED	NO
1/7/98 6:39 AM	181	17	TREE CONTACT - SECONDARY	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
1/7/98 6:43 AM	525	70	OTHER	CONNECTOR/SLEEVE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
1/7/98 9:02 AM	3	235	INTENTIONAL - EMERGENCY REPAIRS	PHASE WIRE	OTHER	FIELD INSPECTION	NO
1/7/98 9:46 AM	61	23959	UNDERGROUND EQUIPMENT - UG FAILURE	SUBSTATION BREAKER	TEMPORARY SWITCHING	FIELD INSPECTION	NO
1/7/98 10:22 AM	128	1842	WEATHER - FLOODING/RAIN	SUBSTATION BREAKER	TEMPORARY SWITCHING	FIELD INSPECTION	NO
1/7/98 11:13 AM	39	729	WEATHER - FLOODING/RAIN	PHASE WIRE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
1/7/98 11:16 AM	36	1095	WEATHER - FLOODING/RAIN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
1/7/98 11:29 AM	71	88	OVERHEAD EQUIPMENT - MALFUNCTION	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
1/7/98 11:57 AM	249	65	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
1/7/98 12:01 PM	37	1139	UNDERGROUND EQUIPMENT - UG FAILURE	SUBSTATION BREAKER	TEMPORARY SWITCHING	FIELD INSPECTION	NO
1/7/98 12:29 PM	86	75	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
1/7/98 3:55 PM	70	53	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
1/7/98 6:03 PM	97	60	TREE CONTACT - PRIMARY	FUSE/CUTOUT	TREE TRIMMED	TREE TRIMMING	NO
1/7/98 7:45 PM	225	26	OTHER	NEUTRAL WIRE	REPLACED EQUIPMENT	FIELD INSPECTION	NO
1/7/98 9:34 PM	61	89	TREE CONTACT - PRIMARY	PHASE WIRE	TREE TRIMMED	TREE TRIMMING	NO
1/7/98 10:09 PM	41	141	WEATHER - WIND	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
1/7/98 11:10 PM	963	26	OTHER	CABLE	REPLACED UNDERGROUND MATERIAL	FIELD INSPECTION	YES
1/8/98 7:01 AM	160	128	WEATHER - ICE	SUBSTATION RECLOSER	OTHER	FIELD INSPECTION	NO
1/8/98 7:18 AM	154	989	WEATHER - ICE	SUBSTATION RECLOSER	CLOSED LINE RECLOSER	FIELD INSPECTION	NO
1/8/98 7:32 AM	688	136	TREE LIMB BROKEN - PRIMARY	POLE	REPLACED EQUIPMENT	TREE TRIMMING	NO
1/8/98 10:38 AM	22	786	PUBLIC - FOREIGN OBJECT	PHASE WIRE	CLOSED FUSE OR CUTOUT	NO ACTION NEEDED	NO
1/8/98 10:49 AM	1551	46	OTHER	CONNECTOR/SLEEVE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
1/8/98 11:31 AM	499	34	WEATHER - ICE	CONNECTOR/SLEEVE	CHANGED OTHER	FIELD INSPECTION	NO
1/8/98 12:20 PM	315	166	WEATHER - ICE	STATIC WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
1/8/98 2:19 PM	99	2453	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	SUBSTATION BREAKER	CLOSED SUBSTATION BREAKER	FIELD INSPECTION	NO
1/8/98 3:02 PM	283	30	WEATHER - ICE	CONNECTOR/SLEEVE	REPLACED EQUIPMENT	FIELD INSPECTION	NO
1/8/98 3:51 PM	3249	162	UNDERGROUND EQUIPMENT - UG FAILURE	CABLE	REPLACED UNDERGROUND MATERIAL	FIELD INSPECTION	YES
1/8/98 4:25 PM	277	53	TREE CONTACT - SECONDARY	CONNECTOR/SLEEVE	CHANGED OTHER	TREE TRIMMING	NO
1/8/98 4:49 PM	1171	30	OTHER	CONNECTOR/SLEEVE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
1/8/98 4:55 PM	5	2579	WEATHER - ICE	SUBSTATION BREAKER	CLOSED SUBSTATION BREAKER	FIELD INSPECTION	NO
1/8/98 5:36 PM	204	65	TREE CONTACT - SECONDARY	PHASE WIRE	REPLACED OVERHEAD MATERIAL	TREE TRIMMING	NO
1/8/98 8:40 PM	50	259	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
1/8/98 9:28 PM	317	14	WEATHER - ICE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
1/9/98 1:17 AM	103	42	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
1/9/98 3:09 AM	430	65	OVERHEAD EQUIPMENT - BROKEN FUSE	OVERHEAD TRANSFORMER	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
1/9/98 9:14 AM	296	48	OTHER	CONNECTOR/SLEEVE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
1/9/98 9:49 AM	101	79	OTHER	CONNECTOR/SLEEVE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
1/9/98 11:54 AM	81	1613	UNKNOWN	SWITCH/DISCONNECT/LTD	TEMPORARY SWITCHING	FIELD INSPECTION	NO
1/9/98 2:55 PM	225	31	OTHER	CONNECTOR/SLEEVE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
1/9/98 3:11 PM	224	54	WEATHER - WIND	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
1/9/98 8:14 PM	52	19	WEATHER - ICE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
1/9/98 9:43 PM	187	19	WEATHER - WIND	CONNECTOR/SLEEVE	CHANGED OTHER	FIELD INSPECTION	NO
1/9/98 10:40 PM	225	53	TREE CONTACT - SECONDARY	PHASE WIRE	REPLACED EQUIPMENT	TREE TRIMMING	NO
1/9/98 11:49 PM	186	1270	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	TREE TRIMMED	TREE TRIMMING	NO
1/10/98 1:11 AM	480	41	UNKNOWN	OVERHEAD TRANSFORMER	OTHER	FIELD INSPECTION	NO
1/10/98 3:17 AM	164	1544	UNKNOWN	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
1/10/98 9:37 AM	247	12	OTHER	AERIAL CABLE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
1/10/98 5:04 PM	1296	11	OTHER	CONNECTOR/SLEEVE	CHANGED OTHER	FIELD INSPECTION	NO
1/10/98 11:30 PM	339	66	OTHER	CONNECTOR/SLEEVE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
1/11/98 12:00 PM	80	28	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
1/11/98 11:04 PM	86	33	UNKNOWN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
1/12/98 8:18 AM	127	269	PUBLIC - ACCIDENT BY OTHERS	POLE	REPAIRED EQUIPMENT	NO ACTION NEEDED	NO
1/12/98 8:38 AM	307	24	OTHER	CONNECTOR/SLEEVE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
1/12/98 11:07 AM	343	25	OTHER	CONNECTOR/SLEEVE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
1/12/98 11:42 AM	58	51	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
1/12/98 12:57 PM	83	30	WILDLIFE	FUSE/CUTOUT	REPLACED EQUIPMENT	ANIMAL GUARD CHECK	NO
1/12/98 1:05 PM	45	34	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
1/12/98 5:11 PM	78	755	PUBLIC - DIG-IN BY OTHERS	CABLE	OTHER	NO ACTION NEEDED	NO
1/13/98 11:57 AM	98	29	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
1/13/98 7:23 PM	52	1276	OTHER	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
1/13/98 7:40 PM	155	98	OTHER	TAP WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
1/14/98 8:14 AM	6	52	INTENTIONAL - SCHEDULED CONSTRUCTION, MAINTENANCE, OR REPAIR	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	NO ACTION NEEDED	NO
1/14/98 8:42 AM	146	33	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
1/15/98 8:15 AM	277	13	WEATHER - ICE	OVERHEAD TRANSFORMER	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
1/15/98 2:39 PM	156	1282	WEATHER - ICE	FUSE/CUTOUT	CHANGED OTHER	FIELD INSPECTION	NO
1/15/98 2:46 PM	139	25	OTHER	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
1/16/98 4:05 AM	370	51	OTHER	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
1/16/98 9:11 AM	54	95	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
1/16/98 1:46 PM	284	43	TREE CONTACT - SECONDARY	CONNECTOR/SLEEVE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
1/17/98 8:33 AM	87	3298	OTHER	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
1/17/98 9:06 AM	59	1505	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
1/17/98 11:17 AM	638	14	UNDERGROUND EQUIPMENT - UG FAILURE	TERMINATION	REPAIRED UNDERGROUND MATERIAL	FIELD INSPECTION	NO
1/18/98 9:05 AM	95	2951	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
1/19/98 12:01 PM	56	1143	OTHER	CABLE	OTHER	FIELD INSPECTION	NO
1/19/98 5:55 PM	106	57	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
1/20/98 2:17 PM	88	20	UNKNOWN	CONNECTOR/SLEEVE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
1/20/98 2:47 PM	73	3621	OTHER	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
1/21/98 12:38 AM	487	16	UNKNOWN	METER ENTRANCE	REPLACED EQUIPMENT	FIELD INSPECTION	NO
1/21/98 9:24 AM	58	206	OTHER	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
1/21/98 9:33 AM	57	33	PUBLIC - ACCIDENT BY OTHERS	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	NO ACTION NEEDED	NO
1/21/98 10:36 AM	129	33	CUSTOMER - EQUIPMENT	CONNECTOR/SLEEVE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
1/21/98 8:55 PM	93	462	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
1/22/98 5:01 AM	103	911	INTENTIONAL - EMERGENCY REPAIRS	SWITCH/DISCONNECT/LTD	TEMPORARY SWITCHING	FIELD INSPECTION	NO
1/22/98 5:42 AM	138	72	PUBLIC - FIRE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
1/22/98 8:48 AM	157	30	UNKNOWN	CONNECTOR/SLEEVE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
1/22/98 9:33 AM	2	460	TREE CONTACT - PRIMARY	PHASE WIRE	TREE TRIMMED	TREE TRIMMING	NO
1/22/98 11:39 PM	156	30	WEATHER - ICE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
1/23/98 8:46 AM	269	67	UNKNOWN	CONNECTOR/SLEEVE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
1/23/98 12:58 PM	39	354	PUBLIC - ACCIDENT BY OTHERS	CROSS/ALLEY ARM	REPLACED EQUIPMENT	NO ACTION NEEDED	NO
1/24/98 5:27 AM	245	350	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
1/24/98 10:44 AM	91	9767	WILDLIFE	SWITCH/DISCONNECT/LTD	TEMPORARY SWITCHING	ANIMAL GUARD CHECK	NO
1/24/98 4:20 PM	175	1008	UNKNOWN	SUBSTATION BREAKER	CLOSED SUBSTATION BREAKER	FIELD INSPECTION	NO
1/26/98 2:19 PM	336	41	TREE CONTACT - SECONDARY	NEUTRAL WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
1/26/98 2:29 PM	91	379	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
1/26/98 3:18 PM	192	30	OTHER	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
1/27/98 1:07 AM	103	36	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
1/27/98 11:16 AM	17	44	TREE CONTACT - PRIMARY	FUSE/CUTOUT	TREE REMOVED	TREE TRIMMING	NO
1/27/98 12:20 PM	75	344	UNDERGROUND EQUIPMENT - UG FAILURE	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
1/27/98 11:24 PM	40	112	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
1/28/98 7:07 AM	100	40	OVERHEAD EQUIPMENT - CONTAMINATION	TAP WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
1/29/98 6:24 AM	136	5875	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
1/29/98 7:38 AM	128	9112	WEATHER - FLOODING/RAIN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
1/29/98 10:54 PM	431	104	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
1/30/98 7:26 AM	74	36	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
1/31/98 11:33 AM	87	41	UNKNOWN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
2/1/98 8:02 AM	88	147	UNKNOWN	ARRESTER	REPAIRED EQUIPMENT	FIELD INSPECTION	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
2/1/98 4:44 PM	173	108	OTHER	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
2/1/98 11:21 PM	99	6816	WEATHER - LIGHTNING	PHASE WIRE	OTHER	FIELD INSPECTION	NO
2/3/98 9:56 AM	79	27	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
2/3/98 8:27 PM	588	28	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
2/4/98 7:46 AM	84	732	UNKNOWN	SWITCH/DISCONNECT/LTD	TEMPORARY SWITCHING	FIELD INSPECTION	NO
2/4/98 4:40 PM	110	21	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
2/4/98 7:22 PM	394	17	TREE CONTACT - SECONDARY	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
2/5/98 4:17 AM	113	55	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
2/5/98 7:12 AM	225	55	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
2/6/98 10:00 AM	140	14	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
2/6/98 12:32 PM	118	894	PUBLIC - FOREIGN OBJECT	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	NO ACTION NEEDED	NO
2/7/98 10:16 AM	39	4140	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
2/7/98 10:44 AM	78	11	OVERHEAD EQUIPMENT - MALFUNCTION	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
2/7/98 12:18 PM	12	4140	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
2/9/98 1:18 AM	82	33	UNKNOWN	CABLE	OTHER	FIELD INSPECTION	NO
2/9/98 5:43 AM	447	83	OTHER	CABLE	TEMPORARY JUMPER TO RESTORE	FIELD INSPECTION	NO
2/10/98 6:42 AM	2	13	OTHER	INSULATOR	TEMPORARY JUMPER TO RESTORE	FIELD INSPECTION	NO
2/10/98 10:13 AM	487	57	WEATHER - FLOODING/RAIN	OVERHEAD TRANSFORMER	CHANGED OTHER	FIELD INSPECTION	NO
2/10/98 10:57 AM	93	1941	OTHER	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
2/10/98 2:15 PM	109	776	WEATHER - FLOODING/RAIN	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
2/10/98 2:43 PM	71	1917	UNKNOWN	PHASE WIRE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
2/10/98 3:09 PM	204	16	UNKNOWN	CONNECTOR/SLEEVE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
2/11/98 4:26 AM	88	1219	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
2/11/98 5:54 AM	149	1347	WEATHER - FLOODING/RAIN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
2/11/98 6:03 AM	77	3076	WEATHER - FLOODING/RAIN	PHASE WIRE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
2/11/98 9:25 AM	310	16	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
2/11/98 9:27 AM	248	1917	WEATHER - FLOODING/RAIN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
2/11/98 6:23 PM	207	30	WEATHER - FLOODING/RAIN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
2/11/98 7:56 PM	144	204	PUBLIC - VANDALISM	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	NO ACTION NEEDED	NO
2/11/98 11:45 PM	231	1484	INTENTIONAL - EMERGENCY REPAIRS	SWITCH/DISCONNECT/LTD	CLOSED SWITCH/DISCONNECT/LT	FIELD INSPECTION	NO
2/12/98 11:28 AM	42	98	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
2/13/98 5:18 AM	41	2090	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
2/14/98 3:33 PM	57	7196	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
2/15/98 8:34 AM	86	2992	WILDLIFE	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
2/15/98 10:56 AM	174	1139	UNKNOWN	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
2/15/98 7:26 PM	40	497	OTHER	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
2/16/98 2:11 PM	99	16	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
2/16/98 2:45 PM	99	134	OTHER	TAP WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
2/16/98 3:00 PM	160	50	WEATHER - FLOODING/RAIN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
2/16/98 7:52 PM	114	25	OVERHEAD EQUIPMENT - MALFUNCTION	OVERHEAD TRANSFORMER	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
2/16/98 9:18 PM	122	1739	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
2/16/98 10:06 PM	83	258	OTHER	SWITCH/DISCONNECT/LTD	CLOSED SUBSTATION BREAKER	FIELD INSPECTION	NO
2/16/98 10:10 PM	131	47	OVERHEAD EQUIPMENT - CONTAMINATION	SWITCH/DISCONNECT/LTD	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
2/17/98 1:33 AM	97	20	PUBLIC - VANDALISM	OVERHEAD TRANSFORMER	CLOSED FUSE OR CUTOUT	NO ACTION NEEDED	NO
2/17/98 8:11 AM	119	16	OVERHEAD EQUIPMENT - MALFUNCTION	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
2/17/98 9:14 AM	46	39	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
2/17/98 1:48 PM	57	61	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
2/17/98 7:33 PM	200	59	INTENTIONAL - EMERGENCY REPAIRS	SECTIONALIZER	CLOSED SECTIONALIZER	FIELD INSPECTION	NO
2/18/98 4:47 AM	137	11094	WEATHER - FLOODING/RAIN	TERMINATION	TEMPORARY SWITCHING	FIELD INSPECTION	NO
2/18/98 7:16 AM	114	53	WEATHER - FLOODING/RAIN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
2/18/98 7:52 AM	58	37	WEATHER - FLOODING/RAIN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
2/19/98 10:15 AM	174	8885	UNDERGROUND EQUIPMENT - UG FAILURE	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
2/19/98 2:45 PM	40	2700	PUBLIC - DIG-IN BY OTHERS	CABLE	TEMPORARY SWITCHING	NO ACTION NEEDED	NO
2/20/98 1:10 AM	40	283	OTHER	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
2/20/98 5:31 AM	64	189	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
2/20/98 9:19 AM	36	189	PUBLIC - ACCIDENT BY OTHERS	SWITCH/DISCONNECT/LTD	TEMPORARY SWITCHING	NO ACTION NEEDED	NO
2/20/98 10:59 AM	99	3530	UNKNOWN	CABLE JOINT/SPLICE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
2/21/98 8:04 AM	36	36	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
2/21/98 12:05 PM	100	155	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
2/21/98 12:07 PM	273	53	OTHER	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
2/21/98 10:10 PM	1110	144	UNKNOWN	OTHER EQUIPMENT	CHANGED OTHER	FIELD INSPECTION	YES

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
2/22/98 2:52 PM	70	901	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	OTHER EQUIPMENT	OTHER	FIELD INSPECTION	NO
2/23/98 9:10 PM	225	14	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
2/24/98 2:12 PM	48	940	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
2/24/98 2:15 PM	118	27	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
2/24/98 9:39 PM	67	5608	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
2/25/98 4:09 PM	28	607	UNKNOWN	CABLE	CLOSED SUBSTATION BREAKER	FIELD INSPECTION	NO
2/25/98 4:10 PM	87	1942	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
2/25/98 7:18 PM	97	13	PUBLIC - VEHICLES	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	NO ACTION NEEDED	NO
2/25/98 9:12 PM	54	1462	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
2/26/98 10:28 AM	39	6874	OTHER	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
2/26/98 2:42 PM	73	27	OTHER	OVERHEAD TRANSFORMER	REPAIRED TRANSFORMER	FIELD INSPECTION	NO
2/26/98 5:23 PM	743	335	OTHER	CABLE	TEMPORARY JUMPER TO RESTORE	FIELD INSPECTION	NO
2/26/98 5:34 PM	81	44	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
2/26/98 8:46 PM	119	36	WEATHER - FLOODING/RAIN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
2/26/98 11:01 PM	147	86	UNKNOWN	SWITCH/DISCONNECT/LTD	REPLACED EQUIPMENT	FIELD INSPECTION	NO
2/27/98 12:19 AM	191	32	WEATHER - FLOODING/RAIN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
2/27/98 11:39 AM	129	177	UNKNOWN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
2/27/98 6:13 PM	57	29	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
2/28/98 6:36 AM	84	20	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
2/28/98 12:15 PM	110	21	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
2/28/98 4:30 PM	74	47	WILDLIFE	TERMINATION	TEMPORARY SWITCHING	ANIMAL GUARD CHECK	NO
3/2/98 3:28 AM	122	128	UNKNOWN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/2/98 6:07 AM	103	17	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
3/3/98 12:08 AM	287	261	OTHER	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
3/3/98 1:27 AM	208	2154	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
3/3/98 9:45 AM	65	37	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
3/3/98 12:10 PM	60	319	OTHER	FUSE/CUTOUT	TEMPORARY SWITCHING	FIELD INSPECTION	NO
3/3/98 1:32 PM	124	53	OTHER	PHASE WIRE	CONTRACTOR WARNED	FIELD INSPECTION	NO
3/4/98 12:47 AM	31	2884	UNKNOWN	CROSS/ALLEY ARM	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/4/98 8:59 AM	127	652	PUBLIC - ACCIDENT BY OTHERS	SWITCH/DISCONNECT/LTD	CONTRACTOR WARNED	NO ACTION NEEDED	NO
3/5/98 1:50 PM	874	1394	WILDLIFE	TERMINATION	OTHER	ANIMAL GUARD CHECK	YES
3/5/98 3:26 PM	64	779	WILDLIFE	SUBSTATION BREAKER	CLOSED SUBSTATION BREAKER	ANIMAL GUARD CHECK	NO
3/6/98 8:39 AM	171	30	INTENTIONAL - EMERGENCY REPAIRS	OVERHEAD TRANSFORMER	OTHER	FIELD INSPECTION	NO
3/6/98 4:24 PM	36	2210	OTHER	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
3/7/98 7:23 PM	51	258	UNKNOWN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/7/98 10:17 PM	73	13	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
3/8/98 8:04 AM	62	1377	OTHER	PHASE WIRE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
3/8/98 8:30 AM	263	1849	WEATHER - FLOODING/RAIN	PHASE WIRE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
3/8/98 9:30 AM	335	200	PUBLIC - ACCIDENT BY OTHERS	POLE	TEMPORARY SWITCHING	NO ACTION NEEDED	NO
3/8/98 9:43 AM	332	42	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
3/8/98 2:42 PM	117	665	WEATHER - FLOODING/RAIN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/8/98 8:16 PM	3373	700	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/8/98 9:29 PM	2521	56	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 12:14 AM	1270	945	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 12:18 AM	1527	716	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	SUBSTATION BREAKER	CLOSED SUBSTATION BREAKER	FIELD INSPECTION	NO
3/9/98 2:27 AM	218	640	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 2:51 AM	1034	154	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 3:34 AM	1266	853	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 4:05 AM	1210	1617	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 4:12 AM	1257	4168	WEATHER - ICE	SWITCH/DISCONNECT/LTD	REPLACED EQUIPMENT	FIELD INSPECTION	NO
3/9/98 4:15 AM	300	1240	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 4:19 AM	478	1642	WEATHER - ICE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/9/98 4:22 AM	308	684	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 4:26 AM	1649	1264	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
3/9/98 4:35 AM	770	4420	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	SUBSTATION TRANSFORMER	TEMPORARY SWITCHING	FIELD INSPECTION	NO
3/9/98 4:38 AM	547	1016	WEATHER - ICE	SECTIONALIZER	CLOSED SECTIONALIZER	FIELD INSPECTION	NO
3/9/98 4:38 AM	805	71	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 4:39 AM	2466	590	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
3/9/98 4:40 AM	1356	1670	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 4:41 AM	1029	924	WEATHER - ICE	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/9/98 4:43 AM	2107	144	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 4:44 AM	2246	900	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 4:50 AM	3171	169	WEATHER - WIND	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/9/98 4:51 AM	284	765	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 4:51 AM	1929	724	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 4:52 AM	2283	702	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/9/98 4:54 AM	541	1389	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 4:56 AM	983	3478	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 4:56 AM	3760	3189	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 4:59 AM	511	1004	WEATHER - ICE	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 4:59 AM	932	1720	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 4:59 AM	2101	1759	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 5:01 AM	1779	4415	WEATHER - ICE	PHASE WIRE	REPAIRED OTHER	FIELD INSPECTION	NO
3/9/98 5:02 AM	1093	1394	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 5:03 AM	824	972	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 5:04 AM	606	2150	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 5:04 AM	1044	646	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 5:05 AM	843	1363	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 5:05 AM	1580	45	WEATHER - ICE	POLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
3/9/98 5:08 AM	277	81	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 5:08 AM	1872	208	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
3/9/98 5:08 AM	1942	2122	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 5:09 AM	1886	1790	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 5:09 AM	2996	1016	WEATHER - ICE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/9/98 5:12 AM	668	895	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 5:13 AM	2020	420	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 5:14 AM	406	1222	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 5:15 AM	2325	95	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 5:17 AM	275	709	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 5:18 AM	482	970	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 5:18 AM	1993	66	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/9/98 5:18 AM	2217	120	WEATHER - WIND	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/9/98 5:20 AM	550	860	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 5:24 AM	1581	2042	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 5:24 AM	2156	1158	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 5:25 AM	390	1586	TREE CONTACT - PRIMARY	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	TREE TRIMMING	NO
3/9/98 5:25 AM	575	847	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 5:25 AM	2195	4673	WEATHER - ICE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/9/98 5:28 AM	367	544	WEATHER - ICE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/9/98 5:32 AM	188	3495	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	SUBSTATION BREAKER	CLOSED SUBSTATION BREAKER	FIELD INSPECTION	NO
3/9/98 5:33 AM	2697	126	WEATHER - WIND	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/9/98 5:35 AM	455	804	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 5:35 AM	463	1753	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 5:36 AM	674	2197	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 5:36 AM	754	86	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 5:37 AM	1026	1428	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 5:39 AM	496	1852	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 5:39 AM	1206	392	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 5:39 AM	1633	122	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 5:40 AM	1010	116	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 5:41 AM	2029	4005	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 5:44 AM	1626	141	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
3/9/98 5:44 AM	2251	2506	WEATHER - ICE	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/9/98 5:49 AM	761	2728	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 5:50 AM	755	11	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 5:55 AM	200	125	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 5:55 AM	409	601	WEATHER - ICE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/9/98 5:56 AM	878	299	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
3/9/98 6:02 AM	3133	556	WEATHER - WIND	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/9/98 6:08 AM	549	813	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 6:15 AM	245	102	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 6:15 AM	992	501	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 6:18 AM	512	2439	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 6:19 AM	1166	677	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	SUBSTATION BREAKER	CLOSED SUBSTATION BREAKER	FIELD INSPECTION	NO
3/9/98 6:20 AM	540	3191	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 6:22 AM	2333	331	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 6:23 AM	412	24	WEATHER - WIND	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/9/98 6:23 AM	3061	982	UNKNOWN	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	YES
3/9/98 6:25 AM	650	1864	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 6:28 AM	1222	1776	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 6:29 AM	2131	141	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 6:34 AM	807	722	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 6:34 AM	2046	976	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 6:36 AM	664	134	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	TREE TRIMMED	TREE TRIMMING	NO
3/9/98 6:39 AM	227	2989	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 6:39 AM	541	1908	WEATHER - ICE	PHASE WIRE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
3/9/98 6:45 AM	282	1139	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 6:49 AM	2126	76	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 6:49 AM	2141	50	WEATHER - WIND	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/9/98 6:50 AM	1945	394	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 6:52 AM	2408	78	TREE CONTACT - PRIMARY	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	TREE TRIMMING	NO
3/9/98 6:57 AM	3043	753	WEATHER - FLOODING/RAIN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/9/98 6:58 AM	1312	1055	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 7:07 AM	2393	2187	WEATHER - ICE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/9/98 7:12 AM	2058	576	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 7:19 AM	656	1844	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 7:20 AM	991	2884	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 7:26 AM	390	1328	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 7:30 AM	1584	1311	WEATHER - ICE	PHASE WIRE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
3/9/98 7:37 AM	1933	409	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 7:41 AM	2059	335	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 7:43 AM	559	1210	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 7:43 AM	2057	19	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 7:43 AM	2269	868	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 7:48 AM	699	1517	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 7:52 AM	783	461	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 7:53 AM	820	897	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 7:54 AM	2046	13	WEATHER - ICE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/9/98 7:57 AM	1983	27	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 8:03 AM	1119	1204	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 8:04 AM	2017	1360	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 8:08 AM	402	469	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 8:11 AM	1599	1901	WEATHER - ICE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/9/98 8:12 AM	558	920	WEATHER - ICE	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/9/98 8:15 AM	1965	82	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 8:15 AM	3255	343	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 8:15 AM	3405	304	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 8:17 AM	983	258	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 8:18 AM	1632	276	WEATHER - ICE	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
3/9/98 8:22 AM	73	551	WEATHER - ICE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/9/98 8:23 AM	2137	1133	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 8:25 AM	545	1975	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 8:26 AM	949	984	WEATHER - ICE	SWITCH/DISCONNECT/LTD	TEMPORARY SWITCHING	FIELD INSPECTION	NO
3/9/98 8:32 AM	2465	733	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/9/98 8:33 AM	507	14	WEATHER - ICE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/9/98 8:36 AM	714	895	WEATHER - ICE	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/9/98 8:38 AM	582	34	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 8:40 AM	74	3935	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
3/9/98 8:40 AM	418	3743	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 8:47 AM	2093	341	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 8:50 AM	1710	1760	WEATHER - ICE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/9/98 8:58 AM	422	52	TREE LIMB BROKEN - SECONDARY	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/9/98 9:01 AM	3569	29	WEATHER - ICE	AERIAL CABLE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 9:03 AM	1777	831	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 9:05 AM	530	2333	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	TREE REMOVED	TREE TRIMMING	NO
3/9/98 9:11 AM	1599	45	TREE CONTACT - SECONDARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/9/98 9:11 AM	2399	301	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 9:16 AM	1859	2765	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 9:16 AM	3554	53	TREE LIMB BROKEN - SECONDARY	AERIAL CABLE	REPLACED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/9/98 9:20 AM	2484	75	WEATHER - ICE	TAP WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 9:21 AM	1342	826	WEATHER - ICE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/9/98 9:21 AM	2014	1926	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 9:27 AM	2958	226	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	TREE REMOVED	TREE TRIMMING	NO
3/9/98 9:27 AM	3313	16	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 9:35 AM	540	1008	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 9:35 AM	1261	1464	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 9:36 AM	3897	37	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 9:39 AM	3201	123	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 9:44 AM	816	923	WEATHER - ICE	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
3/9/98 9:45 AM	3170	168	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 9:49 AM	1870	251	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 9:51 AM	1739	32	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 9:52 AM	3448	877	WEATHER - ICE	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 9:56 AM	536	523	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 9:59 AM	2021	65	PUBLIC - FOREIGN OBJECT	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
3/9/98 10:02 AM	1793	108	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 10:07 AM	2573	123	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 10:20 AM	2020	458	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 10:24 AM	396	947	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 10:28 AM	1387	233	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 10:38 AM	2057	1309	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 10:44 AM	4486	24	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 10:49 AM	431	1080	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 10:50 AM	3030	52	WEATHER - ICE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/9/98 10:53 AM	1867	42	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 10:55 AM	1685	1309	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 11:01 AM	1874	389	WEATHER - WIND	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/9/98 11:11 AM	1907	583	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 11:16 AM	1194	504	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 11:22 AM	1053	254	WEATHER - ICE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/9/98 11:26 AM	3784	62	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 11:28 AM	203	532	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 11:32 AM	3088	58	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 12:00 PM	3885	53	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 12:01 PM	1919	58	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 12:04 PM	456	308	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 12:09 PM	13	562	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 12:20 PM	930	41	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 12:26 PM	4654	325	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/9/98 12:28 PM	3032	58	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 12:29 PM	1581	769	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 12:43 PM	1567	17	WEATHER - WIND	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/9/98 1:00 PM	2415	676	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 1:06 PM	864	414	WEATHER - ICE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/9/98 1:19 PM	634	710	WEATHER - ICE	POLE	REPLACED EQUIPMENT	FIELD INSPECTION	NO
3/9/98 1:37 PM	1223	859	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
3/9/98 2:06 PM	772	15	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 2:15 PM	480	4252	WEATHER - ICE	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 2:29 PM	2851	114	UNKNOWN	FUSE/CUTOUT	CHANGED OTHER	FIELD INSPECTION	YES

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
3/9/98 2:36 PM	2904	25	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 2:42 PM	4458	35	WEATHER - ICE	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 3:17 PM	205	2813	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 3:26 PM	1014	1597	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
3/9/98 3:27 PM	463	1214	WEATHER - ICE	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/9/98 3:27 PM	1484	684	WEATHER - ICE	SWITCH/DISCONNECT/LTD	TEMPORARY SWITCHING	FIELD INSPECTION	NO
3/9/98 3:32 PM	1798	1272	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 3:33 PM	2327	34	WEATHER - ICE	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/9/98 3:34 PM	1840	264	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/9/98 3:38 PM	651	1470	WEATHER - ICE	POLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
3/9/98 3:41 PM	1214	681	WEATHER - WIND	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/9/98 3:46 PM	799	85	WEATHER - ICE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/9/98 3:47 PM	1443	3935	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 3:52 PM	848	1484	WEATHER - ICE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/9/98 4:05 PM	1169	68	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 4:21 PM	3354	39	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 4:47 PM	1833	1082	TREE CONTACT - PRIMARY	PHASE WIRE	TREE TRIMMED	TREE TRIMMING	NO
3/9/98 4:48 PM	2892	63	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 5:03 PM	77	1753	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 5:30 PM	1740	1102	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 5:46 PM	1494	72	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 6:02 PM	3628	21	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 6:11 PM	2689	23	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 6:14 PM	1456	847	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 6:30 PM	3330	28	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 6:47 PM	1729	976	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 7:00 PM	1592	674	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/9/98 7:04 PM	941	431	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 7:08 PM	2602	47	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 7:22 PM	2664	24	TREE LIMB BROKEN - SECONDARY	PHASE WIRE	OTHER	TREE TRIMMING	NO
3/9/98 7:54 PM	60	16	WEATHER - ICE	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/9/98 7:58 PM	3167	311	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 8:17 PM	3223	43	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 8:21 PM	2634	27	WEATHER - ICE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/9/98 8:24 PM	1	157	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 8:31 PM	3119	22	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 8:44 PM	1516	331	TREE LIMB BROKEN - SECONDARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/9/98 8:54 PM	4716	73	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 9:59 PM	3901	42	TREE LIMB BROKEN - SECONDARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/9/98 10:31 PM	3659	48	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 11:09 PM	1581	1062	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 11:23 PM	927	188	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/9/98 11:25 PM	2375	20	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 1:40 AM	3440	34	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	NEUTRAL WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 4:29 AM	1606	225	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 5:01 AM	356	16	WEATHER - ICE	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
3/10/98 5:31 AM	2908	29	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 5:55 AM	2675	44	WEATHER - ICE	OVERHEAD TRANSFORMER	REPAIRED TRANSFORMER	FIELD INSPECTION	NO
3/10/98 6:01 AM	1709	857	WEATHER - ICE	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 6:14 AM	1116	374	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 6:16 AM	764	33	WEATHER - ICE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/10/98 6:30 AM	643	531	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 6:32 AM	1573	50	WEATHER - ICE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/10/98 6:52 AM	1970	719	WEATHER - ICE	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 7:11 AM	2076	716	WEATHER - WIND	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 7:14 AM	646	147	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 7:41 AM	1879	41	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 7:46 AM	814	687	PUBLIC - FOREIGN OBJECT	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
3/10/98 7:53 AM	797	11	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 8:19 AM	3041	24	TRANSMISSION AND SUBSTATION	NEUTRAL WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
EQUIPMENT - SUBSTATION EQUIPMENT							
3/10/98 8:27 AM	1833	41	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 8:36 AM	419	16	WEATHER - WIND	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/10/98 8:41 AM	744	4600	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 8:43 AM	1727	394	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
EQUIPMENT - SUBSTATION EQUIPMENT							
3/10/98 8:55 AM	1805	61	TREE LIMB BROKEN - SECONDARY	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/10/98 9:19 AM	1781	53	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 9:19 AM	1909	25	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 9:23 AM	1777	58	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 9:23 AM	2977	43	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	NEUTRAL WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
EQUIPMENT - SUBSTATION EQUIPMENT							
3/10/98 9:31 AM	779	1167	WEATHER - WIND	TAP WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 9:40 AM	2000	419	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 9:46 AM	2954	30	TREE CONTACT - SECONDARY	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/10/98 9:56 AM	274	1415	WEATHER - WIND	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/10/98 9:58 AM	1543	1210	WEATHER - ICE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/10/98 10:08 AM	412	1597	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 10:08 AM	1616	630	WEATHER - ICE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/10/98 10:09 AM	151	953	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 10:25 AM	1715	34	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 10:47 AM	1693	32	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 10:48 AM	77	1394	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/10/98 10:51 AM	1709	357	WEATHER - WIND	PHASE WIRE	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/10/98 10:59 AM	2341	46	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 11:07 AM	2873	18	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
EQUIPMENT - SUBSTATION EQUIPMENT							
3/10/98 11:30 AM	1835	21	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
EQUIPMENT - SUBSTATION EQUIPMENT							
3/10/98 11:40 AM	1640	54	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 11:53 AM	1043	271	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 11:58 AM	577	941	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 12:02 PM	2278	26	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 12:05 PM	1615	22	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 12:10 PM	2885	38	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 12:12 PM	2808	32	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	NEUTRAL WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
EQUIPMENT - SUBSTATION EQUIPMENT							
3/10/98 12:16 PM	1604	111	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 12:28 PM	1592	34	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 1:43 PM	1552	1623	WEATHER - ICE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/10/98 1:50 PM	935	233	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
3/10/98 2:12 PM	2693	31	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 2:26 PM	1574	14	WEATHER - WIND	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/10/98 2:32 PM	838	144	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 3:25 PM	530	690	WEATHER - ICE	SUBSTATION BREAKER	CLOSED SUBSTATION BREAKER	FIELD INSPECTION	NO
3/10/98 3:31 PM	1409	62	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 3:42 PM	1398	65	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 4:19 PM	1361	35	TREE LIMB BROKEN - SECONDARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/10/98 4:28 PM	1352	94	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 4:37 PM	53	464	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 4:40 PM	2750	17	TREE LIMB BROKEN - SECONDARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/10/98 4:44 PM	2536	42	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	NEUTRAL WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
EQUIPMENT - SUBSTATION EQUIPMENT							
3/10/98 4:50 PM	47	269	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 5:09 PM	1311	75	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 5:10 PM	1310	120	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 5:28 PM	2522	29	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 5:32 PM	1288	28	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 5:48 PM	2082	53	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 6:16 PM	1716	40	WEATHER - ICE	OVERHEAD TRANSFORMER	REPAIRED TRANSFORMER	FIELD INSPECTION	NO
3/10/98 6:44 PM	1446	44	UNKNOWN	OVERHEAD TRANSFORMER	CHANGED SIZE	FIELD INSPECTION	YES
3/10/98 6:46 PM	1214	77	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
3/10/98 7:02 PM	1198	49	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 7:02 PM	1828	36	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 8:16 PM	2419	20	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	NEUTRAL WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 8:55 PM	1325	40	WEATHER - ICE	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 8:57 PM	468	476	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 9:09 PM	1071	36	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 11:19 PM	20	405	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/10/98 11:22 PM	938	73	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/11/98 3:00 AM	480	2338	WEATHER - ICE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/11/98 4:34 AM	1446	839	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/11/98 4:56 AM	544	86	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/11/98 5:09 AM	1281	50	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/11/98 5:46 AM	474	338	WEATHER - ICE	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/11/98 5:58 AM	797	2545	WEATHER - ICE	POLE	REPLACED EQUIPMENT	FIELD INSPECTION	NO
3/11/98 7:08 AM	182	209	OVERHEAD EQUIPMENT - MALFUNCTION	FUSE/CUTOUT	REPLACED TRANSFORMER	FIELD INSPECTION	NO
3/11/98 7:19 AM	251	1360	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/11/98 7:35 AM	244	23	WEATHER - ICE	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/11/98 7:39 AM	357	339	WEATHER - ICE	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/11/98 7:52 AM	448	1976	WEATHER - ICE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/11/98 7:57 AM	1353	37	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/11/98 8:13 AM	262	4825	WEATHER - ICE	FUSE/CUTOUT	CHANGED OTHER	FIELD INSPECTION	NO
3/11/98 8:47 AM	988	27	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/11/98 8:49 AM	581	71	WEATHER - ICE	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/11/98 9:03 AM	907	24	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/11/98 9:13 AM	525	85	WEATHER - ICE	PHASE WIRE	TEMPORARY JUMPER TO RESTORE	FIELD INSPECTION	NO
3/11/98 9:22 AM	1352	25	WEATHER - FLOODING/RAIN	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/11/98 10:16 AM	1904	76	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/11/98 11:04 AM	716	25	TREE LIMB BROKEN - SECONDARY	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/11/98 11:09 AM	908	32	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/11/98 11:30 AM	1470	41	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/11/98 11:58 AM	813	22	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/11/98 12:26 PM	379	775	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/11/98 12:55 PM	1805	56	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/11/98 2:19 PM	41	823	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/11/98 3:37 PM	73	13	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/11/98 3:46 PM	594	32	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/11/98 3:47 PM	1033	16	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/11/98 3:56 PM	64	1991	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/11/98 4:27 PM	1113	14	TREE LIMB BROKEN - SECONDARY	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/11/98 4:59 PM	1201	26	TREE LIMB BROKEN - SECONDARY	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/11/98 5:15 PM	1371	49	WEATHER - ICE	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/11/98 5:41 PM	579	59	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/11/98 6:14 PM	1006	18	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/11/98 6:46 PM	997	62	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/11/98 7:34 PM	1076	38	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/11/98 8:08 PM	902	20	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/11/98 8:57 PM	1023	37	TREE LIMB BROKEN - SECONDARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/11/98 10:13 PM	537	20	TREE LIMB BROKEN - PRIMARY	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/11/98 11:03 PM	1527	110	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/11/98 11:08 PM	1931	70	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/11/98 11:18 PM	281	23	WEATHER - ICE	FUSE/CUTOUT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/11/98 11:59 PM	135	20	TREE CONTACT - SECONDARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/12/98 2:37 AM	233	24	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/12/98 2:46 AM	101	30	TREE CONTACT - SECONDARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/12/98 3:42 AM	151	19	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/12/98 7:33 AM	2592	88	UNKNOWN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	YES
3/12/98 7:36 AM	989	55	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
3/12/98 8:04 AM	356	60	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/12/98 8:40 AM	605	20	PUBLIC - ACCIDENT BY OTHERS	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
3/12/98 9:22 AM	458	65	TREE LIMB BROKEN - SECONDARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/12/98 9:35 AM	625	37	TREE LIMB BROKEN - SECONDARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/12/98 10:04 AM	416	52	TREE LIMB BROKEN - SECONDARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/12/98 10:21 AM	147	1830	PUBLIC - FOREIGN OBJECT	PHASE WIRE	CLOSED SECTIONALIZER	NO ACTION NEEDED	NO
3/12/98 10:44 AM	76	1183	WEATHER - FLOODING/RAIN	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/12/98 11:22 AM	908	45	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/12/98 11:55 AM	305	38	TREE LIMB BROKEN - SECONDARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/12/98 1:09 PM	231	21	TREE LIMB BROKEN - SECONDARY	NEUTRAL WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/12/98 1:45 PM	30	1038	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
3/12/98 1:50 PM	60	1357	TREE CONTACT - PRIMARY	PHASE WIRE	TREE TRIMMED	TREE TRIMMING	NO
3/12/98 2:11 PM	649	30	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/12/98 3:36 PM	534	50	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/12/98 3:42 PM	558	59	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/12/98 4:12 PM	228	40	TREE LIMB BROKEN - SECONDARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/12/98 4:13 PM	207	49	TREE LIMB BROKEN - SECONDARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/12/98 4:55 PM	635	52	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/12/98 5:35 PM	25	1080	OTHER	SWITCH/DISCONNECT/LTD	OTHER	FIELD INSPECTION	NO
3/12/98 6:45 PM	375	34	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/12/98 6:51 PM	281	3358	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/12/98 11:42 PM	228	25	WEATHER - ICE	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/13/98 3:37 AM	73	3973	UNDERGROUND EQUIPMENT - MALFUNCTION	CABLE	TEMPORARY JUMPER TO RESTORE	FIELD INSPECTION	NO
3/13/98 6:45 AM	90	261	PUBLIC - FOREIGN OBJECT	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
3/13/98 7:56 AM	754	70	UNKNOWN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	YES
3/13/98 9:13 AM	1217	32	TREE LIMB BROKEN - SECONDARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/13/98 10:48 AM	137	405	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/13/98 11:44 AM	138	72	WEATHER - ICE	FUSE/CUTOUT	REPAIRED EQUIPMENT	FIELD INSPECTION	NO
3/13/98 12:37 PM	87	612	WEATHER - ICE	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/13/98 1:39 PM	201	102	WEATHER - ICE	NEUTRAL WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/13/98 2:16 PM	381	69	TREE LIMB BROKEN - SECONDARY	PHASE WIRE	REPLACED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/13/98 3:07 PM	289	1317	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/13/98 4:02 PM	112	3445	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/13/98 4:13 PM	94	3580	WEATHER - ICE	POLE	REPAIRED EQUIPMENT	FIELD INSPECTION	NO
3/13/98 4:34 PM	156	2019	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/13/98 5:18 PM	545	46	TREE LIMB BROKEN - SECONDARY	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/13/98 6:59 PM	77	31	PUBLIC - VEHICLES	FUSE/CUTOUT	REPAIRED EQUIPMENT	NO ACTION NEEDED	NO
3/13/98 7:47 PM	163	85	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/14/98 12:30 AM	330	64	UNKNOWN	SECTIONALIZER	TEMPORARY SWITCHING	FIELD INSPECTION	NO
3/14/98 1:33 AM	2218	47	OVERHEAD EQUIPMENT - MALFUNCTION	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	YES
3/14/98 3:28 AM	777	77	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	YES
3/14/98 7:30 AM	1931	59	TREE LIMB BROKEN - SECONDARY	AERIAL CABLE	REPLACED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/14/98 9:40 AM	1828	113	OTHER	CONNECTOR/SLEEVE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/14/98 10:38 AM	355	45	TREE LIMB BROKEN - SECONDARY	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/14/98 10:56 AM	1323	33	WEATHER - WIND	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/14/98 2:30 PM	345	89	WEATHER - ICE	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
3/14/98 8:55 PM	671	23	TREE LIMB BROKEN - SECONDARY	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/14/98 11:01 PM	154	3582	WEATHER - ICE	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
3/15/98 2:23 PM	82	21	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
3/16/98 1:30 AM	440	19	WEATHER - WIND	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
3/16/98 11:28 AM	14	3743	OTHER	SWITCH/DISCONNECT/LTD	TEMPORARY SWITCHING	FIELD INSPECTION	NO
3/16/98 1:02 PM	1733	39	TREE LIMB BROKEN - SECONDARY	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/16/98 1:30 PM	1684	20	TREE LIMB BROKEN - SECONDARY	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/16/98 2:22 PM	188	33	UNKNOWN	CABLE JOINT/SPLICE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
3/16/98 3:07 PM	193	497	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/16/98 6:07 PM	90	3746	PUBLIC - VEHICLES	TIE WIRE	REPLACED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
3/16/98 11:16 PM	104	1175	OTHER	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
3/17/98 8:59 AM	106	533	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/17/98 10:12 AM	203	42	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/17/98 10:13 AM	307	1269	WEATHER - FLOODING/RAIN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
3/17/98 10:34 AM	106	1758	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
3/17/98 10:41 AM	354	1775	WEATHER - FLOODING/RAIN	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/17/98 10:56 AM	164	56	WEATHER - FLOODING/RAIN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/17/98 11:47 AM	461	269	OTHER	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/17/98 1:46 PM	252	954	WEATHER - FLOODING/RAIN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/17/98 3:30 PM	164	33	TREE LIMB BROKEN - SECONDARY	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/17/98 3:40 PM	61	31	WEATHER - ICE	OVERHEAD TRANSFORMER	REPAIRED TRANSFORMER	FIELD INSPECTION	NO
3/17/98 3:44 PM	241	1915	PUBLIC - FOREIGN OBJECT	SWITCH/DISCONNECT/LTD	OTHER	NO ACTION NEEDED	NO
3/17/98 3:45 PM	150	64	OTHER	FUSE/CUTOUT	OTHER	FIELD INSPECTION	NO
3/17/98 4:33 PM	97	125	OTHER	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
3/17/98 7:25 PM	95	69	TREE LIMB BROKEN - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
3/17/98 10:12 PM	118	1124	WEATHER - FLOODING/RAIN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/17/98 10:40 PM	200	35	WEATHER - ICE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/18/98 12:33 AM	162	85	TREE CONTACT - PRIMARY	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/18/98 3:47 AM	89	58	WEATHER - FLOODING/RAIN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/18/98 4:02 AM	148	18	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
3/18/98 7:13 AM	78	1612	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
3/18/98 8:09 AM	171	65	WEATHER - FLOODING/RAIN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/18/98 11:45 AM	100	85	PUBLIC - ACCIDENT BY OTHERS	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
3/18/98 1:13 PM	132	71	WEATHER - ICE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/18/98 1:20 PM	40	3625	PUBLIC - DIG-IN BY OTHERS	CABLE	TEMPORARY SWITCHING	NO ACTION NEEDED	NO
3/18/98 1:58 PM	7	61	INTENTIONAL - EMERGENCY REPAIRS	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/18/98 6:17 PM	213	42	WEATHER - ICE	TAP WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/18/98 7:21 PM	164	47	UNKNOWN	TAP WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/18/98 7:44 PM	366	27	UNKNOWN	CONNECTOR/SLEEVE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/18/98 9:27 PM	74	878	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/19/98 8:52 AM	123	1720	UNKNOWN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/19/98 9:17 AM	133	1272	TREE CONTACT - PRIMARY	PHASE WIRE	TREE TRIMMED	TREE TRIMMING	NO
3/19/98 10:41 AM	24	2532	WEATHER - ICE	CROSS/ALLEY ARM	REPLACED EQUIPMENT	FIELD INSPECTION	NO
3/19/98 12:45 PM	120	26	TREE LIMB BROKEN - PRIMARY	OVERHEAD TRANSFORMER	OTHER	TREE TRIMMING	NO
3/19/98 1:25 PM	60	117	UNKNOWN	UNDERGROUND TRANSFORMER	REPAIRED TRANSFORMER	FIELD INSPECTION	NO
3/19/98 2:57 PM	33	1462	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
3/19/98 7:12 PM	160	75	OVERHEAD EQUIPMENT - MALFUNCTION	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/19/98 8:52 PM	58	329	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/19/98 9:46 PM	79	102	TREE LIMB BROKEN - SECONDARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
3/20/98 4:23 AM	117	25	TREE CONTACT - SECONDARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
3/20/98 7:08 AM	127	529	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/20/98 7:11 AM	54	874	WEATHER - FLOODING/RAIN	TAP WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/20/98 7:50 AM	240	64	WEATHER - WIND	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/20/98 8:41 AM	84	1055	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/20/98 9:29 AM	91	1171	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/20/98 10:13 AM	22	50	TREE CONTACT - SECONDARY	PHASE WIRE	REPAIRED EQUIPMENT	TREE TRIMMING	NO
3/20/98 12:17 PM	57	693	WEATHER - FLOODING/RAIN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/20/98 1:06 PM	204	28	WEATHER - WIND	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/20/98 1:26 PM	94	64	OTHER	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
3/20/98 4:03 PM	62	31	TREE LIMB BROKEN - PRIMARY	CROSS/ALLEY ARM	OTHER	TREE TRIMMING	NO
3/20/98 5:56 PM	28	5358	TREE CONTACT - PRIMARY	FUSE/CUTOUT	TEMPORARY SWITCHING	TREE TRIMMING	NO
3/20/98 10:52 PM	158	4756	WEATHER - WIND	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/21/98 3:07 AM	178	286	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/21/98 5:00 AM	200	54	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/21/98 7:14 PM	76	506	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
3/22/98 10:34 AM	66	453	WILDLIFE	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
3/22/98 2:17 PM	123	1606	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
3/22/98 2:21 PM	144	512	TREE CONTACT - PRIMARY	FUSE/CUTOUT	TEMPORARY JUMPER TO RESTORE	TREE TRIMMING	NO
3/22/98 7:03 PM	72	127	OVERHEAD EQUIPMENT - MALFUNCTION	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/23/98 7:36 AM	69	2437	OVERHEAD EQUIPMENT - MALFUNCTION	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/23/98 10:20 AM	430	316	INTENTIONAL - SCHEDULED CONSTRUCTION, MAINTENANCE, OR REPAIR	OVERHEAD TRANSFORMER	REPLACED EQUIPMENT	NO ACTION NEEDED	NO
3/23/98 12:40 PM	1510	15	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/23/98 2:01 PM	72	58	PUBLIC - VEHICLES	PHASE WIRE	REPLACED OVERHEAD MATERIAL	NO ACTION NEEDED	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
3/24/98 12:06 PM	54	32642	PUBLIC - DIG-IN BY OTHERS	CABLE	TEMPORARY SWITCHING	NO ACTION NEEDED	NO
3/24/98 1:26 PM	44	933	PUBLIC - DIG-IN BY OTHERS	CABLE	TEMPORARY SWITCHING	NO ACTION NEEDED	NO
3/24/98 3:45 PM	235	51	TREE CONTACT - SECONDARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/24/98 8:11 PM	14	34	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
3/24/98 11:14 PM	111	2718	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
3/25/98 2:07 AM	79	867	TREE CONTACT - PRIMARY	OTHER EQUIPMENT	OTHER	TREE TRIMMING	NO
3/25/98 7:56 PM	68	35	PUBLIC - FIRE	TAP WIRE	REPLACED EQUIPMENT	NO ACTION NEEDED	NO
3/25/98 10:53 PM	132	1913	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
3/26/98 8:44 AM	76	11	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
3/26/98 9:11 AM	154	44	WEATHER - WIND	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/26/98 10:04 AM	191	1379	UNDERGROUND EQUIPMENT - UG FAILURE	SUBSTATION BREAKER	TEMPORARY SWITCHING	FIELD INSPECTION	NO
3/26/98 10:05 AM	160	34	WEATHER - WIND	FUSE/CUTOUT	CHANGED OTHER	FIELD INSPECTION	NO
3/26/98 11:49 AM	296	364	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPLACED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/26/98 11:59 AM	138	66	WEATHER - WIND	FUSE/CUTOUT	OTHER	FIELD INSPECTION	NO
3/26/98 12:12 PM	528	141	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/26/98 1:50 PM	1389	857	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/26/98 1:54 PM	121	660	UNDERGROUND EQUIPMENT - UG FAILURE	SUBSTATION BREAKER	TEMPORARY SWITCHING	FIELD INSPECTION	NO
3/26/98 2:05 PM	175	10	WEATHER - WIND	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/26/98 2:28 PM	157	439	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/26/98 3:03 PM	62	269	WEATHER - WIND	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/26/98 4:29 PM	78	129	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/26/98 4:43 PM	587	12	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/26/98 4:57 PM	33	735	PUBLIC - FOREIGN OBJECT	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
3/26/98 5:08 PM	14	148	INTENTIONAL - EMERGENCY REPAIRS	FUSE/CUTOUT	TREE REMOVED	FIELD INSPECTION	NO
3/26/98 5:25 PM	85	1761	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	OTHER EQUIPMENT	TEMPORARY SWITCHING	FIELD INSPECTION	NO
3/26/98 5:46 PM	99	326	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/26/98 6:13 PM	60	684	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/26/98 7:43 PM	107	216	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
3/26/98 11:20 PM	145	2446	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
3/26/98 11:56 PM	289	48	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/27/98 9:34 AM	101	4775	PUBLIC - FOREIGN OBJECT	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
3/27/98 10:14 AM	71	213	WEATHER - WIND	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/27/98 11:23 AM	102	1162	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
3/27/98 1:36 PM	59	74	PUBLIC - DIG-IN BY OTHERS	CABLE	TEMPORARY SWITCHING	NO ACTION NEEDED	NO
3/27/98 1:44 PM	151	2108	WEATHER - WIND	CROSS/ALLEY ARM	TEMPORARY SWITCHING	FIELD INSPECTION	NO
3/27/98 2:23 PM	67	1971	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/27/98 4:03 PM	62	3058	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/27/98 5:01 PM	249	1215	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
3/27/98 5:43 PM	207	1421	WEATHER - WIND	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/27/98 6:21 PM	149	325	PUBLIC - FOREIGN OBJECT	PHASE WIRE	REPLACED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
3/28/98 5:25 AM	124	1597	OTHER	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/28/98 6:04 AM	186	419	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/28/98 7:10 AM	143	4055	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/28/98 9:12 AM	134	1220	TREE CONTACT - PRIMARY	PHASE WIRE	TREE TRIMMED	TREE TRIMMING	NO
3/28/98 9:40 AM	39	220	INTENTIONAL - PROTECTION OF SYSTEM INTEGRITY	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	NO ACTION NEEDED	NO
3/28/98 11:12 AM	168	893	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
3/28/98 1:39 PM	126	14	UNKNOWN	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/28/98 2:41 PM	104	1073	UNKNOWN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
3/28/98 7:28 PM	117	219	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/29/98 7:08 AM	83	1225	WILDLIFE	SUBSTATION BREAKER	CLOSED SUBSTATION BREAKER	ANIMAL GUARD CHECK	NO
3/29/98 11:52 AM	82	36	WILDLIFE	FUSE/CUTOUT	REPAIRED EQUIPMENT	ANIMAL GUARD CHECK	NO
3/29/98 4:20 PM	715	45	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
3/29/98 5:03 PM	82	954	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
3/29/98 5:25 PM	118	77	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/29/98 10:19 PM	12	284	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
3/29/98 10:19 PM	102	2296	PUBLIC - FOREIGN OBJECT	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	NO ACTION NEEDED	NO
3/29/98 10:55 PM	80	14	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/30/98 12:09 AM	166	1345	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
3/30/98 12:30 AM	209	103	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
3/30/98 2:28 AM	202	1215	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/30/98 3:20 AM	65	6502	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
3/30/98 9:10 AM	319	101	WEATHER - WIND	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/30/98 9:51 AM	428	281	TREE LIMB BROKEN - PRIMARY	POLE	REPAIRED EQUIPMENT	TREE TRIMMING	NO
3/30/98 12:24 PM	651	1110	UNDERGROUND EQUIPMENT - UG FAILURE	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
3/30/98 1:04 PM	51	1011	TREE CONTACT - PRIMARY	PHASE WIRE	TREE REMOVED	TREE TRIMMING	NO
3/30/98 2:12 PM	43	698	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
3/30/98 5:47 PM	17	1015	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
3/31/98 5:45 AM	115	1078	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/31/98 6:24 AM	201	162	WEATHER - FLOODING/RAIN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/31/98 7:14 AM	21	36	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
3/31/98 9:08 AM	155	18	WEATHER - FLOODING/RAIN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/31/98 10:30 AM	130	25	WEATHER - FLOODING/RAIN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/31/98 12:32 PM	65	7309	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	OTHER TRANSFORMER	TEMPORARY SWITCHING	FIELD INSPECTION	NO
3/31/98 1:10 PM	600	56	WILDLIFE	CABLE	REPAIRED OVERHEAD MATERIAL	ANIMAL GUARD CHECK	NO
3/31/98 2:01 PM	131	1011	TREE CONTACT - PRIMARY	PHASE WIRE	TREE REMOVED	TREE TRIMMING	NO
3/31/98 3:29 PM	91	22	WEATHER - FLOODING/RAIN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
3/31/98 4:25 PM	1175	12	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	YES
4/1/98 8:16 AM	165	2025	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
4/1/98 8:17 AM	45	637	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
4/1/98 8:27 AM	162	182	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
4/1/98 8:29 AM	48	1001	WEATHER - FLOODING/RAIN	INSULATOR	CLOSED SWITCH/DISCONNECT/LT	FIELD INSPECTION	NO
4/1/98 9:02 AM	15	221	WEATHER - FLOODING/RAIN	INSULATOR	TEMPORARY SWITCHING	FIELD INSPECTION	NO
4/1/98 11:45 AM	70	709	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
4/1/98 7:18 PM	102	661	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
4/1/98 10:49 PM	81	67	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
4/2/98 8:12 AM	67	158	WILDLIFE	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
4/2/98 9:18 AM	81	10	PUBLIC - ACCIDENT BY OTHERS	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	NO ACTION NEEDED	NO
4/2/98 8:18 PM	52	1045	PUBLIC - ACCIDENT BY OTHERS	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	NO ACTION NEEDED	NO
4/3/98 11:19 AM	166	1676	WEATHER - LIGHTNING	TAP WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
4/3/98 6:12 PM	132	4923	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	TREE REMOVED	TREE TRIMMING	NO
4/4/98 7:51 AM	112	542	TREE CONTACT - PRIMARY	PHASE WIRE	TREE REMOVED	TREE TRIMMING	NO
4/4/98 8:56 AM	74	432	PUBLIC - FOREIGN OBJECT	PHASE WIRE	REPLACED FUSE OR CUTOUT	NO ACTION NEEDED	NO
4/4/98 10:55 AM	36	20	OTHER	CROSS/ALLEY ARM	TEMPORARY SWITCHING	FIELD INSPECTION	NO
4/4/98 11:36 AM	82	1513	TREE CONTACT - PRIMARY	PHASE WIRE	TREE TRIMMED	TREE TRIMMING	NO
4/4/98 5:47 PM	53	1314	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
4/4/98 8:16 PM	34	1528	OTHER	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
4/4/98 8:16 PM	43	1310	OTHER	SUBSTATION BREAKER	TEMPORARY SWITCHING	FIELD INSPECTION	NO
4/5/98 2:42 PM	108	81	PUBLIC - FOREIGN OBJECT	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	NO ACTION NEEDED	NO
4/6/98 4:38 PM	67	30	OVERHEAD EQUIPMENT - MALFUNCTION	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
4/7/98 7:22 PM	88	816	WEATHER - LIGHTNING	ARRESTER	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
4/7/98 7:30 PM	102	679	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
4/7/98 9:28 PM	232	986	UNDERGROUND EQUIPMENT - UG FAILURE	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
4/7/98 9:43 PM	527	28	WEATHER - LIGHTNING	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
4/8/98 10:58 AM	43	6272	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
4/8/98 11:35 AM	55	30	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
4/8/98 12:51 PM	1446	649	WEATHER - FLOODING/RAIN	ARRESTER	REPAIRED EQUIPMENT	FIELD INSPECTION	NO
4/8/98 4:22 PM	278	3468	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
4/9/98 12:46 AM	104	28	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
4/10/98 7:17 AM	35	4254	INTENTIONAL - EMERGENCY REPAIRS	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
4/10/98 2:43 PM	151	57	TREE CONTACT - SECONDARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
4/11/98 6:20 PM	140	898	UNKNOWN	CABLE JOINT/SPLICE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
4/12/98 9:43 AM	92	103	WILDLIFE	CROSS/ALLEY ARM	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
4/12/98 3:07 PM	98	1386	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
4/12/98 3:09 PM	460	414	WEATHER - WIND	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
4/12/98 3:10 PM	157	1517	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
4/13/98 6:29 AM	121	2289	TREE CONTACT - PRIMARY	TAP WIRE	REPLACED OVERHEAD MATERIAL	TREE TRIMMING	NO
4/13/98 11:31 AM	119	490	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
4/13/98 5:31 PM	59	40	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
4/13/98 7:50 PM	54	1759	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	SUBSTATION TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
4/13/98 8:05 PM	39	4715	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	SUBSTATION TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
4/13/98 9:00 PM	58	40	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
4/14/98 9:57 AM	31	38	PUBLIC - DIG-IN BY OTHERS	CABLE	TEMPORARY SWITCHING	NO ACTION NEEDED	NO
4/14/98 11:53 AM	72	339	INTENTIONAL - PROTECTION OF SYSTEM INTEGRITY	SWITCH/DISCONNECT/LTD	CLOSED SWITCH/DISCONNECT/LT	NO ACTION NEEDED	NO
4/14/98 12:03 PM	222	1732	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
4/14/98 12:52 PM	52	606	PUBLIC - VEHICLES	POLE	REPAIRED EQUIPMENT	NO ACTION NEEDED	NO
4/14/98 1:34 PM	256	27	PUBLIC - ACCIDENT BY OTHERS	POLE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
4/14/98 1:58 PM	49	497	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
4/14/98 2:08 PM	17	2092	UNKNOWN	CABLE JOINT/SPLICE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
4/14/98 5:17 PM	663	60	UNKNOWN	CABLE JOINT/SPLICE	REPAIRED UNDERGROUND MATERIAL	FIELD INSPECTION	NO
4/14/98 5:30 PM	181	61	OTHER	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
4/15/98 4:46 AM	89	1367	UNKNOWN	OTHER EQUIPMENT	TEMPORARY SWITCHING	FIELD INSPECTION	NO
4/15/98 4:55 AM	80	570	UNKNOWN	OTHER EQUIPMENT	TEMPORARY SWITCHING	FIELD INSPECTION	NO
4/15/98 4:57 AM	78	1158	UNKNOWN	OTHER EQUIPMENT	TEMPORARY SWITCHING	FIELD INSPECTION	NO
4/15/98 6:57 AM	75	50	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
4/15/98 12:20 PM	40	1885	WILDLIFE	FUSE/CUTOUT	TEMPORARY SWITCHING	ANIMAL GUARD CHECK	NO
4/15/98 9:04 PM	141	1462	UNDERGROUND EQUIPMENT - UG FAILURE	CABLE JOINT/SPLICE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
4/15/98 10:07 PM	152	2549	UNDERGROUND EQUIPMENT - UG FAILURE	CABLE JOINT/SPLICE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
4/16/98 1:35 AM	170	47	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
4/16/98 2:59 AM	131	144	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
4/16/98 5:42 AM	154	27	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
4/16/98 6:50 AM	200	2870	UNDERGROUND EQUIPMENT - UG FAILURE	OTHER EQUIPMENT	TEMPORARY SWITCHING	FIELD INSPECTION	NO
4/16/98 7:17 AM	463	272	WILDLIFE	SWITCH/DISCONNECT/LTD	REPAIRED UNDERGROUND MATERIAL	ANIMAL GUARD CHECK	NO
4/16/98 10:42 AM	13	314	TREE CONTACT - PRIMARY	PHASE WIRE	TREE REMOVED	TREE TRIMMING	NO
4/16/98 3:35 PM	70	60	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
4/16/98 5:31 PM	74	605	OTHER	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
4/16/98 10:59 PM	286	57	WEATHER - FLOODING/RAIN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
4/17/98 9:14 AM	76	193	WILDLIFE	PHASE WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
4/17/98 2:49 PM	106	15	PUBLIC - VEHICLES	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
4/17/98 3:35 PM	75	354	PUBLIC - VEHICLES	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
4/17/98 6:43 PM	12	200	INTENTIONAL - PROTECTION OF SYSTEM INTEGRITY	CROSS/ALLEY ARM	OTHER	NO ACTION NEEDED	NO
4/17/98 7:22 PM	263	61	OTHER	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
4/18/98 1:28 AM	213	93	PUBLIC - FOREIGN OBJECT	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	NO ACTION NEEDED	NO
4/18/98 1:39 AM	146	33	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
4/18/98 8:34 AM	196	609	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
4/18/98 10:09 AM	14	1058	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
4/18/98 2:03 PM	142	267	UNKNOWN	CONNECTOR/SLEEVE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
4/18/98 3:05 PM	105	173	WILDLIFE	TAP WIRE	REPAIRED OVERHEAD MATERIAL	ANIMAL GUARD CHECK	NO
4/18/98 3:26 PM	49	28	WILDLIFE	PHASE WIRE	REPLACED OVERHEAD MATERIAL	ANIMAL GUARD CHECK	NO
4/19/98 12:56 AM	78	4803	WILDLIFE	SUBSTATION BREAKER	CLOSED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
4/19/98 1:11 AM	49	218	WILDLIFE	SWITCHGEAR	TEMPORARY SWITCHING	ANIMAL GUARD CHECK	NO
4/19/98 1:38 AM	44	956	PUBLIC - FOREIGN OBJECT	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	NO ACTION NEEDED	NO
4/19/98 7:47 AM	93	54	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
4/19/98 4:34 PM	576	28	OVERHEAD EQUIPMENT - MALFUNCTION	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
4/20/98 4:11 PM	291	137	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
4/20/98 4:12 PM	290	269	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
4/20/98 4:15 PM	287	422	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
4/20/98 4:16 PM	286	173	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
4/20/98 4:16 PM	286	423	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
4/20/98 8:28 PM	152	144	OVERHEAD EQUIPMENT - MALFUNCTION	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
4/20/98 10:41 PM	124	810	WEATHER - LIGHTNING	SUBSTATION BREAKER	OTHER	FIELD INSPECTION	NO
4/20/98 10:46 PM	119	155	WEATHER - LIGHTNING	SUBSTATION BREAKER	CLOSED SUBSTATION BREAKER	FIELD INSPECTION	NO
4/20/98 10:48 PM	117	3082	WEATHER - LIGHTNING	SUBSTATION BREAKER	CLOSED SUBSTATION BREAKER	FIELD INSPECTION	NO
4/21/98 2:52 PM	46	427	UNKNOWN	PHASE WIRE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
4/21/98 3:56 PM	154	47	PUBLIC - FOREIGN OBJECT	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
4/22/98 11:12 PM	173	269	UNDERGROUND EQUIPMENT - UG FAILURE	CABLE JOINT/SPLICE	TEMPORARY SWITCHING	FIELD INSPECTION	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
4/23/98 2:16 PM	519	113	PUBLIC - FOREIGN OBJECT	UNDERGROUND TRANSFORMER	REPLACED TRANSFORMER	NO ACTION NEEDED	NO
4/24/98 10:02 AM	613	25	PUBLIC - ACCIDENT BY OTHERS	PHASE WIRE	TEMPORARY SWITCHING	NO ACTION NEEDED	NO
4/24/98 10:11 AM	17	31	PUBLIC - ACCIDENT BY OTHERS	POLE	REPLACED EQUIPMENT	NO ACTION NEEDED	NO
4/24/98 10:46 AM	478	449	PUBLIC - ACCIDENT BY OTHERS	PHASE WIRE	REPLACED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
4/24/98 5:10 PM	30	73	OTHER	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
4/25/98 7:16 AM	524	1406	OTHER	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
4/25/98 9:48 AM	150	36	WILDLIFE	FUSE/CUTOUT	REPLACED OVERHEAD MATERIAL	ANIMAL GUARD CHECK	NO
4/25/98 6:01 PM	141	391	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
4/25/98 8:56 PM	37	286	UNKNOWN	CABLE JOINT/SPLICE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
4/26/98 1:45 AM	465	29	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
4/26/98 1:48 AM	117	26	WEATHER - LIGHTNING	CABLE JOINT/SPLICE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
4/26/98 1:48 AM	117	94	WEATHER - LIGHTNING	CABLE JOINT/SPLICE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
4/26/98 1:51 AM	69	411	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
4/26/98 4:49 AM	1	94	WEATHER - FLOODING/RAIN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
4/26/98 1:25 PM	41	13	TREE CONTACT - PRIMARY	PHASE WIRE	TEMPORARY SWITCHING	TREE TRIMMING	NO
4/26/98 2:08 PM	142	52	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
4/26/98 4:17 PM	123	58	WEATHER - FLOODING/RAIN	OVERHEAD TRANSFORMER	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
4/26/98 4:21 PM	119	15	WEATHER - FLOODING/RAIN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
4/26/98 4:23 PM	172	54	WEATHER - FLOODING/RAIN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
4/26/98 4:28 PM	134	1347	UNKNOWN	SUBSTATION BREAKER	CLOSED SUBSTATION BREAKER	FIELD INSPECTION	NO
4/27/98 12:33 AM	12	11	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
4/27/98 7:46 AM	242	10	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
4/27/98 8:05 AM	196	63	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
4/27/98 8:21 AM	16	37	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
4/27/98 12:41 PM	29	1048	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
4/27/98 5:43 PM	207	204	TREE CONTACT - PRIMARY	PHASE WIRE	REPLACED OVERHEAD MATERIAL	TREE TRIMMING	NO
4/27/98 8:35 PM	125	60	UNDERGROUND EQUIPMENT - UG FAILURE	TERMINATION	TEMPORARY SWITCHING	FIELD INSPECTION	NO
4/28/98 8:52 AM	94	521	PUBLIC - DIG-IN BY OTHERS	CABLE	TEMPORARY SWITCHING	NO ACTION NEEDED	NO
4/28/98 12:32 PM	18	59	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
4/28/98 2:01 PM	59	48	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
4/28/98 11:25 PM	145	65	UNKNOWN	FUSE/CUTOUT	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
4/29/98 2:49 AM	236	304	UNDERGROUND EQUIPMENT - UG FAILURE	CABLE JOINT/SPLICE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
4/29/98 8:46 AM	274	77	UNDERGROUND EQUIPMENT - UG FAILURE	CABLE JOINT/SPLICE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
4/29/98 9:39 AM	101	33	TREE CONTACT - PRIMARY	PHASE WIRE	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
4/29/98 12:12 PM	93	984	UNDERGROUND EQUIPMENT - UG FAILURE	CABLE JOINT/SPLICE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
4/29/98 3:31 PM	49	1909	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
4/29/98 4:08 PM	112	18	WILDLIFE	FUSE/CUTOUT	REPLACED OVERHEAD MATERIAL	ANIMAL GUARD CHECK	NO
4/30/98 10:51 AM	89	117	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
4/30/98 8:54 PM	181	71	OTHER	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
5/1/98 6:35 AM	120	7389	UNKNOWN	CABLE JOINT/SPLICE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
5/1/98 7:28 AM	75	4456	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
5/1/98 1:05 PM	120	26	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
5/1/98 3:26 PM	189	45	TREE CONTACT - PRIMARY	PHASE WIRE	REPLACED OVERHEAD MATERIAL	TREE TRIMMING	NO
5/2/98 7:05 AM	160	175	OTHER	PHASE WIRE	TEMPORARY JUMPER TO RESTORE	FIELD INSPECTION	NO
5/2/98 4:44 PM	11	81	OTHER	OVERHEAD TRANSFORMER	REPAIRED TRANSFORMER	FIELD INSPECTION	NO
5/3/98 8:18 AM	142	22	WILDLIFE	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
5/3/98 3:39 PM	156	57	PUBLIC - VANDALISM	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
5/3/98 8:31 PM	76	874	PUBLIC - FOREIGN OBJECT	CONNECTOR/SLEEVE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
5/4/98 9:05 AM	55	778	WILDLIFE	PHASE WIRE	TEMPORARY SWITCHING	ANIMAL GUARD CHECK	NO
5/4/98 3:45 PM	18	350	UNDERGROUND EQUIPMENT - UG FAILURE	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
5/5/98 10:28 AM	47	379	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
5/5/98 12:42 PM	103	99	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
5/5/98 3:20 PM	70	7349	PUBLIC - ACCIDENT BY OTHERS	PHASE WIRE	TEMPORARY SWITCHING	NO ACTION NEEDED	NO
5/5/98 10:13 PM	202	19	PUBLIC - ACCIDENT BY OTHERS	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
5/6/98 6:26 AM	74	41	TREE CONTACT - PRIMARY	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
5/6/98 11:30 AM	20	11	UNKNOWN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
5/6/98 12:25 PM	30	715	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
5/6/98 1:36 PM	64	458	UNKNOWN	OTHER EQUIPMENT	TEMPORARY SWITCHING	FIELD INSPECTION	NO
5/6/98 1:53 PM	107	2666	WEATHER - LIGHTNING	OTHER EQUIPMENT	TEMPORARY SWITCHING	FIELD INSPECTION	NO
5/6/98 2:37 PM	853	205	WEATHER - LIGHTNING	UNDERGROUND	REPLACED TRANSFORMER	FIELD INSPECTION	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
				TRANSFORMER			
5/6/98 2:49 PM	66	39	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
5/7/98 3:14 AM	136	1080	WEATHER - FLOODING/RAIN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
5/7/98 6:24 AM	82	121	WEATHER - FLOODING/RAIN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
5/7/98 8:16 AM	112	11	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
5/7/98 11:29 AM	76	25	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
5/7/98 12:27 PM	138	2970	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
5/7/98 1:22 PM	33	1240	UNKNOWN	OTHER EQUIPMENT	TEMPORARY SWITCHING	FIELD INSPECTION	NO
5/7/98 1:45 PM	158	14	UNKNOWN	NEUTRAL WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
5/8/98 4:11 AM	64	23	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
5/8/98 9:44 AM	81	23	UNKNOWN	OVERHEAD TRANSFORMER	TEMPORARY JUMPER TO RESTORE	FIELD INSPECTION	NO
5/8/98 12:01 PM	86	3256	UNKNOWN	CABLE JOINT/SPLICE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
5/8/98 12:02 PM	84	1710	UNKNOWN	CABLE JOINT/SPLICE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
5/8/98 12:34 PM	141	675	OTHER	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
5/8/98 2:25 PM	245	119	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
5/9/98 2:15 PM	350	719	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
5/10/98 12:32 AM	80	930	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
5/10/98 6:44 AM	164	233	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
5/10/98 7:10 AM	180	117	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
5/11/98 10:45 AM	90	40	PUBLIC - FOREIGN OBJECT	PHASE WIRE	REPAIRED TRANSFORMER	NO ACTION NEEDED	NO
5/11/98 5:05 PM	55	27	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
5/11/98 7:18 PM	77	700	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
5/12/98 8:28 AM	62	474	WILDLIFE	ARRESTER	OTHER	ANIMAL GUARD CHECK	NO
5/12/98 10:03 AM	107	38	OTHER	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
5/12/98 1:51 PM	111	5250	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
5/12/98 9:45 PM	120	1311	WEATHER - LIGHTNING	SWITCH/DISCONNECT/LTD	OTHER	FIELD INSPECTION	NO
5/12/98 10:34 PM	56	47	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
5/13/98 2:08 AM	87	60	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
5/13/98 9:35 AM	260	37	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
5/13/98 11:15 AM	80	2967	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
5/13/98 11:17 AM	183	2549	PUBLIC - DIG-IN BY OTHERS	CABLE	TEMPORARY SWITCHING	NO ACTION NEEDED	NO
5/13/98 9:05 PM	10	306	INTENTIONAL - PROTECTION OF SYSTEM INTEGRITY	SWITCH/DISCONNECT/LTD	REPLACED EQUIPMENT	NO ACTION NEEDED	NO
5/14/98 1:49 PM	131	19	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
5/14/98 4:31 PM	279	16	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
5/14/98 4:41 PM	59	476	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
5/15/98 6:03 AM	87	94	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
5/15/98 8:41 AM	139	11	CUSTOMER - OVERLOAD	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	NO ACTION NEEDED	NO
5/15/98 11:20 AM	235	427	WEATHER - WIND	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
5/15/98 1:54 PM	136	511	OTHER	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
5/15/98 2:08 PM	22	191	OTHER	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
5/15/98 2:43 PM	1	214	OTHER	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
5/15/98 3:03 PM	82	80	TREE CONTACT - SECONDARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
5/15/98 3:45 PM	60	98	OTHER	SWITCH/DISCONNECT/LTD	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
5/15/98 4:39 PM	71	45	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
5/15/98 4:47 PM	133	553	PUBLIC - VANDALISM	PHASE WIRE	REPLACED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
5/15/98 9:49 PM	203	401	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
5/15/98 10:29 PM	51	345	TREE CONTACT - PRIMARY	TAP WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
5/16/98 3:27 AM	110	46	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
5/16/98 6:55 AM	85	375	WEATHER - WIND	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
5/16/98 8:07 AM	86	101	OTHER	FUSE/CUTOUT	TEMPORARY SWITCHING	FIELD INSPECTION	NO
5/16/98 10:59 AM	121	35	OVERHEAD EQUIPMENT - MALFUNCTION	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
5/16/98 8:07 PM	68	314	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
5/17/98 6:16 AM	274	108	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
5/17/98 8:27 AM	133	7718	UNDERGROUND EQUIPMENT - UG FAILURE	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
5/17/98 9:40 AM	660	86	WEATHER - FLOODING/RAIN	CABLE JOINT/SPLICE	REPAIRED UNDERGROUND MATERIAL	FIELD INSPECTION	NO
5/17/98 3:50 PM	120	3004	UNKNOWN	CABLE JOINT/SPLICE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
5/17/98 5:53 PM	77	103	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
5/17/98 10:53 PM	44	5785	UNKNOWN	CABLE JOINT/SPLICE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
5/18/98 7:21 AM	169	50	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
5/18/98 7:39 AM	31	813	COMED/CONTRACTOR - DIG-IN BY	CABLE	TEMPORARY SWITCHING	TRAINING	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
			CONTRACTOR				
5/18/98 1:38 PM	74	334	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
5/18/98 1:42 PM	65	214	UNKNOWN	TAP WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
5/18/98 3:43 PM	67	51	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
5/18/98 7:48 PM	129	133	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
5/18/98 10:28 PM	172	1222	PUBLIC - FIRE	PHASE WIRE	TEMPORARY SWITCHING	NO ACTION NEEDED	NO
5/18/98 10:30 PM	170	216	PUBLIC - FIRE	PHASE WIRE	TEMPORARY SWITCHING	NO ACTION NEEDED	NO
5/19/98 6:13 AM	27	102	PUBLIC - FOREIGN OBJECT	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	NO ACTION NEEDED	NO
5/19/98 6:40 AM	270	31	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
5/19/98 7:18 AM	62	17	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
5/19/98 2:41 PM	82	53	UNKNOWN	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
5/19/98 2:43 PM	402	55	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
5/20/98 2:28 AM	47	1368	OTHER	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
5/23/98 7:35 AM	170	51	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
5/23/98 3:32 PM	192	972	PUBLIC - FOREIGN OBJECT	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
5/23/98 9:04 PM	36	311	UNKNOWN	CABLE JOINT/SPLICE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
5/24/98 7:23 AM	642	96	OTHER	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
5/24/98 7:42 AM	578	84	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
5/24/98 7:51 AM	74	29	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
5/24/98 8:05 AM	180	258	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
5/24/98 8:13 AM	230	94	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
5/24/98 8:26 AM	439	35	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
5/24/98 10:32 AM	94	29	COMED/CONTRACTOR - ACCIDENT BY COMED	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TRAINING	NO
5/24/98 6:07 PM	42	2897	INTENTIONAL - EMERGENCY REPAIRS	SECTIONALIZER	CLOSED SECTIONALIZER	FIELD INSPECTION	NO
5/24/98 7:48 PM	107	1119	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
5/24/98 9:05 PM	5	17	TREE CONTACT - PRIMARY	NEUTRAL WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
5/25/98 9:56 AM	94	12	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
5/26/98 11:27 AM	61	692	PUBLIC - ACCIDENT BY OTHERS	POLE	TEMPORARY SWITCHING	NO ACTION NEEDED	NO
5/26/98 5:19 PM	168	4134	UNDERGROUND EQUIPMENT - UG FAILURE	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
5/27/98 8:54 AM	79	59	UNKNOWN	CABLE JOINT/SPLICE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
5/27/98 9:58 AM	107	16	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
5/27/98 3:40 PM	105	234	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
5/27/98 4:16 PM	109	12386	UNKNOWN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
5/27/98 5:03 PM	102	304	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
5/27/98 7:19 PM	66	74	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
5/28/98 8:12 AM	153	1204	UNKNOWN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
5/28/98 11:55 AM	65	266	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
5/28/98 2:40 PM	80	103	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
5/28/98 5:22 PM	183	4314	OTHER	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
5/28/98 9:14 PM	501	89	WEATHER - LIGHTNING	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
5/28/98 10:45 PM	275	2979	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
5/28/98 10:45 PM	345	91	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
5/28/98 10:48 PM	357	169	WEATHER - LIGHTNING	PHASE WIRE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
5/28/98 10:48 PM	642	150	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
5/28/98 10:50 PM	375	195	WEATHER - WIND	POLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
5/28/98 10:50 PM	677	13	TREE CONTACT - SECONDARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
5/28/98 10:53 PM	259	2205	WEATHER - LIGHTNING	OTHER EQUIPMENT	TEMPORARY SWITCHING	FIELD INSPECTION	NO
5/28/98 10:53 PM	717	54	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
5/28/98 10:54 PM	636	51	TREE CONTACT - SECONDARY	FUSE/CUTOUT	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
5/28/98 10:55 PM	370	52	WEATHER - FLOODING/RAIN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
5/28/98 10:56 PM	106	691	WEATHER - WIND	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
5/28/98 10:56 PM	667	81	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPAIRED EQUIPMENT	TREE TRIMMING	NO
5/28/98 10:58 PM	642	17	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
5/28/98 10:59 PM	581	13	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
5/28/98 10:59 PM	646	519	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
5/28/98 11:00 PM	600	84	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
5/28/98 11:03 PM	277	1672	WEATHER - FLOODING/RAIN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
5/28/98 11:05 PM	520	126	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
5/28/98 11:06 PM	704	201	WEATHER - LIGHTNING	FUSE/CUTOUT	TEMPORARY SWITCHING	FIELD INSPECTION	NO
5/28/98 11:08 PM	607	679	TREE CONTACT - PRIMARY	POLE	TEMPORARY SWITCHING	TREE TRIMMING	NO
5/28/98 11:09 PM	96	308	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
5/28/98 11:09 PM	793	61	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
5/28/98 11:10 PM	163	2593	WEATHER - LIGHTNING	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
5/28/98 11:40 PM	623	76	TREE CONTACT - SECONDARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
5/29/98 1:32 AM	513	19	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
5/29/98 3:04 AM	91	458	OTHER	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
5/29/98 3:28 AM	437	100	TREE CONTACT - PRIMARY	PHASE WIRE	REPLACED OTHER	TREE TRIMMING	NO
5/29/98 4:04 AM	71	195	OTHER	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
5/29/98 4:12 AM	583	84	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
5/29/98 6:18 AM	642	46	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
5/29/98 7:59 AM	171	53	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
5/29/98 8:33 AM	162	53	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
5/29/98 8:45 AM	465	251	WEATHER - LIGHTNING	POLE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
5/29/98 9:16 AM	664	679	TREE LIMB BROKEN - PRIMARY	POLE	REPLACED OVERHEAD MATERIAL	TREE TRIMMING	NO
5/29/98 10:24 AM	428	21	OTHER	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
5/29/98 10:59 AM	8	660	TREE CONTACT - PRIMARY	PHASE WIRE	TREE REMOVED	TREE TRIMMING	NO
5/29/98 7:52 PM	108	1802	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
5/30/98 1:32 PM	35	261	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
5/30/98 3:20 PM	45	22	TREE LIMB BROKEN - PRIMARY	FUSE/CUTOUT	TEMPORARY SWITCHING	TREE TRIMMING	NO
5/30/98 4:08 PM	112	112	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
5/30/98 8:14 PM	126	26	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OTHER	TREE TRIMMING	NO
5/30/98 8:21 PM	69	40	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
5/30/98 8:59 PM	46	2509	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
5/30/98 10:16 PM	509	51	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
5/30/98 10:31 PM	174	164	TREE CONTACT - PRIMARY	NEUTRAL WIRE	OTHER	TREE TRIMMING	NO
5/31/98 12:54 AM	166	148	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
5/31/98 2:08 AM	152	658	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
5/31/98 2:23 AM	224	65	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
5/31/98 4:00 AM	140	59	OTHER	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
5/31/98 8:53 AM	27	126	UNKNOWN	CROSS/ALLEY ARM	REPAIRED EQUIPMENT	FIELD INSPECTION	NO
6/1/98 5:56 AM	164	30	UNKNOWN	OTHER EQUIPMENT	TREE TRIMMED	FIELD INSPECTION	NO
6/1/98 12:35 PM	70	829	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
6/2/98 6:17 AM	141	2300	OTHER	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
6/2/98 6:32 AM	87	39	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
6/2/98 8:17 AM	93	10	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
6/2/98 8:59 AM	172	50	PUBLIC - FOREIGN OBJECT	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	NO ACTION NEEDED	NO
6/2/98 9:14 AM	241	17	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
6/2/98 9:39 AM	110	825	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
6/2/98 10:02 AM	159	2949	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
6/2/98 11:12 AM	34	824	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
6/2/98 2:49 PM	71	1710	OTHER	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
6/3/98 6:23 AM	102	63	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
6/3/98 7:30 AM	100	20	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
6/3/98 9:51 AM	146	30	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
6/3/98 12:23 PM	160	3171	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
6/3/98 1:20 PM	110	44	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
6/3/98 2:17 PM	153	25	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
6/3/98 5:57 PM	168	77	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
6/3/98 7:29 PM	79	1511	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
6/4/98 2:03 AM	97	6678	OTHER	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
6/4/98 8:36 AM	120	40	WILDLIFE	PHASE WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
6/4/98 9:05 AM	113	28	WILDLIFE	PHASE WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
6/4/98 3:32 PM	63	30	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
6/4/98 3:38 PM	136	41	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
6/5/98 7:52 AM	198	16	OTHER	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/5/98 8:22 AM	156	63	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPAIRED EQUIPMENT	TREE TRIMMING	NO
6/5/98 9:28 AM	102	2882	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
6/5/98 9:41 AM	139	12	WILDLIFE	PHASE WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
6/5/98 10:59 AM	86	37	PUBLIC - VANDALISM	PHASE WIRE	REPLACED FUSE OR CUTOUT	NO ACTION NEEDED	NO
6/5/98 1:04 PM	206	684	PUBLIC - ACCIDENT BY OTHERS	PHASE WIRE	TREE REMOVED	NO ACTION NEEDED	NO
6/5/98 1:56 PM	104	115	PUBLIC - ACCIDENT BY OTHERS	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
6/6/98 7:06 AM	135	18	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
6/6/98 9:05 AM	90	75	WILDLIFE	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
6/6/98 11:22 AM	286	35	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
6/6/98 5:04 PM	66	1884	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/6/98 9:39 PM	93	75	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/6/98 10:02 PM	83	140	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
6/7/98 7:33 AM	67	37	WILDLIFE	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
6/7/98 7:35 AM	75	12	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
6/7/98 7:38 AM	67	24	WILDLIFE	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
6/7/98 5:52 PM	90	16	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
6/7/98 7:17 PM	48	26	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/8/98 5:15 AM	75	80	UNKNOWN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
6/8/98 7:08 AM	117	67	WILDLIFE	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
6/8/98 7:50 AM	625	51	UNKNOWN	UNDERGROUND TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
6/8/98 7:51 AM	54	177	WILDLIFE	SWITCH/DISCONNECT/LTD	TEMPORARY SWITCHING	ANIMAL GUARD CHECK	NO
6/8/98 9:56 AM	131	20	WILDLIFE	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
6/8/98 12:23 PM	47	11403	OTHER	CABLE JOINT/SPLICE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
6/8/98 10:30 PM	425	431	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
6/9/98 8:32 AM	93	13	OTHER	PHASE WIRE	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/9/98 10:16 AM	51	116	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/9/98 3:39 PM	136	314	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
6/9/98 3:46 PM	203	218	WEATHER - LIGHTNING	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/9/98 3:47 PM	648	81	WEATHER - LIGHTNING	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
6/9/98 3:52 PM	188	823	WEATHER - LIGHTNING	OTHER TRANSFORMER	TEMPORARY SWITCHING	FIELD INSPECTION	NO
6/9/98 4:01 PM	68	774	TREE CONTACT - PRIMARY	PHASE WIRE	TREE TRIMMED	TREE TRIMMING	NO
6/9/98 4:07 PM	83	60	WEATHER - LIGHTNING	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/9/98 4:13 PM	97	782	WEATHER - LIGHTNING	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/9/98 4:27 PM	175	102	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/9/98 6:56 PM	176	11	WILDLIFE	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
6/9/98 7:54 PM	96	110	WEATHER - LIGHTNING	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/10/98 12:48 AM	72	46	INTENTIONAL - PROTECTION OF SYSTEM INTEGRITY	FUSE/CUTOUT	TREE REMOVED	NO ACTION NEEDED	NO
6/10/98 6:48 AM	172	69	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
6/10/98 7:08 AM	97	104	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
6/10/98 7:22 AM	83	24	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
6/10/98 8:32 AM	88	109	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
6/10/98 5:35 PM	65	31	WILDLIFE	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
6/10/98 5:36 PM	104	203	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
6/11/98 3:53 AM	127	20	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/11/98 6:03 AM	13	1777	WEATHER - FLOODING/RAIN	OTHER	CLOSED SUBSTATION BREAKER	FIELD INSPECTION	NO
6/11/98 7:07 AM	168	95	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
6/11/98 8:01 AM	144	20	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
6/11/98 8:45 AM	45	61	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
6/11/98 10:22 AM	125	150	PUBLIC - DIG-IN BY OTHERS	CABLE	TEMPORARY SWITCHING	NO ACTION NEEDED	NO
6/11/98 10:25 AM	85	26	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
6/11/98 1:01 PM	32	740	WILDLIFE	SWITCH/DISCONNECT/LTD	CLOSED SUBSTATION BREAKER	ANIMAL GUARD CHECK	NO
6/11/98 1:06 PM	32	116	UNKNOWN	OTHER EQUIPMENT	TEMPORARY SWITCHING	FIELD INSPECTION	NO
6/11/98 4:18 PM	177	590	TREE CONTACT - PRIMARY	PHASE WIRE	TREE TRIMMED	TREE TRIMMING	NO
6/11/98 5:04 PM	724	18	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	YES
6/11/98 5:49 PM	151	157	TREE CONTACT - PRIMARY	PHASE WIRE	TREE TRIMMED	TREE TRIMMING	NO
6/11/98 7:44 PM	321	187	OTHER	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
6/11/98 8:12 PM	97	46	OVERHEAD EQUIPMENT - MALFUNCTION	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/11/98 8:49 PM	96	343	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
6/11/98 9:57 PM	328	31	TREE CONTACT - PRIMARY	PHASE WIRE	TREE TRIMMED	TREE TRIMMING	NO
6/11/98 9:58 PM	332	14	TREE CONTACT - PRIMARY	OVERHEAD TRANSFORMER	TREE TRIMMED	TREE TRIMMING	NO
6/11/98 10:28 PM	59	447	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
6/11/98 10:32 PM	193	102	TREE CONTACT - PRIMARY	PHASE WIRE	TREE TRIMMED	TREE TRIMMING	NO
6/12/98 3:34 AM	56	2110	UNDERGROUND EQUIPMENT - UG FAILURE	PHASE WIRE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
6/12/98 6:03 AM	192	120	OTHER	OVERHEAD TRANSFORMER	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/12/98 3:16 PM	1	2560	TREE CONTACT - PRIMARY	PHASE WIRE	TREE TRIMMED	TREE TRIMMING	NO
6/12/98 3:35 PM	105	121	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
6/12/98 3:42 PM	93	987	TREE CONTACT - PRIMARY	PHASE WIRE	TREE TRIMMED	TREE TRIMMING	NO
6/12/98 5:03 PM	127	21	OVERHEAD EQUIPMENT - MALFUNCTION	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/12/98 6:01 PM	69	65	TREE CONTACT - PRIMARY	PHASE WIRE	TREE TRIMMED	TREE TRIMMING	NO
6/13/98 5:49 AM	1776	27	OVERHEAD EQUIPMENT - MALFUNCTION	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	YES
6/13/98 6:22 AM	161	126	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
6/13/98 7:15 AM	335	52	WILDLIFE	PHASE WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
6/13/98 7:29 AM	266	42	WILDLIFE	PHASE WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
6/13/98 3:54 PM	226	40	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/13/98 8:25 PM	125	13	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
6/14/98 7:10 AM	225	14	PUBLIC - FIRE	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	NO ACTION NEEDED	NO
6/14/98 8:01 AM	49	43	WILDLIFE	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
6/14/98 2:34 PM	196	29	WEATHER - FLOODING/RAIN	TAP WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
6/14/98 6:30 PM	165	23	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
6/15/98 6:32 AM	152	23	WILDLIFE	PHASE WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
6/15/98 2:03 PM	72	39	OVERHEAD EQUIPMENT - MALFUNCTION	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/16/98 6:53 PM	157	4870	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	SUBSTATION BREAKER	TEMPORARY SWITCHING	FIELD INSPECTION	NO
6/17/98 7:26 AM	144	12	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
6/17/98 10:08 AM	522	32	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/17/98 2:32 PM	23	105	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/17/98 3:16 PM	119	73	WILDLIFE	TAP WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
6/17/98 4:25 PM	600	103	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
6/17/98 7:30 PM	255	13	TREE CONTACT - PRIMARY	PHASE WIRE	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
6/17/98 8:18 PM	132	95	CUSTOMER - OVERLOAD	PHASE WIRE	REPLACED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
6/17/98 10:17 PM	883	102	UNDERGROUND EQUIPMENT - CONTAMINATION	UNDERGROUND TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	YES
6/18/98 3:21 AM	159	13	PUBLIC - VANDALISM	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
6/18/98 7:26 AM	122	89	WILDLIFE	PHASE WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
6/18/98 8:28 AM	47	17	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
6/18/98 2:55 PM	85	41	WILDLIFE	FUSE/CUTOUT	REPLACED OVERHEAD MATERIAL	ANIMAL GUARD CHECK	NO
6/18/98 3:22 PM	293	27	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
6/18/98 4:48 PM	112	72	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
6/18/98 5:18 PM	102	31	WEATHER - LIGHTNING	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/18/98 6:41 PM	839	103	WEATHER - LIGHTNING	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
6/18/98 7:23 PM	199	34	TREE CONTACT - PRIMARY	PHASE WIRE	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
6/18/98 7:24 PM	96	47	WEATHER - LIGHTNING	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/18/98 8:28 PM	128	1971	PUBLIC - FOREIGN OBJECT	SUBSTATION BREAKER	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
6/18/98 8:28 PM	232	2113	TREE CONTACT - PRIMARY	SUBSTATION BREAKER	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
6/18/98 8:33 PM	153	2841	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	SUBSTATION BREAKER	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
6/18/98 8:36 PM	424	21	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
6/18/98 8:37 PM	428	62	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
6/18/98 8:43 PM	559	683	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
6/18/98 8:47 PM	347	660	TREE CONTACT - PRIMARY	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	TREE TRIMMING	NO
6/18/98 8:48 PM	357	109	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
6/18/98 8:52 PM	271	47	TREE CONTACT - PRIMARY	PHASE WIRE	TREE TRIMMED	TREE TRIMMING	NO
6/18/98 8:54 PM	616	77	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
6/18/98 8:55 PM	95	31	OTHER	PHASE WIRE	TREE TRIMMED	FIELD INSPECTION	NO
6/18/98 8:55 PM	259	650	TREE CONTACT - PRIMARY	SUBSTATION BREAKER	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
6/18/98 8:59 PM	616	20	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/18/98 9:02 PM	258	1549	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
6/18/98 9:04 PM	200	177	TREE CONTACT - PRIMARY	PHASE WIRE	TREE TRIMMED	TREE TRIMMING	NO
6/18/98 9:07 PM	133	232	TREE CONTACT - PRIMARY	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	TREE TRIMMING	NO
6/18/98 9:12 PM	263	1367	TREE CONTACT - PRIMARY	SECTIONALIZER	CLOSED FUSE OR CUTOUT	TREE TRIMMING	NO
6/18/98 9:13 PM	489	90	WEATHER - LIGHTNING	TAP WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
6/18/98 9:14 PM	254	111	TREE CONTACT - PRIMARY	PHASE WIRE	TREE TRIMMED	TREE TRIMMING	NO
6/18/98 9:14 PM	386	249	UNKNOWN	OTHER EQUIPMENT	TREE TRIMMED	FIELD INSPECTION	NO
6/18/98 9:15 PM	235	239	TREE CONTACT - PRIMARY	PHASE WIRE	TREE TRIMMED	TREE TRIMMING	NO
6/18/98 9:16 PM	284	173	TREE CONTACT - PRIMARY	PHASE WIRE	TREE TRIMMED	TREE TRIMMING	NO
6/18/98 9:17 PM	573	71	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
6/18/98 9:25 PM	1175	50	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
6/18/98 9:28 PM	372	1704	TREE CONTACT - PRIMARY	SUBSTATION BREAKER	CLOSED SUBSTATION BREAKER	TREE TRIMMING	NO
6/18/98 9:32 PM	193	12	WEATHER - LIGHTNING	ARRESTER	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/18/98 9:38 PM	447	145	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
6/18/98 9:40 PM	470	150	TREE CONTACT - PRIMARY	PHASE WIRE	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
6/18/98 9:46 PM	511	179	WEATHER - LIGHTNING	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/18/98 10:12 PM	188	972	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
6/18/98 10:17 PM	163	75	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
6/18/98 10:29 PM	361	36	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
6/19/98 4:31 AM	59	60	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
6/19/98 5:45 AM	199	81	WEATHER - LIGHTNING	FUSE/CUTOUT	REPAIRED EQUIPMENT	FIELD INSPECTION	NO
6/19/98 8:46 AM	64	132	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
6/19/98 9:33 AM	425	19	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
6/19/98 12:19 PM	156	12	WILDLIFE	PHASE WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
6/19/98 3:20 PM	115	1178	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
6/19/98 3:34 PM	166	28	WEATHER - WIND	TAP WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
6/19/98 4:57 PM	119	1298	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
6/19/98 5:26 PM	24	1030	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
6/19/98 7:45 PM	60	859	PUBLIC - FOREIGN OBJECT	SUBSTATION BREAKER	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
6/19/98 7:58 PM	20	43	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
6/20/98 6:36 AM	67	74	WILDLIFE	PHASE WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
6/20/98 6:51 AM	184	26	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
6/20/98 6:53 AM	377	847	UNKNOWN	TERMINATION	TEMPORARY SWITCHING	FIELD INSPECTION	NO
6/20/98 8:45 AM	215	459	PUBLIC - FOREIGN OBJECT	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
6/20/98 9:23 AM	52	4173	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
6/20/98 1:19 PM	86	1457	UNKNOWN	OTHER EQUIPMENT	TREE TRIMMED	FIELD INSPECTION	NO
6/20/98 1:50 PM	500	51	INTENTIONAL - EMERGENCY REPAIRS	SECTIONALIZER	CLOSED SECTIONALIZER	FIELD INSPECTION	NO
6/20/98 2:00 PM	320	11	TREE CONTACT - PRIMARY	PHASE WIRE	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
6/20/98 2:34 PM	193	25	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
6/20/98 5:07 PM	248	59	OTHER	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
6/20/98 9:49 PM	491	21	OTHER	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
6/20/98 9:58 PM	257	46	WEATHER - FLOODING/RAIN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/21/98 12:07 AM	323	38	UNKNOWN	OTHER EQUIPMENT	REPLACED TRANSFORMER	FIELD INSPECTION	NO
6/21/98 6:06 AM	122	71	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
6/21/98 6:26 AM	114	37	WILDLIFE	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
6/21/98 8:29 AM	51	168	WILDLIFE	PHASE WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
6/21/98 11:51 AM	369	76	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/21/98 4:23 PM	222	211	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
6/21/98 6:28 PM	40	446	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
6/22/98 7:20 PM	257	861	OTHER	SUBSTATION BREAKER	TEMPORARY SWITCHING	FIELD INSPECTION	NO
6/23/98 5:27 AM	53	792	WILDLIFE	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
6/23/98 5:50 AM	105	475	UNKNOWN	SWITCH/DISCONNECT/LTD	TEMPORARY SWITCHING	FIELD INSPECTION	NO
6/23/98 9:00 AM	60	25	WILDLIFE	PHASE WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
6/23/98 12:17 PM	23	21	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/23/98 2:04 PM	156	47	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
6/23/98 5:43 PM	132	867	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/24/98 5:46 AM	69	345	UNKNOWN	TAP WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
6/24/98 8:06 AM	259	17	UNKNOWN	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/24/98 11:36 AM	484	84	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
6/24/98 12:22 PM	57	1645	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
6/24/98 1:17 PM	183	37	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/24/98 1:24 PM	186	24	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/24/98 2:04 PM	32	931	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
6/24/98 2:20 PM	85	16	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/24/98 2:22 PM	78	190	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
6/24/98 3:47 PM	108	326	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
6/24/98 4:59 PM	2356	1668	WEATHER - LIGHTNING	TAP WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
6/24/98 5:17 PM	78	717	UNKNOWN	OTHER EQUIPMENT	TEMPORARY SWITCHING	FIELD INSPECTION	NO
6/24/98 7:01 PM	629	22	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
6/24/98 7:04 PM	76	11	UNDERGROUND EQUIPMENT - UG FAILURE	CABLE JOINT/SPLICE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
6/24/98 7:13 PM	617	21	UNKNOWN	OTHER EQUIPMENT	REPLACED TRANSFORMER	FIELD INSPECTION	NO
6/24/98 7:29 PM	116	914	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
6/24/98 7:32 PM	88	20	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
6/24/98 7:32 PM	433	81	COMED/CONTRACTOR - UNCLASSIFIED ERROR	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TRAINING	NO
6/24/98 7:33 PM	447	175	WEATHER - WIND	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/24/98 7:37 PM	108	243	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
6/24/98 7:43 PM	782	51	WEATHER - EXTREME HEAT	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
6/24/98 7:58 PM	72	206	UNDERGROUND EQUIPMENT - MALFUNCTION	SUBSTATION BREAKER	CLOSED CIRCUIT SWITCHER	FIELD INSPECTION	NO
6/24/98 8:01 PM	54	870	UNDERGROUND EQUIPMENT - UG FAILURE	SUBSTATION BREAKER	OTHER	FIELD INSPECTION	NO
6/24/98 8:02 PM	103	1048	UNDERGROUND EQUIPMENT - UG FAILURE	CABLE JOINT/SPLICE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
6/24/98 8:03 PM	157	2456	OTHER	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
6/24/98 8:33 PM	572	47	WEATHER - EXTREME HEAT	OVERHEAD TRANSFORMER	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
6/24/98 8:55 PM	275	85	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/24/98 9:35 PM	790	13	UNKNOWN	TAP WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	YES
6/24/98 9:44 PM	661	124	OTHER	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
6/24/98 9:57 PM	708	45	WEATHER - EXTREME HEAT	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
6/24/98 10:00 PM	195	469	OTHER	TAP WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
6/24/98 10:10 PM	195	549	OTHER	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
6/24/98 11:10 PM	665	30	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
6/25/98 3:35 AM	45	75	COMED/CONTRACTOR - UNCLASSIFIED ERROR	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TRAINING	NO
6/25/98 6:37 AM	393	86	UNKNOWN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
6/25/98 10:52 AM	63	451	PUBLIC - FOREIGN OBJECT	FUSE/CUTOUT	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
6/25/98 12:24 PM	126	83	UNKNOWN	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/25/98 12:32 PM	278	25	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
6/25/98 3:16 PM	1784	56	TREE LIMB BROKEN - SECONDARY	CONNECTOR/SLEEVE	CHANGED SIZE	TREE TRIMMING	NO
6/25/98 5:23 PM	172	12	WEATHER - LIGHTNING	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
6/25/98 6:22 PM	88	48	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
6/25/98 7:14 PM	1115	85	WEATHER - LIGHTNING	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
6/25/98 7:23 PM	60	80	OTHER	ARRESTER	REPAIRED EQUIPMENT	FIELD INSPECTION	NO
6/25/98 7:54 PM	98	67	OTHER	UNDERGROUND TRANSFORMER	TEMPORARY JUMPER TO RESTORE	FIELD INSPECTION	NO
6/25/98 8:29 PM	841	70	WEATHER - LIGHTNING	OVERHEAD TRANSFORMER	CHANGED SIZE	FIELD INSPECTION	NO
6/25/98 9:25 PM	20	1066	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	SUBSTATION BUS	CLOSED SUBSTATION BREAKER	FIELD INSPECTION	NO
6/25/98 9:29 PM	81	788	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	SUBSTATION BUS	TEMPORARY SWITCHING	FIELD INSPECTION	NO
6/25/98 9:34 PM	121	1061	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	SUBSTATION BUS	TEMPORARY SWITCHING	FIELD INSPECTION	NO
6/25/98 9:40 PM	47	1023	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	SUBSTATION BUS	TEMPORARY SWITCHING	FIELD INSPECTION	NO
6/25/98 9:43 PM	44	204	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	SUBSTATION BUS	TEMPORARY SWITCHING	FIELD INSPECTION	NO
6/25/98 9:55 PM	675	145	WEATHER - LIGHTNING	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
6/25/98 10:09 PM	416	133	UNDERGROUND EQUIPMENT - UG FAILURE	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/25/98 10:23 PM	907	35	WEATHER - LIGHTNING	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/25/98 11:24 PM	636	145	WEATHER - LIGHTNING	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
6/25/98 11:55 PM	225	118	WEATHER - LIGHTNING	PHASE WIRE	REPLACED OTHER	FIELD INSPECTION	NO
6/26/98 12:13 AM	392	210	TREE CONTACT - PRIMARY	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	TREE TRIMMING	NO
6/26/98 12:14 AM	326	31	WEATHER - LIGHTNING	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
6/26/98 12:20 AM	475	17	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
6/26/98 12:26 AM	670	13	WEATHER - LIGHTNING	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
6/26/98 12:40 AM	657	193	WEATHER - LIGHTNING	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/26/98 3:11 AM	109	278	TREE LIMB BROKEN - PRIMARY	FUSE/CUTOUT	TEMPORARY SWITCHING	TREE TRIMMING	NO
6/26/98 3:20 AM	590	48	TREE CONTACT - PRIMARY	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	TREE TRIMMING	NO
6/26/98 3:31 AM	268	1753	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
6/26/98 3:32 AM	178	44	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/26/98 3:33 AM	546	165	WEATHER - LIGHTNING	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/26/98 3:37 AM	385	327	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
6/26/98 3:39 AM	410	109	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
6/26/98 3:42 AM	501	81	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
6/26/98 3:44 AM	212	1034	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
6/26/98 3:48 AM	732	89	WEATHER - WIND	FUSE/CUTOUT	REPAIRED EQUIPMENT	FIELD INSPECTION	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
6/26/98 3:49 AM	250	2225	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
6/26/98 3:50 AM	165	1456	TREE CONTACT - PRIMARY	SUBSTATION BREAKER	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
6/26/98 3:51 AM	413	46	WEATHER - LIGHTNING	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/26/98 3:51 AM	439	37	WEATHER - LIGHTNING	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/26/98 3:58 AM	132	67	TREE CONTACT - PRIMARY	PHASE WIRE	TREE TRIMMED	TREE TRIMMING	NO
6/26/98 4:04 AM	726	220	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	YES
6/26/98 4:10 AM	1070	37	WEATHER - EXTREME HEAT	OVERHEAD TRANSFORMER	REPAIRED TRANSFORMER	FIELD INSPECTION	NO
6/26/98 4:15 AM	345	60	WEATHER - LIGHTNING	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/26/98 4:19 AM	556	18	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
6/26/98 4:29 AM	391	181	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
6/26/98 5:00 AM	400	18	WEATHER - LIGHTNING	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/26/98 5:36 AM	289	359	WEATHER - LIGHTNING	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/26/98 5:53 AM	617	115	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
6/26/98 6:11 AM	429	55	WEATHER - LIGHTNING	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/26/98 6:33 AM	837	16	WEATHER - EXTREME HEAT	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
6/26/98 7:08 AM	467	27	TREE CONTACT - SECONDARY	PHASE WIRE	TREE TRIMMED	TREE TRIMMING	NO
6/26/98 9:16 AM	629	40	WEATHER - EXTREME HEAT	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
6/26/98 10:28 AM	332	138	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
6/26/98 11:37 AM	338	16	WEATHER - WIND	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
6/26/98 11:46 AM	254	39	WEATHER - LIGHTNING	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
6/26/98 12:35 PM	70	104	WEATHER - LIGHTNING	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
6/26/98 2:00 PM	210	48	WEATHER - WIND	FUSE/CUTOUT	REPAIRED EQUIPMENT	FIELD INSPECTION	NO
6/26/98 2:39 PM	291	39	WEATHER - EXTREME HEAT	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
6/26/98 3:18 PM	102	304	OTHER	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
6/26/98 3:22 PM	148	76	WEATHER - WIND	FUSE/CUTOUT	REPAIRED EQUIPMENT	FIELD INSPECTION	NO
6/26/98 3:41 PM	209	29	TREE CONTACT - SECONDARY	CONNECTOR/SLEEVE	TREE TRIMMED	TREE TRIMMING	NO
6/26/98 4:28 PM	167	115	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/26/98 4:31 PM	74	53	OTHER	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/26/98 4:52 PM	63	160	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
6/26/98 5:56 PM	519	27	WEATHER - EXTREME HEAT	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
6/26/98 6:18 PM	462	21	TREE LIMB BROKEN - SECONDARY	CONNECTOR/SLEEVE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
6/26/98 6:19 PM	126	30	CUSTOMER - OVERLOAD	CONNECTOR/SLEEVE	REPLACED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
6/26/98 8:22 PM	63	18	UNKNOWN	OTHER EQUIPMENT	TEMPORARY SWITCHING	FIELD INSPECTION	NO
6/26/98 9:17 PM	162	14	WEATHER - EXTREME HEAT	FUSE/CUTOUT	REPAIRED EQUIPMENT	FIELD INSPECTION	NO
6/26/98 9:23 PM	417	78	TREE LIMB BROKEN - SECONDARY	CONNECTOR/SLEEVE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
6/26/98 9:31 PM	359	256	WEATHER - EXTREME HEAT	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
6/27/98 1:03 AM	482	76	UNKNOWN	OVERHEAD TRANSFORMER	TEMPORARY SWITCHING	FIELD INSPECTION	NO
6/27/98 2:09 AM	296	49	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
6/27/98 6:11 AM	174	1480	WEATHER - WIND	PHASE WIRE	REPAIRED EQUIPMENT	FIELD INSPECTION	NO
6/27/98 6:29 AM	114	366	TREE CONTACT - PRIMARY	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	TREE TRIMMING	NO
6/27/98 6:47 AM	63	575	TREE CONTACT - PRIMARY	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	TREE TRIMMING	NO
6/27/98 6:48 AM	132	34	WILDLIFE	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
6/27/98 7:16 AM	204	109	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/27/98 11:22 AM	648	67	UNKNOWN	CROSS/ALLEY ARM	REPAIRED EQUIPMENT	FIELD INSPECTION	NO
6/27/98 1:34 PM	73	11	PUBLIC - FOREIGN OBJECT	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
6/27/98 6:07 PM	168	31	UNKNOWN	TAP WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
6/28/98 4:16 AM	301	89	WEATHER - LIGHTNING	OVERHEAD TRANSFORMER	TEMPORARY SWITCHING	FIELD INSPECTION	NO
6/28/98 4:26 AM	229	340	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
6/28/98 4:34 AM	121	15	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
6/28/98 4:51 AM	799	47	WEATHER - LIGHTNING	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/28/98 4:52 AM	78	11	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/28/98 5:21 AM	504	917	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
6/28/98 6:50 AM	360	92	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
6/28/98 6:56 AM	754	140	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	YES
6/28/98 7:08 AM	432	111	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
6/28/98 7:16 AM	244	192	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
6/28/98 7:31 AM	288	28	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/28/98 9:06 AM	214	264	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
6/28/98 1:04 PM	496	30	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
6/28/98 6:15 PM	285	36	TREE CONTACT - SECONDARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
6/28/98 6:48 PM	122	68	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
6/28/98 7:20 PM	450	17	TREE LIMB BROKEN - SECONDARY	CROSS/ALLEY ARM	REPLACED EQUIPMENT	TREE TRIMMING	NO
6/28/98 8:46 PM	1154	40	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	YES
6/28/98 9:30 PM	495	139	OTHER	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
6/29/98 7:27 AM	48	17	WILDLIFE	PHASE WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
6/29/98 9:21 AM	42	3470	OTHER	TERMINATION	CLOSED SUBSTATION BREAKER	FIELD INSPECTION	NO
6/29/98 10:16 AM	48	2134	WEATHER - LIGHTNING	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
6/29/98 10:32 AM	458	12	UNKNOWN	OTHER EQUIPMENT	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
6/29/98 2:01 PM	164	517	PUBLIC - DIG-IN BY OTHERS	CABLE	TEMPORARY SWITCHING	NO ACTION NEEDED	NO
6/29/98 4:51 PM	36	281	TREE LIMB BROKEN - PRIMARY	SWITCH/DISCONNECT/LTD	TEMPORARY SWITCHING	TREE TRIMMING	NO
6/29/98 5:56 PM	97	1278	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
6/29/98 6:42 PM	88	32	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
6/29/98 7:09 PM	821	42	OTHER	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
6/29/98 7:11 PM	379	184	TREE CONTACT - PRIMARY	PHASE WIRE	TREE REMOVED	TREE TRIMMING	NO
6/29/98 7:27 PM	33	1517	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
6/29/98 10:12 PM	818	42	OTHER	UNDERGROUND TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
6/30/98 5:44 AM	161	374	WILDLIFE	PHASE WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
6/30/98 7:35 AM	65	32	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
6/30/98 10:43 AM	54	220	TREE CONTACT - PRIMARY	PHASE WIRE	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
6/30/98 12:59 PM	359	29	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
6/30/98 7:26 PM	4683	1729	WEATHER - LIGHTNING	PHASE WIRE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
7/1/98 7:49 PM	326	181	OTHER	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
7/2/98 2:09 AM	231	79	OTHER	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
7/2/98 5:44 AM	48	105	WILDLIFE	PHASE WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
7/2/98 6:49 AM	155	15	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
7/2/98 7:21 AM	49	28	WILDLIFE	PHASE WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
7/2/98 4:21 PM	32	3070	OTHER	SUBSTATION BREAKER	TEMPORARY SWITCHING	FIELD INSPECTION	NO
7/2/98 7:55 PM	40	36	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/3/98 2:24 AM	41	79	INTENTIONAL - PROTECTION OF SYSTEM INTEGRITY	OVERHEAD TRANSFORMER	REPAIRED TRANSFORMER	NO ACTION NEEDED	NO
7/3/98 6:22 AM	80	87	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
7/3/98 7:44 PM	476	198	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
7/3/98 7:45 PM	580	79	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/3/98 7:50 PM	160	146	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
7/3/98 7:52 PM	963	28	WEATHER - LIGHTNING	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
7/3/98 7:54 PM	621	521	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/3/98 7:57 PM	1387	49	WEATHER - LIGHTNING	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
7/3/98 7:58 PM	972	26	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/3/98 7:58 PM	981	20	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
7/3/98 7:59 PM	586	47	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/3/98 8:00 PM	250	1161	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
7/3/98 8:01 PM	489	1777	UNDERGROUND EQUIPMENT - UG FAILURE	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
7/3/98 8:03 PM	497	126	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/3/98 8:04 PM	410	929	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
7/3/98 8:07 PM	468	178	TREE LIMB BROKEN - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
7/3/98 8:09 PM	761	26	WEATHER - LIGHTNING	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
7/3/98 8:15 PM	935	183	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	YES
7/3/98 8:19 PM	146	572	UNKNOWN	SUBSTATION TRANSFORMER	TEMPORARY JUMPER TO RESTORE	FIELD INSPECTION	NO
7/3/98 8:25 PM	832	58	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/3/98 8:29 PM	871	129	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/3/98 8:30 PM	600	66	WEATHER - LIGHTNING	FUSE/CUTOUT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
7/3/98 8:32 PM	93	2884	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
7/3/98 9:00 PM	1121	23	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
7/3/98 9:13 PM	1227	10	WEATHER - LIGHTNING	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
7/3/98 9:24 PM	736	23	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPAIRED EQUIPMENT	TREE TRIMMING	NO
7/3/98 9:36 PM	819	215	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	YES
7/3/98 9:46 PM	655	688	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
7/3/98 10:07 PM	263	644	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
7/3/98 10:22 PM	468	61	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
7/3/98 10:49 PM	161	84	UNKNOWN	CONNECTOR/SLEEVE	TEMPORARY JUMPER TO RESTORE	FIELD INSPECTION	NO
7/3/98 11:34 PM	656	204	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
7/4/98 1:00 AM	447	133	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
7/4/98 2:59 AM	281	412	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
7/4/98 5:32 AM	198	25	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/4/98 5:43 AM	268	30	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/4/98 6:09 AM	301	24	WEATHER - LIGHTNING	FUSE/CUTOUT	REPAIRED EQUIPMENT	FIELD INSPECTION	NO
7/4/98 6:42 AM	601	23	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/4/98 8:09 AM	814	104	UNKNOWN	CONNECTOR/SLEEVE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	YES
7/4/98 8:29 AM	421	148	WILDLIFE	CABLE	TEMPORARY SWITCHING	ANIMAL GUARD CHECK	NO
7/4/98 8:49 AM	245	49	WEATHER - LIGHTNING	TAP WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
7/4/98 11:34 AM	141	218	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
7/4/98 1:45 PM	147	166	TREE LIMB BROKEN - PRIMARY	NEUTRAL WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
7/4/98 4:20 PM	60	374	UNKNOWN	SUBSTATION BREAKER	CLOSED SUBSTATION BREAKER	FIELD INSPECTION	NO
7/4/98 9:05 PM	1110	10	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/5/98 5:42 AM	45	1673	OVERHEAD EQUIPMENT - MALFUNCTION	SUBSTATION TRANSFORMER	TEMPORARY SWITCHING	FIELD INSPECTION	NO
7/5/98 5:45 AM	42	374	OVERHEAD EQUIPMENT - MALFUNCTION	SUBSTATION TRANSFORMER	TEMPORARY SWITCHING	FIELD INSPECTION	NO
7/5/98 6:09 AM	18	304	OVERHEAD EQUIPMENT - MALFUNCTION	SUBSTATION TRANSFORMER	TEMPORARY SWITCHING	FIELD INSPECTION	NO
7/5/98 6:25 AM	2	1978	OVERHEAD EQUIPMENT - MALFUNCTION	SUBSTATION TRANSFORMER	TEMPORARY SWITCHING	FIELD INSPECTION	NO
7/5/98 9:12 AM	98	104	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
7/5/98 1:42 PM	128	30	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
7/5/98 4:00 PM	481	33	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
7/6/98 7:45 AM	310	46	INTENTIONAL - PROTECTION OF SYSTEM INTEGRITY	SWITCH/DISCONNECT/LTD	TREE REMOVED	NO ACTION NEEDED	NO
7/6/98 7:49 AM	136	44	OVERHEAD EQUIPMENT - MALFUNCTION	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
7/6/98 11:40 AM	190	12	OTHER	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/6/98 11:55 AM	137	461	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
7/6/98 3:04 PM	311	14	OTHER	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
7/6/98 8:22 PM	83	45	UNKNOWN	TAP WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
7/6/98 9:27 PM	190	86	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
7/6/98 10:33 PM	257	193	TREE CONTACT - PRIMARY	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	TREE TRIMMING	NO
7/6/98 11:19 PM	119	232	TREE CONTACT - PRIMARY	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	TREE TRIMMING	NO
7/6/98 11:23 PM	217	123	TREE CONTACT - PRIMARY	SECTIONALIZER	CLOSED SECTIONALIZER	TREE TRIMMING	NO
7/6/98 11:25 PM	125	220	TREE CONTACT - PRIMARY	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	TREE TRIMMING	NO
7/6/98 11:56 PM	339	389	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
7/7/98 12:06 AM	172	16	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/7/98 1:38 AM	72	158	WEATHER - FLOODING/RAIN	CROSS/ALLEY ARM	REPAIRED EQUIPMENT	FIELD INSPECTION	NO
7/7/98 7:55 AM	110	82	WEATHER - FLOODING/RAIN	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/7/98 8:02 AM	118	48	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
7/7/98 9:05 AM	85	348	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
7/7/98 9:19 AM	141	17	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
7/7/98 9:53 PM	27	61	INTENTIONAL - PROTECTION OF SYSTEM INTEGRITY	SWITCH/DISCONNECT/LTD	CLOSED SWITCH/DISCONNECT/LT	NO ACTION NEEDED	NO
7/8/98 1:31 AM	94	79	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
7/8/98 6:05 AM	53	10	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
7/8/98 7:03 AM	72	472	OTHER	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
7/8/98 7:10 AM	185	23	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/8/98 7:30 AM	130	11	WILDLIFE	FUSE/CUTOUT	REPLACED OVERHEAD MATERIAL	ANIMAL GUARD CHECK	NO
7/8/98 10:56 AM	259	23	OTHER	CONNECTOR/SLEEVE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
7/8/98 2:48 PM	27	44	UNKNOWN	OTHER EQUIPMENT	TEMPORARY SWITCHING	FIELD INSPECTION	NO
7/8/98 3:40 PM	118	140	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
7/9/98 2:21 AM	39	2090	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
7/9/98 6:52 AM	108	14	UNKNOWN	OTHER EQUIPMENT	TEMPORARY SWITCHING	FIELD INSPECTION	NO
7/9/98 7:36 AM	5	20	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
7/9/98 8:24 AM	126	251	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
7/9/98 8:32 AM	118	409	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
7/9/98 9:38 AM	557	27	PUBLIC - DIG-IN BY OTHERS	CABLE	REPAIRED UNDERGROUND MATERIAL	NO ACTION NEEDED	NO
7/9/98 10:21 AM	249	110	OTHER	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/9/98 4:50 PM	70	37	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/9/98 6:27 PM	83	178	UNKNOWN	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/10/98 12:42 AM	88	20	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/10/98 9:45 AM	21	1686	PUBLIC - FOREIGN OBJECT	OVERHEAD TRANSFORMER	REPAIRED TRANSFORMER	NO ACTION NEEDED	NO
7/10/98 9:46 AM	109	20	PUBLIC - FOREIGN OBJECT	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	NO ACTION NEEDED	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
7/10/98 1:51 PM	499	31	OTHER	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
7/10/98 1:59 PM	164	439	UNKNOWN	OTHER EQUIPMENT	TEMPORARY SWITCHING	FIELD INSPECTION	NO
7/10/98 6:11 PM	247	42	TREE CONTACT - SECONDARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
7/10/98 7:41 PM	4	177	UNKNOWN	OTHER EQUIPMENT	CLOSED SECTIONALIZER	FIELD INSPECTION	NO
7/11/98 8:13 AM	157	19	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
7/11/98 8:13 AM	242	23	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
7/11/98 9:00 AM	235	32	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
7/11/98 10:09 AM	239	1125	UNKNOWN	OTHER EQUIPMENT	TREE REMOVED	FIELD INSPECTION	NO
7/11/98 1:37 PM	366	26	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
7/11/98 1:43 PM	230	10	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
7/11/98 4:43 PM	93	135	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
7/11/98 7:28 PM	119	14	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
7/12/98 11:26 AM	69	230	TREE CONTACT - PRIMARY	PHASE WIRE	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
7/12/98 1:21 PM	119	59	OTHER	TAP WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
7/12/98 4:12 PM	94	23	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
7/12/98 7:42 PM	133	27	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
7/13/98 6:19 AM	136	37	WILDLIFE	TAP WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
7/13/98 8:42 AM	338	152	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
7/13/98 11:59 AM	111	14	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
7/13/98 12:54 PM	141	57	PUBLIC - ACCIDENT BY OTHERS	POLE	REPAIRED EQUIPMENT	NO ACTION NEEDED	NO
7/13/98 3:12 PM	106	37	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/14/98 7:27 AM	98	18	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
7/14/98 11:51 AM	268	14	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
7/14/98 2:32 PM	34	1528	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
7/14/98 2:34 PM	24	992	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	OTHER EQUIPMENT	CLOSED SUBSTATION BREAKER	FIELD INSPECTION	NO
7/14/98 2:36 PM	89	138	PUBLIC - FOREIGN OBJECT	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
7/14/98 3:57 PM	97	47	WEATHER - EXTREME HEAT	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/14/98 5:36 PM	133	8146	WEATHER - EXTREME HEAT	SUBSTATION BREAKER	TEMPORARY SWITCHING	FIELD INSPECTION	NO
7/14/98 5:37 PM	28	170	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
7/14/98 5:38 PM	44	878	INTENTIONAL - PROTECTION OF SYSTEM INTEGRITY	FUSE/CUTOUT	TEMPORARY SWITCHING	NO ACTION NEEDED	NO
7/14/98 6:04 PM	101	32	UNKNOWN	OTHER EQUIPMENT	OTHER	FIELD INSPECTION	NO
7/14/98 7:20 PM	109	25	OTHER	FUSE/CUTOUT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
7/14/98 8:05 PM	1090	76	PUBLIC - FOREIGN OBJECT	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	NO ACTION NEEDED	NO
7/14/98 8:44 PM	16	1079	INTENTIONAL - PROTECTION OF SYSTEM INTEGRITY	SWITCH/DISCONNECT/LTD	CLOSED FUSE OR CUTOUT	NO ACTION NEEDED	NO
7/14/98 9:59 PM	71	143	UNKNOWN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
7/14/98 11:57 PM	169	44	UNKNOWN	TAP WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
7/15/98 1:09 AM	131	91	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/15/98 2:07 AM	57	4066	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	SUBSTATION TRANSFORMER	TEMPORARY SWITCHING	FIELD INSPECTION	NO
7/15/98 6:34 AM	101	96	WILDLIFE	PHASE WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
7/15/98 6:49 AM	38	11	OTHER	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
7/15/98 8:06 AM	59	451	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	SUBSTATION BREAKER	TEMPORARY SWITCHING	FIELD INSPECTION	NO
7/15/98 10:51 AM	119	29	WILDLIFE	TAP WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
7/15/98 12:10 PM	140	29	WILDLIFE	PHASE WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
7/15/98 12:44 PM	81	44	OTHER	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/15/98 1:29 PM	89	19	PUBLIC - FIRE	PHASE WIRE	REPLACED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
7/15/98 6:39 PM	66	17	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
7/15/98 9:38 PM	141	47	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/16/98 4:40 AM	101	472	OTHER	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
7/16/98 7:01 AM	124	33	OTHER	FUSE/CUTOUT	CHANGED OTHER	FIELD INSPECTION	NO
7/16/98 8:00 AM	240	60	OTHER	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
7/16/98 8:36 AM	99	232	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
7/16/98 8:48 AM	102	196	WILDLIFE	TAP WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
7/16/98 8:52 AM	120	21	WILDLIFE	TAP WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
7/16/98 10:10 AM	2	4484	UNKNOWN	SUBSTATION BREAKER	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/16/98 11:17 AM	98	39	PUBLIC - VEHICLES	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
7/16/98 1:14 PM	19	221	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/16/98 2:00 PM	40	130	OTHER	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
7/16/98 9:04 PM	86	44	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
7/17/98 12:16 AM	149	34	WILDLIFE	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
7/17/98 3:15 AM	355	66	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
7/17/98 7:33 AM	135	39	WILDLIFE	PHASE WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
7/17/98 10:25 AM	222	16	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
7/18/98 5:34 AM	231	49	PUBLIC - FIRE	PHASE WIRE	REPLACED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
7/18/98 9:38 AM	147	18	OTHER	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/18/98 2:41 PM	529	160	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
7/18/98 4:30 PM	2099	50	WEATHER - LIGHTNING	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
7/18/98 4:58 PM	114	15	UNKNOWN	TAP WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
7/18/98 7:11 PM	294	43	UNKNOWN	OVERHEAD TRANSFORMER	TEMPORARY SWITCHING	FIELD INSPECTION	NO
7/18/98 10:10 PM	208	41	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
7/19/98 12:20 AM	134	30	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
7/19/98 12:51 AM	59	42	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/19/98 3:36 AM	74	43	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
7/19/98 5:34 AM	461	329	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
7/19/98 5:35 AM	393	115	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
7/19/98 5:36 AM	749	15	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/19/98 5:37 AM	423	78	WEATHER - LIGHTNING	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
7/19/98 5:39 AM	73	2439	WEATHER - LIGHTNING	PHASE WIRE	CLOSED SUBSTATION BREAKER	FIELD INSPECTION	NO
7/19/98 5:40 AM	630	58	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/19/98 5:42 AM	873	261	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
7/19/98 5:44 AM	233	589	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
7/19/98 5:44 AM	841	114	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
7/19/98 5:44 AM	934	215	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
7/19/98 5:44 AM	1256	103	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
7/19/98 5:45 AM	180	2884	WEATHER - LIGHTNING	PHASE WIRE	OTHER	FIELD INSPECTION	NO
7/19/98 5:45 AM	758	115	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
7/19/98 5:48 AM	1397	410	TREE CONTACT - PRIMARY	PHASE WIRE	REPLACED OVERHEAD MATERIAL	TREE TRIMMING	NO
7/19/98 5:51 AM	464	270	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
7/19/98 5:52 AM	1321	15	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/19/98 5:54 AM	886	364	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
7/19/98 5:55 AM	665	41	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/19/98 5:55 AM	915	234	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/19/98 5:56 AM	54	1613	WEATHER - LIGHTNING	PHASE WIRE	OTHER	FIELD INSPECTION	NO
7/19/98 5:57 AM	1528	44	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	YES
7/19/98 5:59 AM	486	38	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
7/19/98 6:00 AM	1184	1006	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
7/19/98 6:04 AM	681	139	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
7/19/98 6:05 AM	655	106	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/19/98 6:06 AM	1245	30	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
7/19/98 6:08 AM	1340	55	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/19/98 6:14 AM	856	46	WEATHER - LIGHTNING	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
7/19/98 6:16 AM	1213	52	TREE CONTACT - PRIMARY	PHASE WIRE	REPLACED OVERHEAD MATERIAL	TREE TRIMMING	NO
7/19/98 6:18 AM	732	560	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
7/19/98 6:18 AM	1467	21	TREE CONTACT - PRIMARY	PHASE WIRE	REPLACED OVERHEAD MATERIAL	TREE TRIMMING	NO
7/19/98 6:18 AM	1662	56	WEATHER - LIGHTNING	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
7/19/98 6:20 AM	275	395	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
7/19/98 6:42 AM	2154	21	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
7/19/98 6:53 AM	942	1434	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
7/19/98 7:00 AM	1660	27	TREE LIMB BROKEN - SECONDARY	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
7/19/98 7:02 AM	737	53	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	YES
7/19/98 7:25 AM	1640	41	WEATHER - LIGHTNING	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/19/98 7:31 AM	629	119	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/19/98 7:37 AM	1235	14	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/19/98 7:43 AM	1380	72	UNKNOWN	OTHER EQUIPMENT	CHANGED SIZE	FIELD INSPECTION	YES
7/19/98 7:48 AM	127	40	TREE CONTACT - SECONDARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
7/19/98 8:03 AM	1552	57	TREE LIMB BROKEN - SECONDARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
7/19/98 9:14 AM	121	28	WILDLIFE	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
7/19/98 9:15 AM	1245	23	TREE CONTACT - PRIMARY	PHASE WIRE	REPLACED OVERHEAD MATERIAL	TREE TRIMMING	NO
7/19/98 9:20 AM	1152	18	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
7/19/98 9:29 AM	1501	23	TREE CONTACT - SECONDARY	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
7/19/98 10:58 AM	1622	30	TREE LIMB BROKEN - SECONDARY	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
7/19/98 11:52 AM	1883	34	TREE CONTACT - SECONDARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
7/19/98 11:57 AM	1448	42	TREE LIMB BROKEN - SECONDARY	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
7/19/98 12:16 PM	105	506	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
7/19/98 1:06 PM	1449	108	TREE LIMB BROKEN - SECONDARY	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
7/19/98 1:53 PM	519	153	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/19/98 2:08 PM	917	19	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
7/19/98 3:24 PM	1131	117	WEATHER - LIGHTNING	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
7/19/98 6:35 PM	382	18	WEATHER - LIGHTNING	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
7/19/98 8:37 PM	183	2593	UNDERGROUND EQUIPMENT - UG FAILURE	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
7/19/98 9:29 PM	1096	67	TREE CONTACT - SECONDARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
7/19/98 9:53 PM	687	33	WEATHER - LIGHTNING	CONNECTOR/SLEEVE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
7/19/98 10:10 PM	770	16	TREE LIMB BROKEN - SECONDARY	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
7/19/98 10:12 PM	1308	148	OVERHEAD EQUIPMENT - MALFUNCTION	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	YES
7/19/98 10:34 PM	611	224	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
7/19/98 10:51 PM	208	123	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
7/19/98 11:17 PM	733	24	TREE LIMB BROKEN - SECONDARY	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
7/19/98 11:17 PM	1318	19	WEATHER - LIGHTNING	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
7/19/98 11:25 PM	640	44	TREE CONTACT - PRIMARY	PHASE WIRE	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
7/20/98 12:09 AM	726	32	WEATHER - LIGHTNING	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
7/20/98 2:26 AM	99	2501	UNDERGROUND EQUIPMENT - UG FAILURE	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
7/20/98 3:48 AM	32	1942	UNDERGROUND EQUIPMENT - UG FAILURE	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
7/20/98 6:07 AM	413	19	WEATHER - LIGHTNING	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
7/20/98 6:38 AM	277	41	TREE LIMB BROKEN - SECONDARY	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
7/20/98 7:17 AM	423	26	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/20/98 8:20 AM	539	41	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
7/20/98 8:22 AM	188	66	WILDLIFE	OVERHEAD TRANSFORMER	CLOSED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
7/20/98 9:23 AM	94	23	OTHER	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/20/98 9:28 AM	11	1672	PUBLIC - FOREIGN OBJECT	TAP WIRE	CLOSED SUBSTATION BREAKER	NO ACTION NEEDED	NO
7/20/98 11:13 AM	142	137	UNKNOWN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
7/20/98 11:27 AM	153	757	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/20/98 11:28 AM	262	74	TREE CONTACT - PRIMARY	TAP WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
7/20/98 11:33 AM	372	20	WEATHER - LIGHTNING	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
7/20/98 1:48 PM	207	179	PUBLIC - ACCIDENT BY OTHERS	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
7/20/98 3:10 PM	170	48	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
7/20/98 3:28 PM	112	325	TREE LIMB BROKEN - PRIMARY	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
7/20/98 5:07 PM	254	42	WEATHER - LIGHTNING	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/20/98 8:28 PM	216	82	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
7/20/98 9:20 PM	850	17	UNKNOWN	TAP WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	YES
7/21/98 7:06 AM	234	47	WEATHER - EXTREME HEAT	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
7/21/98 7:47 AM	1693	23	WEATHER - EXTREME HEAT	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
7/21/98 7:48 AM	47	2468	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
7/21/98 9:06 AM	129	2854	TREE CONTACT - PRIMARY	SUBSTATION BREAKER	TEMPORARY SWITCHING	TREE TRIMMING	NO
7/21/98 10:30 AM	140	1850	UNKNOWN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
7/21/98 10:31 AM	179	170	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
7/21/98 10:31 AM	469	24	PUBLIC - DIG-IN BY OTHERS	CABLE	REPAIRED UNDERGROUND MATERIAL	NO ACTION NEEDED	NO
7/21/98 12:30 PM	235	104	TREE CONTACT - PRIMARY	TAP WIRE	REPLACED OVERHEAD MATERIAL	TREE TRIMMING	NO
7/21/98 12:57 PM	258	101	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/21/98 1:41 PM	259	149	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
7/21/98 2:00 PM	155	41	UNKNOWN	OVERHEAD TRANSFORMER	REPAIRED TRANSFORMER	FIELD INSPECTION	NO
7/21/98 3:46 PM	97	681	UNKNOWN	TAP WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
7/21/98 3:49 PM	311	1042	UNKNOWN	PHASE WIRE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
7/21/98 4:02 PM	33	92	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
7/21/98 4:47 PM	93	2854	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
7/21/98 6:23 PM	10	953	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
7/21/98 6:32 PM	40	396	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
7/21/98 6:39 PM	296	53	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
7/21/98 6:42 PM	603	32	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
7/21/98 6:56 PM	154	120	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
7/21/98 7:38 PM	40	1248	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
7/21/98 8:49 PM	203	61	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
7/21/98 9:10 PM	468	89	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
7/21/98 9:18 PM	167	205	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
7/21/98 9:26 PM	155	156	UNKNOWN	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/21/98 9:39 PM	127	4923	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
7/21/98 10:48 PM	566	90	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
7/21/98 11:44 PM	172	110	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
7/22/98 5:15 AM	175	94	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
7/22/98 5:45 AM	375	216	UNKNOWN	CABLE	REPLACED UNDERGROUND MATERIAL	FIELD INSPECTION	NO
7/22/98 6:45 AM	115	33	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/22/98 7:13 AM	120	681	UNKNOWN	SWITCH/DISCONNECT/LTD	CLOSED SUBSTATION BREAKER	FIELD INSPECTION	NO
7/22/98 7:14 AM	131	1531	UNKNOWN	SWITCH/DISCONNECT/LTD	CLOSED SUBSTATION BREAKER	FIELD INSPECTION	NO
7/22/98 8:15 AM	100	38	WILDLIFE	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
7/22/98 11:00 AM	23	335	OTHER	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
7/22/98 11:26 AM	138	234	UNKNOWN	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/22/98 5:55 PM	490	42	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
7/22/98 10:31 PM	379	38	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
7/23/98 11:34 AM	56	63	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
7/24/98 12:14 PM	102	403	OTHER	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
7/24/98 12:15 PM	102	476	OTHER	SUBSTATION BREAKER	TEMPORARY SWITCHING	FIELD INSPECTION	NO
7/24/98 2:56 PM	147	776	TREE CONTACT - PRIMARY	PHASE WIRE	TEMPORARY SWITCHING	TREE TRIMMING	NO
7/24/98 3:08 PM	103	187	PUBLIC - FOREIGN OBJECT	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	NO ACTION NEEDED	NO
7/24/98 3:16 PM	484	129	TREE CONTACT - PRIMARY	PHASE WIRE	REPLACED OVERHEAD MATERIAL	TREE TRIMMING	NO
7/24/98 7:16 PM	144	44	WILDLIFE	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
7/25/98 5:55 AM	105	3478	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
7/25/98 10:35 AM	2	608	COMED/CONTRACTOR - SWITCHING ERROR	SWITCH/DISCONNECT/LTD	CLOSED SWITCH/DISCONNECT/LT	TRAINING	NO
7/25/98 12:50 PM	342	34	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
7/25/98 10:50 PM	46	135	UNKNOWN	OTHER EQUIPMENT	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
7/26/98 7:02 AM	118	143	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
7/26/98 7:57 AM	173	27	PUBLIC - FIRE	PHASE WIRE	REPLACED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
7/26/98 9:48 AM	147	55	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
7/26/98 3:27 PM	63	232	PUBLIC - FIRE	PHASE WIRE	TEMPORARY SWITCHING	NO ACTION NEEDED	NO
7/26/98 6:20 PM	140	135	WILDLIFE	PHASE WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
7/26/98 11:47 PM	86	37	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	SUBSTATION BREAKER	CLOSED SUBSTATION BREAKER	FIELD INSPECTION	NO
7/27/98 12:08 AM	65	36	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	SUBSTATION BREAKER	CLOSED SUBSTATION BREAKER	FIELD INSPECTION	NO
7/27/98 8:25 AM	195	259	UNKNOWN	OTHER EQUIPMENT	CONTRACTOR WARNED	FIELD INSPECTION	NO
7/27/98 1:51 PM	22	50	UNKNOWN	CABLE JOINT/SPLICE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
7/27/98 1:55 PM	115	10	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/27/98 2:45 PM	105	68	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/28/98 8:17 AM	73	18	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
7/28/98 9:40 AM	45	504	UNKNOWN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
7/28/98 12:29 PM	96	31	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
7/28/98 1:10 PM	63	612	UNKNOWN	OTHER EQUIPMENT	TEMPORARY SWITCHING	FIELD INSPECTION	NO
7/28/98 1:16 PM	109	30	UNKNOWN	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
7/28/98 2:35 PM	75	70	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
7/28/98 4:05 PM	145	10	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
7/29/98 1:59 AM	32	3940	OTHER	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
7/29/98 2:47 AM	163	599	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
7/29/98 6:56 AM	89	14	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
7/29/98 2:46 PM	94	51	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
7/29/98 7:23 PM	72	31	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
7/29/98 8:33 PM	92	233	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
7/29/98 10:44 PM	96	20	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
7/30/98 4:34 AM	126	32	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
7/30/98 6:53 AM	82	52	WILDLIFE	FUSE/CUTOUT	REPLACED OVERHEAD MATERIAL	ANIMAL GUARD CHECK	NO
7/30/98 8:56 AM	94	100	WILDLIFE	FUSE/CUTOUT	REPLACED OVERHEAD MATERIAL	ANIMAL GUARD CHECK	NO
7/30/98 8:59 AM	81	29	WILDLIFE	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
7/30/98 1:09 PM	201	13	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
7/30/98 5:06 PM	59	59	INTENTIONAL - PROTECTION OF SYSTEM	SWITCH/DISCONNECT/LTD	TREE TRIMMED	NO ACTION NEEDED	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
			INTEGRITY				
7/31/98 7:06 AM	154	43	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED OTHER	FIELD INSPECTION	NO
7/31/98 10:58 AM	109	769	TREE CONTACT - PRIMARY	PHASE WIRE	OTHER	TREE TRIMMING	NO
7/31/98 12:07 PM	6	38	PUBLIC - FOREIGN OBJECT	LLC	REPLACED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
7/31/98 1:42 PM	153	65	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
8/1/98 3:07 AM	278	145	UNKNOWN	OTHER EQUIPMENT	OTHER	FIELD INSPECTION	NO
8/1/98 7:58 PM	285	709	WILDLIFE	FUSE/CUTOUT	REPLACED OVERHEAD MATERIAL	ANIMAL GUARD CHECK	NO
8/2/98 6:59 PM	256	975	OTHER	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
8/3/98 6:06 AM	73	26	WILDLIFE	PHASE WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
8/3/98 10:43 AM	157	59	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
8/3/98 10:44 AM	59	215	OTHER	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
8/4/98 12:21 AM	84	213	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/4/98 12:23 AM	147	103	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
8/4/98 12:27 AM	183	22	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/4/98 1:06 AM	131	519	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/4/98 7:35 AM	175	54	WEATHER - LIGHTNING	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
8/4/98 7:58 AM	72	5745	WEATHER - LIGHTNING	PHASE WIRE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
8/4/98 8:25 AM	725	183	OTHER	OTHER EQUIPMENT	REPAIRED OTHER	FIELD INSPECTION	NO
8/4/98 9:06 AM	207	1139	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/4/98 9:33 AM	125	167	WEATHER - LIGHTNING	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
8/4/98 1:03 PM	147	128	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
8/4/98 1:06 PM	89	27	TREE CONTACT - SECONDARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/4/98 1:51 PM	105	17	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
8/4/98 2:09 PM	104	36	WEATHER - LIGHTNING	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
8/4/98 2:11 PM	139	54	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/4/98 2:44 PM	171	991	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
8/4/98 4:10 PM	610	11	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
8/4/98 4:38 PM	70	178	TREE CONTACT - PRIMARY	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	TREE TRIMMING	NO
8/4/98 6:21 PM	84	176	WILDLIFE	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
8/4/98 8:00 PM	510	19	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/4/98 8:34 PM	7	75	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/5/98 3:31 AM	89	4648	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
8/5/98 3:50 AM	100	458	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/5/98 3:51 AM	89	68	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
8/5/98 5:22 AM	278	47	OTHER	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
8/5/98 8:41 AM	99	73	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
8/5/98 8:45 AM	76	83	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
8/5/98 9:34 AM	106	465	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
8/5/98 1:38 PM	85	11	UNKNOWN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/5/98 4:28 PM	299	92	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
8/5/98 4:30 PM	170	857	WEATHER - LIGHTNING	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/5/98 4:44 PM	616	53	WEATHER - LIGHTNING	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/5/98 4:52 PM	240	18	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPAIRED EQUIPMENT	TREE TRIMMING	NO
8/5/98 5:02 PM	198	38	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/5/98 5:09 PM	364	281	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
8/5/98 5:55 PM	235	12	WEATHER - LIGHTNING	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
8/5/98 7:36 PM	184	44	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
8/5/98 7:45 PM	184	150	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
8/5/98 7:54 PM	167	600	WEATHER - LIGHTNING	NEUTRAL WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/6/98 2:08 AM	650	159	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/6/98 8:56 AM	335	667	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
8/6/98 9:05 AM	268	544	UNDERGROUND EQUIPMENT - UG FAILURE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
8/6/98 10:44 AM	237	58	TREE CONTACT - SECONDARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/6/98 11:34 PM	138	27	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
8/7/98 4:17 AM	1	22	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
8/7/98 7:08 AM	172	27	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
8/7/98 12:42 PM	158	100	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
8/7/98 1:58 PM	212	61	OTHER	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
8/7/98 8:29 PM	811	28	UNKNOWN	OTHER EQUIPMENT	TREE TRIMMED	FIELD INSPECTION	YES
8/7/98 9:32 PM	1366	27	UNKNOWN	CABLE	REPLACED UNDERGROUND MATERIAL	FIELD INSPECTION	YES
8/7/98 9:44 PM	226	12	OTHER	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
8/7/98 9:45 PM	465	68	UNKNOWN	POLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/7/98 11:14 PM	496	138	TREE CONTACT - PRIMARY	PHASE WIRE	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
8/8/98 1:32 AM	712	42	WEATHER - LIGHTNING	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
8/8/98 7:26 AM	744	60	WEATHER - LIGHTNING	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
8/8/98 9:17 AM	273	2893	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
8/8/98 12:35 PM	640	155	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
8/8/98 8:13 PM	315	36	WEATHER - FLOODING/RAIN	FUSE/CUTOUT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/8/98 10:07 PM	220	16	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
8/9/98 10:00 AM	330	59	OTHER	CONNECTOR/SLEEVE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/9/98 10:36 AM	161	4047	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
8/9/98 4:21 PM	14	92	UNKNOWN	TAP WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/9/98 6:32 PM	122	38	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
8/9/98 10:12 PM	198	140	OTHER	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/9/98 10:37 PM	18	26	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
8/10/98 3:14 AM	11	2004	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
8/10/98 10:48 AM	56	504	PUBLIC - FOREIGN OBJECT	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
8/10/98 12:31 PM	109	20	UNKNOWN	OTHER EQUIPMENT	TREE REMOVED	FIELD INSPECTION	NO
8/10/98 12:54 PM	86	349	PUBLIC - FOREIGN OBJECT	PHASE WIRE	REPLACED FUSE OR CUTOUT	NO ACTION NEEDED	NO
8/10/98 2:08 PM	62	16	OTHER	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
8/10/98 2:47 PM	168	113	OTHER	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/10/98 4:20 PM	228	59	WEATHER - LIGHTNING	CONNECTOR/SLEEVE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/10/98 4:43 PM	40	141	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
8/10/98 6:27 PM	72	29	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
8/10/98 9:49 PM	46	95	INTENTIONAL - PROTECTION OF SYSTEM INTEGRITY	SWITCH/DISCONNECT/LTD	CLOSED FUSE OR CUTOUT	NO ACTION NEEDED	NO
8/11/98 9:13 PM	123	15	WILDLIFE	PHASE WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
8/12/98 8:24 AM	81	306	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
8/12/98 2:44 PM	51	2807	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	SUBSTATION BREAKER	TEMPORARY SWITCHING	FIELD INSPECTION	NO
8/13/98 3:30 AM	110	23	UNKNOWN	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
8/13/98 6:59 AM	131	128	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
8/13/98 11:18 PM	482	104	TREE LIMB BROKEN - PRIMARY	SWITCH/DISCONNECT/LTD	REPLACED EQUIPMENT	TREE TRIMMING	NO
8/14/98 6:51 AM	129	49	TREE CONTACT - PRIMARY	SWITCH/DISCONNECT/LTD	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
8/14/98 6:57 AM	39	433	WILDLIFE	SWITCH/DISCONNECT/LTD	REPAIRED EQUIPMENT	ANIMAL GUARD CHECK	NO
8/14/98 7:22 AM	73	14	WILDLIFE	PHASE WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
8/14/98 10:22 AM	145	97	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
8/15/98 6:28 AM	122	287	WILDLIFE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	ANIMAL GUARD CHECK	NO
8/15/98 7:43 AM	362	34	PUBLIC - ACCIDENT BY OTHERS	SWITCH/DISCONNECT/LTD	TEMPORARY SWITCHING	NO ACTION NEEDED	NO
8/15/98 6:39 PM	66	242	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/15/98 6:58 PM	157	49	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
8/16/98 11:25 AM	125	530	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	SUBSTATION BREAKER	CLOSED SUBSTATION BREAKER	FIELD INSPECTION	NO
8/17/98 7:32 AM	134	22	WILDLIFE	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
8/17/98 8:23 AM	77	20	OTHER	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
8/17/98 8:44 AM	80	16	OVERHEAD EQUIPMENT - MALFUNCTION	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
8/17/98 1:16 PM	69	126	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/17/98 9:15 PM	155	88	UNKNOWN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/18/98 7:49 AM	41	27	OTHER	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
8/19/98 6:20 AM	120	115	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
8/19/98 6:46 AM	494	14	OTHER	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
8/19/98 9:09 AM	6	28	INTENTIONAL - SCHEDULED CONSTRUCTION, MAINTENANCE, OR REPAIR	OVERHEAD TRANSFORMER	CLOSED FUSE OR CUTOUT	NO ACTION NEEDED	NO
8/19/98 11:32 AM	69	31	OTHER	FUSE/CUTOUT	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/19/98 4:01 PM	59	639	PUBLIC - FOREIGN OBJECT	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	NO ACTION NEEDED	NO
8/20/98 12:06 AM	100	269	UNDERGROUND EQUIPMENT - UG FAILURE	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
8/20/98 12:43 AM	307	706	UNKNOWN	CABLE JOINT/SPLICE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
8/20/98 5:11 PM	114	66	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
8/20/98 6:23 PM	82	1229	UNDERGROUND EQUIPMENT - UG FAILURE	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
8/20/98 7:56 PM	144	85	UNKNOWN	CONNECTOR/SLEEVE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/20/98 9:41 PM	669	119	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
8/20/98 10:27 PM	28	386	INTENTIONAL - EMERGENCY REPAIRS	SWITCH/DISCONNECT/LTD	CLOSED SWITCH/DISCONNECT/LT	FIELD INSPECTION	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
8/21/98 7:26 AM	169	54	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
8/21/98 8:44 AM	65	140	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	OTHER EQUIPMENT	TEMPORARY SWITCHING	FIELD INSPECTION	NO
8/21/98 3:45 PM	100	1467	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
8/21/98 5:05 PM	95	141	PUBLIC - FOREIGN OBJECT	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
8/21/98 7:19 PM	81	294	WILDLIFE	PHASE WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
8/21/98 8:01 PM	43	2800	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
8/21/98 8:32 PM	93	88	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
8/21/98 8:55 PM	135	69	OTHER	CONNECTOR/SLEEVE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/22/98 7:40 AM	66	105	WILDLIFE	PHASE WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
8/22/98 12:28 PM	50	148	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
8/22/98 1:34 PM	71	96	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
8/22/98 1:38 PM	219	40	WEATHER - FLOODING/RAIN	OVERHEAD TRANSFORMER	REPAIRED TRANSFORMER	FIELD INSPECTION	NO
8/22/98 4:53 PM	356	67	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/22/98 5:07 PM	129	309	TREE CONTACT - PRIMARY	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	TREE TRIMMING	NO
8/22/98 5:09 PM	131	276	WEATHER - LIGHTNING	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
8/22/98 5:10 PM	246	489	WEATHER - LIGHTNING	SUBSTATION BREAKER	CLOSED SUBSTATION BREAKER	FIELD INSPECTION	NO
8/22/98 5:10 PM	395	81	WEATHER - LIGHTNING	SECTIONALIZER	CLOSED SECTIONALIZER	FIELD INSPECTION	NO
8/22/98 5:13 PM	257	77	TREE CONTACT - PRIMARY	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	TREE TRIMMING	NO
8/22/98 5:15 PM	199	304	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/22/98 5:23 PM	777	85	WEATHER - LIGHTNING	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
8/22/98 5:25 PM	116	112	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/22/98 5:25 PM	240	2998	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
8/22/98 5:40 PM	395	189	WEATHER - LIGHTNING	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
8/22/98 5:45 PM	152	798	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
8/22/98 5:51 PM	144	269	WEATHER - FLOODING/RAIN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/22/98 7:01 PM	114	79	TREE CONTACT - PRIMARY	OVERHEAD TRANSFORMER	REPAIRED TRANSFORMER	TREE TRIMMING	NO
8/22/98 9:45 PM	240	38	WEATHER - LIGHTNING	OVERHEAD TRANSFORMER	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/22/98 10:43 PM	172	63	TREE CONTACT - PRIMARY	SECTIONALIZER	CLOSED SECTIONALIZER	TREE TRIMMING	NO
8/23/98 6:18 AM	177	565	WEATHER - LIGHTNING	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
8/23/98 6:23 AM	117	16	WILDLIFE	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
8/23/98 10:02 AM	260	26	WILDLIFE	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
8/23/98 10:14 AM	31	2584	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/23/98 11:15 AM	379	121	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
8/23/98 4:41 PM	274	116	UNKNOWN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/24/98 2:01 AM	84	113	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
8/24/98 2:05 AM	175	38	COMED/CONTRACTOR - UNCLASSIFIED ERROR	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TRAINING	NO
8/24/98 10:49 AM	816	1050	UNKNOWN	TAP WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	YES
8/24/98 12:00 PM	670	22	WEATHER - WIND	OTHER EQUIPMENT	REPAIRED OTHER	FIELD INSPECTION	NO
8/24/98 1:43 PM	1802	192	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/24/98 1:55 PM	620	1439	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/24/98 1:57 PM	748	178	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/24/98 1:58 PM	325	398	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/24/98 1:58 PM	392	44	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/24/98 1:59 PM	316	743	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/24/98 1:59 PM	511	1351	WEATHER - LIGHTNING	PHASE WIRE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
8/24/98 1:59 PM	726	928	UNDERGROUND EQUIPMENT - UG FAILURE	PHASE WIRE	TEMPORARY SWITCHING	FIELD INSPECTION	YES
8/24/98 2:00 PM	180	516	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/24/98 2:01 PM	1611	118	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/24/98 2:02 PM	358	14	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/24/98 2:03 PM	842	961	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	SUBSTATION TRANSFORMER	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/24/98 2:03 PM	2412	1210	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/24/98 2:04 PM	241	81	WEATHER - FLOODING/RAIN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/24/98 2:04 PM	1256	895	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/24/98 2:04 PM	1436	26	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/24/98 2:05 PM	740	1250	WEATHER - LIGHTNING	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
8/24/98 2:06 PM	145	129	WEATHER - LIGHTNING	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
8/24/98 2:06 PM	384	897	WEATHER - LIGHTNING	PHASE WIRE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
8/24/98 2:06 PM	579	1457	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
8/24/98 2:07 PM	113	37	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/24/98 2:07 PM	342	1146	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/24/98 2:07 PM	2876	186	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/24/98 2:07 PM	3063	4883	TREE LIMB BROKEN - PRIMARY	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	TREE TRIMMING	NO
8/24/98 2:08 PM	102	860	WEATHER - LIGHTNING	PHASE WIRE	CLOSED SUBSTATION BREAKER	FIELD INSPECTION	NO
8/24/98 2:08 PM	461	316	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/24/98 2:09 PM	366	20	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OTHER	FIELD INSPECTION	NO
8/24/98 2:09 PM	411	1294	WEATHER - LIGHTNING	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
8/24/98 2:09 PM	1936	453	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/24/98 2:09 PM	2601	216	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/24/98 2:10 PM	560	44	TREE LIMB BROKEN - PRIMARY	FUSE/CUTOUT	REPLACED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/24/98 2:10 PM	680	125	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
8/24/98 2:10 PM	2440	87	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/24/98 2:11 PM	269	268	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
8/24/98 2:11 PM	1719	84	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/24/98 2:12 PM	238	24	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/24/98 2:12 PM	370	157	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
8/24/98 2:12 PM	618	229	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/24/98 2:12 PM	795	403	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/24/98 2:12 PM	1323	56	WEATHER - FLOODING/RAIN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
8/24/98 2:13 PM	425	1309	WEATHER - WIND	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/24/98 2:14 PM	421	418	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/24/98 2:14 PM	1886	284	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/24/98 2:15 PM	345	167	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/24/98 2:16 PM	96	867	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
8/24/98 2:16 PM	434	1663	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/24/98 2:16 PM	2069	709	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/24/98 2:17 PM	658	1046	WEATHER - WIND	POLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
8/24/98 2:18 PM	460	531	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/24/98 2:18 PM	2187	26	TREE LIMB BROKEN - PRIMARY	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	TREE TRIMMING	NO
8/24/98 2:18 PM	2303	195	TREE CONTACT - PRIMARY	SWITCH/DISCONNECT/LTD	CLOSED SWITCH/DISCONNECT/LT	TREE TRIMMING	NO
8/24/98 2:20 PM	390	120	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
8/24/98 2:20 PM	545	379	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/24/98 2:20 PM	1720	41	WEATHER - FLOODING/RAIN	GROUND WIRE	OTHER	FIELD INSPECTION	NO
8/24/98 2:21 PM	739	409	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/24/98 2:24 PM	1871	518	TREE CONTACT - PRIMARY	SECTIONALIZER	CLOSED SECTIONALIZER	TREE TRIMMING	NO
8/24/98 2:26 PM	454	30	UNKNOWN	OTHER EQUIPMENT	REPLACED TRANSFORMER	FIELD INSPECTION	NO
8/24/98 2:26 PM	2209	348	TREE CONTACT - PRIMARY	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	TREE TRIMMING	NO
8/24/98 2:27 PM	933	1693	TREE LIMB BROKEN - PRIMARY	POLE	TEMPORARY JUMPER TO RESTORE	TREE TRIMMING	NO
8/24/98 2:28 PM	827	283	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/24/98 2:28 PM	1622	39	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	YES
8/24/98 2:28 PM	1966	283	TREE CONTACT - PRIMARY	SWITCH/DISCONNECT/LTD	CLOSED SWITCH/DISCONNECT/LT	TREE TRIMMING	NO
8/24/98 2:31 PM	1519	55	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/24/98 2:33 PM	267	49	TREE LIMB BROKEN - SECONDARY	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/24/98 2:33 PM	447	602	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
8/24/98 2:34 PM	3066	1678	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/24/98 2:36 PM	1023	209	UNKNOWN	NEUTRAL WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	YES
8/24/98 2:39 PM	1821	1892	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/24/98 2:40 PM	379	447	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	SUBSTATION BREAKER	CLOSED SUBSTATION BREAKER	FIELD INSPECTION	NO
8/24/98 2:41 PM	1444	23	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/24/98 2:45 PM	369	572	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	SUBSTATION BREAKER	CLOSED SUBSTATION BREAKER	FIELD INSPECTION	NO
8/24/98 2:47 PM	145	2412	WEATHER - LIGHTNING	CONNECTOR/SLEEVE	REPLACED EQUIPMENT	FIELD INSPECTION	NO
8/24/98 2:47 PM	303	2608	WEATHER - LIGHTNING	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/24/98 2:47 PM	373	10	TREE CONTACT - PRIMARY	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	TREE TRIMMING	NO
8/24/98 2:49 PM	2786	161	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/24/98 2:50 PM	410	341	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
8/24/98 2:50 PM	520	1440	WEATHER - LIGHTNING	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/24/98 2:50 PM	868	786	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/24/98 2:50 PM	1360	140	UNKNOWN	AERIAL CABLE	REPLACED OTHER	FIELD INSPECTION	YES

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
8/24/98 2:52 PM	2605	33	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/24/98 2:53 PM	2442	13	TREE LIMB BROKEN - SECONDARY	PHASE WIRE	REPLACED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/24/98 2:54 PM	1531	155	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/24/98 2:55 PM	613	344	WEATHER - LIGHTNING	SUBSTATION BUS	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/24/98 2:58 PM	257	96	WEATHER - LIGHTNING	SWITCH/DISCONNECT/LTD	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/24/98 2:58 PM	297	2139	WEATHER - LIGHTNING	PHASE WIRE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
8/24/98 2:58 PM	892	861	UNKNOWN	CONNECTOR/SLEEVE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	YES
8/24/98 2:59 PM	2081	51	OTHER	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	YES
8/24/98 3:02 PM	425	136	UNKNOWN	SWITCH/DISCONNECT/LTD	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/24/98 3:05 PM	1815	410	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/24/98 3:08 PM	817	339	OTHER	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/24/98 3:09 PM	1024	734	WEATHER - WIND	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/24/98 3:11 PM	2731	83	TREE CONTACT - PRIMARY	PHASE WIRE	TREE TRIMMED	TREE TRIMMING	NO
8/24/98 3:17 PM	148	1002	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/24/98 3:23 PM	321	1852	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/24/98 3:26 PM	26	134	WEATHER - LIGHTNING	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
8/24/98 3:31 PM	188	111	TREE CONTACT - PRIMARY	PHASE WIRE	TREE TRIMMED	TREE TRIMMING	NO
8/24/98 3:34 PM	1101	107	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/24/98 3:34 PM	1646	618	WEATHER - LIGHTNING	FUSE/CUTOUT	REPAIRED EQUIPMENT	FIELD INSPECTION	NO
8/24/98 3:35 PM	400	29	WEATHER - WIND	PHASE WIRE	TREE REMOVED	FIELD INSPECTION	NO
8/24/98 3:37 PM	1331	763	WEATHER - WIND	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/24/98 3:46 PM	1774	80	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/24/98 3:47 PM	328	1694	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
8/24/98 3:51 PM	1314	265	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/24/98 3:54 PM	274	254	WEATHER - LIGHTNING	SUBSTATION TRANSFORMER	CLOSED SUBSTATION BREAKER	FIELD INSPECTION	NO
8/24/98 3:54 PM	1626	41	WEATHER - FLOODING/RAIN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/24/98 3:57 PM	1433	909	WEATHER - FLOODING/RAIN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/24/98 4:36 PM	346	76	WEATHER - LIGHTNING	SUBSTATION BREAKER	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/24/98 4:53 PM	1857	161	TREE CONTACT - PRIMARY	SECTIONALIZER	CLOSED SECTIONALIZER	TREE TRIMMING	NO
8/24/98 5:09 PM	88	112	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/24/98 5:42 PM	213	74	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/24/98 5:46 PM	2674	273	WEATHER - WIND	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/24/98 6:24 PM	156	1169	WEATHER - LIGHTNING	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
8/24/98 7:09 PM	86	152	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/24/98 7:26 PM	261	26	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/24/98 8:34 PM	131	201	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
8/24/98 8:45 PM	1035	18	WEATHER - WIND	NEUTRAL WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/24/98 8:54 PM	25	705	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	SUBSTATION BREAKER	CLOSED SUBSTATION BREAKER	FIELD INSPECTION	NO
8/24/98 10:35 PM	865	30	WEATHER - WIND	PHASE WIRE	TREE REMOVED	FIELD INSPECTION	NO
8/24/98 11:22 PM	1553	38	TREE CONTACT - PRIMARY	SECTIONALIZER	CLOSED SECTIONALIZER	TREE TRIMMING	NO
8/25/98 12:51 AM	138	101	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/25/98 1:04 AM	102	12	PUBLIC - FOREIGN OBJECT	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	NO ACTION NEEDED	NO
8/25/98 1:32 AM	637	274	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/25/98 1:58 AM	387	303	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/25/98 2:10 AM	275	184	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
8/25/98 2:23 AM	397	144	UNKNOWN	OTHER EQUIPMENT	REPLACED CIRCUIT SWITCHER	FIELD INSPECTION	NO
8/25/98 2:32 AM	193	19	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/25/98 3:33 AM	117	56	WEATHER - LIGHTNING	FUSE/CUTOUT	TEMPORARY JUMPER TO RESTORE	FIELD INSPECTION	NO
8/25/98 4:43 AM	2041	224	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/25/98 4:44 AM	1016	323	TREE CONTACT - PRIMARY	SECTIONALIZER	CLOSED SECTIONALIZER	TREE TRIMMING	NO
8/25/98 4:51 AM	801	28	WEATHER - FLOODING/RAIN	FUSE/CUTOUT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/25/98 5:03 AM	612	756	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/25/98 5:23 AM	868	29	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/25/98 5:38 AM	252	11	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
8/25/98 7:02 AM	48	2728	TREE CONTACT - PRIMARY	SUBSTATION BREAKER	CLOSED SUBSTATION BREAKER	TREE TRIMMING	NO
8/25/98 7:21 AM	144	91	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
8/25/98 7:28 AM	1112	785	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/25/98 8:04 AM	1076	50	TREE CONTACT - PRIMARY	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	TREE TRIMMING	NO
8/25/98 8:29 AM	1306	41	TREE LIMB BROKEN - SECONDARY	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/25/98 8:33 AM	877	192	TREE CONTACT - PRIMARY	SECTIONALIZER	CLOSED SECTIONALIZER	TREE TRIMMING	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
8/25/98 9:11 AM	477	118	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/25/98 9:34 AM	136	11	PUBLIC - FOREIGN OBJECT	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	NO ACTION NEEDED	NO
8/25/98 9:35 AM	1763	47	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/25/98 9:36 AM	984	47	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/25/98 9:41 AM	2076	608	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/25/98 10:11 AM	529	50	WEATHER - FLOODING/RAIN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/25/98 10:13 AM	227	44	TREE CONTACT - SECONDARY	PHASE WIRE	REPLACED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/25/98 11:00 AM	480	34	WEATHER - FLOODING/RAIN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/25/98 11:20 AM	254	43	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/25/98 11:35 AM	205	41	WEATHER - FLOODING/RAIN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/25/98 11:36 AM	216	23	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
8/25/98 11:38 AM	77	145	UNKNOWN	FUSE/CUTOUT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
8/25/98 11:47 AM	1033	155	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/25/98 12:06 PM	1984	31	WEATHER - LIGHTNING	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/25/98 12:12 PM	118	52	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
8/25/98 12:16 PM	993	419	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPLACED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/25/98 1:02 PM	358	29	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/25/98 1:37 PM	308	136	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/25/98 1:38 PM	91	1087	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	SUBSTATION BREAKER	CLOSED SUBSTATION BREAKER	FIELD INSPECTION	NO
8/25/98 1:38 PM	1522	540	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/25/98 1:42 PM	158	540	UNKNOWN	SWITCH/DISCONNECT/LTD	TEMPORARY SWITCHING	FIELD INSPECTION	NO
8/25/98 2:26 PM	589	143	TREE CONTACT - PRIMARY	SECTIONALIZER	CLOSED SECTIONALIZER	TREE TRIMMING	NO
8/25/98 3:16 PM	1634	17	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/25/98 3:49 PM	371	158	TREE CONTACT - PRIMARY	SECTIONALIZER	CLOSED SECTIONALIZER	TREE TRIMMING	NO
8/25/98 4:39 PM	759	532	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/25/98 5:56 PM	424	161	TREE LIMB BROKEN - PRIMARY	SECTIONALIZER	CLOSED SECTIONALIZER	TREE TRIMMING	NO
8/25/98 7:01 PM	539	32	WEATHER - LIGHTNING	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
8/25/98 7:37 PM	298	146	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
8/25/98 7:48 PM	976	377	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/25/98 10:51 PM	154	26	TREE CONTACT - PRIMARY	SECTIONALIZER	CLOSED SECTIONALIZER	TREE TRIMMING	NO
8/26/98 12:54 AM	81	178	TREE CONTACT - PRIMARY	SWITCH/DISCONNECT/LTD	CLOSED SWITCH/DISCONNECT/LT	TREE TRIMMING	NO
8/26/98 2:17 AM	73	381	INTENTIONAL - EMERGENCY REPAIRS	SWITCH/DISCONNECT/LTD	CLOSED SWITCH/DISCONNECT/LT	FIELD INSPECTION	NO
8/26/98 4:10 AM	490	93	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/26/98 4:28 AM	710	36	WEATHER - LIGHTNING	TAP WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/26/98 5:52 AM	398	44	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/26/98 6:19 AM	24	125	WILDLIFE	SWITCH/DISCONNECT/LTD	CLOSED SUBSTATION BREAKER	ANIMAL GUARD CHECK	NO
8/26/98 6:30 AM	735	148	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/26/98 7:17 AM	360	39	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/26/98 7:30 AM	820	92	WEATHER - WIND	POLE	TEMPORARY JUMPER TO RESTORE	FIELD INSPECTION	NO
8/26/98 8:24 AM	396	48	CUSTOMER - OVERLOAD	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	NO ACTION NEEDED	NO
8/26/98 9:10 AM	215	33	UNKNOWN	FUSE/CUTOUT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
8/26/98 10:30 AM	405	19	TREE CONTACT - PRIMARY	NEUTRAL WIRE	REPLACED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/26/98 11:23 AM	77	67	UNKNOWN	FUSE/CUTOUT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
8/26/98 12:00 PM	559	21	TREE LIMB BROKEN - SECONDARY	PHASE WIRE	REPLACED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/26/98 12:17 PM	731	31	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/26/98 12:48 PM	447	23	UNKNOWN	OTHER EQUIPMENT	REPLACED CIRCUIT SWITCHER	FIELD INSPECTION	NO
8/26/98 1:39 PM	6	190	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/26/98 1:41 PM	299	43	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
8/26/98 3:53 PM	247	42	OTHER	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
8/26/98 4:12 PM	213	15	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
8/26/98 5:10 PM	80	283	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/26/98 7:03 PM	157	34	TREE CONTACT - SECONDARY	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/26/98 8:58 PM	147	79	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
8/26/98 9:33 PM	392	59	TREE LIMB BROKEN - SECONDARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
8/27/98 1:01 PM	304	21	WEATHER - WIND	CROSS/ALLEY ARM	REPLACED EQUIPMENT	FIELD INSPECTION	NO
8/27/98 4:23 PM	487	22	WEATHER - WIND	CROSS/ALLEY ARM	REPLACED EQUIPMENT	FIELD INSPECTION	NO
8/27/98 9:34 PM	31	85	UNKNOWN	OTHER EQUIPMENT	REPLACED CIRCUIT SWITCHER	FIELD INSPECTION	NO
8/28/98 5:29 AM	207	96	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
8/28/98 5:43 AM	62	27	UNKNOWN	OTHER EQUIPMENT	TEMPORARY SWITCHING	FIELD INSPECTION	NO
8/28/98 6:51 AM	79	123	TREE CONTACT - PRIMARY	PHASE WIRE	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
8/28/98 1:58 PM	557	37	UNKNOWN	OTHER EQUIPMENT	REPLACED TRANSFORMER	FIELD INSPECTION	NO
8/28/98 3:59 PM	251	148	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/28/98 4:25 PM	733	95	OTHER	CROSS/ALLEY ARM	REPAIRED EQUIPMENT	FIELD INSPECTION	NO
8/29/98 6:40 AM	212	73	UNKNOWN	FUSE/CUTOUT	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/29/98 11:36 AM	90	1235	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
8/29/98 12:13 PM	102	1217	PUBLIC - FOREIGN OBJECT	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
8/29/98 1:29 PM	661	16	OVERHEAD EQUIPMENT - MALFUNCTION	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
8/29/98 2:49 PM	91	67	WILDLIFE	PHASE WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
8/29/98 3:49 PM	78	3191	UNKNOWN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/30/98 12:09 AM	56	84	UNKNOWN	FUSE/CUTOUT	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/30/98 6:50 AM	90	112	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
8/30/98 3:21 PM	197	2159	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
8/30/98 6:50 PM	80	24	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
8/31/98 6:13 AM	132	37	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
8/31/98 9:39 AM	33	30	OTHER	PHASE WIRE	TREE REMOVED	FIELD INSPECTION	NO
8/31/98 12:07 PM	92	904	INTENTIONAL - EMERGENCY REPAIRS	SWITCH/DISCONNECT/LTD	CLOSED SWITCH/DISCONNECT/LT	FIELD INSPECTION	NO
8/31/98 1:27 PM	773	285	OTHER	CABLE	REPAIRED UNDERGROUND MATERIAL	FIELD INSPECTION	NO
8/31/98 5:10 PM	230	1838	OTHER	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
8/31/98 6:04 PM	246	70	WILDLIFE	PHASE WIRE	REPLACED OTHER	ANIMAL GUARD CHECK	NO
9/1/98 5:20 AM	130	3524	OTHER	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
9/1/98 6:10 AM	170	295	OTHER	PHASE WIRE	REPAIRED OTHER	FIELD INSPECTION	NO
9/1/98 8:35 AM	120	28	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
9/1/98 10:08 AM	82	349	UNKNOWN	TAP WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
9/1/98 9:02 PM	13	85	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
9/1/98 11:05 PM	110	3524	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
9/2/98 4:48 AM	48	779	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
9/2/98 5:32 AM	388	77	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
9/2/98 7:55 AM	1848	15	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	YES
9/2/98 9:34 AM	51	1951	PUBLIC - DIG-IN BY OTHERS	CABLE	TEMPORARY SWITCHING	NO ACTION NEEDED	NO
9/2/98 2:42 PM	98	2700	OTHER	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
9/2/98 4:43 PM	342	122	WILDLIFE	PHASE WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
9/2/98 6:14 PM	55	1462	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
9/2/98 10:15 PM	60	69	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
9/3/98 12:19 AM	106	16	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
9/3/98 10:30 AM	50	61	WILDLIFE	3:1 TRANSFORMER	CHANGED OTHER	ANIMAL GUARD CHECK	NO
9/3/98 2:20 PM	20	24	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
9/3/98 3:11 PM	29	384	TREE CONTACT - PRIMARY	PHASE WIRE	TREE TRIMMED	TREE TRIMMING	NO
9/3/98 7:43 PM	69	1890	UNDERGROUND EQUIPMENT - UG FAILURE	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
9/3/98 11:00 PM	45	77	PUBLIC - FIRE	SWITCH/DISCONNECT/LTD	CLOSED SWITCH/DISCONNECT/LT	NO ACTION NEEDED	NO
9/4/98 11:46 AM	64	26	UNKNOWN	CROSS/ALLEY ARM	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
9/4/98 12:23 PM	32	1544	UNKNOWN	OTHER EQUIPMENT	TEMPORARY SWITCHING	FIELD INSPECTION	NO
9/4/98 2:49 PM	31	1222	OTHER	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
9/4/98 3:36 PM	24	26	OTHER	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
9/4/98 3:51 PM	36	1055	OTHER	SWITCH/DISCONNECT/LTD	TEMPORARY SWITCHING	FIELD INSPECTION	NO
9/4/98 5:32 PM	208	46	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
9/5/98 7:16 AM	164	34	OTHER	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
9/5/98 7:30 PM	60	25	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
9/6/98 12:03 AM	357	61	UNKNOWN	OTHER EQUIPMENT	REPLACED TRANSFORMER	FIELD INSPECTION	NO
9/6/98 7:57 AM	88	38	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
9/6/98 3:03 PM	387	43	OTHER	OVERHEAD TRANSFORMER	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
9/6/98 4:14 PM	678	38	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
9/6/98 4:18 PM	178	28	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
9/6/98 4:29 PM	79	741	OTHER	SWITCH/DISCONNECT/LTD	TEMPORARY SWITCHING	FIELD INSPECTION	NO
9/6/98 4:33 PM	62	119	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
9/6/98 7:07 PM	133	32	TREE CONTACT - PRIMARY	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	TREE TRIMMING	NO
9/6/98 7:40 PM	341	12	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
9/6/98 8:14 PM	588	53	WEATHER - LIGHTNING	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
9/6/98 8:57 PM	148	95	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
9/7/98 12:11 AM	488	4673	UNKNOWN	PHASE WIRE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
9/7/98 1:30 AM	782	188	WEATHER - LIGHTNING	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
9/7/98 1:33 AM	597	202	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
9/7/98 1:37 AM	672	123	WEATHER - LIGHTNING	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
9/7/98 1:39 AM	241	513	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
9/7/98 1:40 AM	395	2608	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
9/7/98 1:40 AM	972	370	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
9/7/98 1:41 AM	128	3256	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
9/7/98 1:41 AM	486	1001	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	PHASE WIRE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
9/7/98 1:42 AM	1145	2545	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
9/7/98 1:43 AM	117	119	WEATHER - LIGHTNING	SECTIONALIZER	CLOSED SECTIONALIZER	FIELD INSPECTION	NO
9/7/98 1:44 AM	301	1367	WEATHER - LIGHTNING	SUBSTATION BREAKER	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
9/7/98 1:44 AM	589	204	WEATHER - LIGHTNING	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
9/7/98 1:51 AM	732	599	WEATHER - LIGHTNING	CABLE	CLOSED SUBSTATION BREAKER	FIELD INSPECTION	NO
9/7/98 1:51 AM	1061	49	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	YES
9/7/98 1:55 AM	430	992	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
9/7/98 1:56 AM	679	89	WEATHER - LIGHTNING	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
9/7/98 1:57 AM	1173	35	WEATHER - LIGHTNING	FUSE/CUTOUT	REPAIRED EQUIPMENT	FIELD INSPECTION	NO
9/7/98 1:59 AM	301	820	WEATHER - LIGHTNING	SECTIONALIZER	CLOSED SECTIONALIZER	FIELD INSPECTION	NO
9/7/98 1:59 AM	491	389	WEATHER - LIGHTNING	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
9/7/98 2:00 AM	782	110	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
9/7/98 2:02 AM	1018	68	WEATHER - LIGHTNING	FUSE/CUTOUT	REPAIRED EQUIPMENT	FIELD INSPECTION	NO
9/7/98 2:06 AM	824	137	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
9/7/98 2:07 AM	783	55	WEATHER - LIGHTNING	FUSE/CUTOUT	REPAIRED EQUIPMENT	FIELD INSPECTION	NO
9/7/98 2:07 AM	908	48	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
9/7/98 2:09 AM	628	142	TREE CONTACT - PRIMARY	PHASE WIRE	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
9/7/98 2:15 AM	1035	63	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
9/7/98 2:25 AM	935	34	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	TREE TRIMMED	TREE TRIMMING	NO
9/7/98 2:34 AM	482	557	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	OTHER EQUIPMENT	CLOSED SWITCHGEAR	FIELD INSPECTION	NO
9/7/98 2:37 AM	603	182	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
9/7/98 2:38 AM	900	15	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
9/7/98 2:41 AM	1149	48	WEATHER - LIGHTNING	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
9/7/98 2:44 AM	481	19	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
9/7/98 2:45 AM	615	355	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
9/7/98 2:46 AM	919	28	WEATHER - LIGHTNING	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
9/7/98 3:12 AM	558	92	WEATHER - LIGHTNING	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
9/7/98 3:28 AM	707	37	WEATHER - LIGHTNING	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
9/7/98 3:47 AM	1018	98	WEATHER - LIGHTNING	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
9/7/98 4:07 AM	496	81	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
9/7/98 4:33 AM	657	163	WEATHER - LIGHTNING	FUSE/CUTOUT	CHANGED OTHER	FIELD INSPECTION	NO
9/7/98 5:03 AM	917	144	WEATHER - LIGHTNING	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
9/7/98 5:21 AM	305	371	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
9/7/98 5:45 AM	590	197	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
9/7/98 5:48 AM	672	126	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
9/7/98 5:49 AM	756	47	TREE CONTACT - PRIMARY	PHASE WIRE	TREE TRIMMED	TREE TRIMMING	NO
9/7/98 6:31 AM	725	102	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
9/7/98 6:33 AM	147	35	WILDLIFE	PHASE WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
9/7/98 6:47 AM	1078	56	WEATHER - WIND	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
9/7/98 6:48 AM	912	156	WEATHER - LIGHTNING	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
9/7/98 8:02 AM	403	110	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
9/7/98 8:27 AM	362	126	WEATHER - LIGHTNING	TAP WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
9/7/98 8:59 AM	577	36	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
9/7/98 9:04 AM	121	34	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
9/7/98 9:26 AM	889	46	TREE CONTACT - SECONDARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
9/7/98 10:09 AM	451	28	WEATHER - LIGHTNING	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
9/7/98 11:07 AM	173	133	WEATHER - LIGHTNING	TAP WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
9/7/98 11:24 AM	921	38	TREE LIMB BROKEN - SECONDARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
9/7/98 12:13 PM	62	193	WEATHER - LIGHTNING	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
9/7/98 12:38 PM	392	65	WEATHER - LIGHTNING	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
9/7/98 2:04 PM	31	58	WEATHER - LIGHTNING	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
9/7/98 2:23 PM	532	96	WEATHER - LIGHTNING	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
9/7/98 2:38 PM	227	4106	WEATHER - LIGHTNING	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
9/7/98 2:43 PM	277	19	UNKNOWN	OTHER EQUIPMENT	REPAIRED TRANSFORMER	FIELD INSPECTION	NO
9/7/98 3:58 PM	422	70	WEATHER - LIGHTNING	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
9/7/98 5:51 PM	39	1010	TREE CONTACT - PRIMARY	PHASE WIRE	TREE TRIMMED	TREE TRIMMING	NO
9/7/98 10:59 PM	351	24	WEATHER - LIGHTNING	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
9/7/98 11:56 PM	138	2437	UNKNOWN	CABLE JOINT/SPLICE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
9/8/98 1:53 AM	187	63	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
9/8/98 6:17 AM	143	118	UNKNOWN	OTHER EQUIPMENT	TEMPORARY SWITCHING	FIELD INSPECTION	NO
9/8/98 6:33 AM	237	24	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
9/8/98 7:18 AM	82	26	WILDLIFE	SWITCH/DISCONNECT/LTD	TEMPORARY SWITCHING	ANIMAL GUARD CHECK	NO
9/8/98 9:19 AM	1641	35	OTHER	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	YES
9/8/98 9:23 AM	22	1601	OTHER	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
9/8/98 10:00 AM	20	154	UNKNOWN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
9/8/98 11:47 AM	468	18	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
9/8/98 12:11 PM	73	1158	OTHER	PHASE WIRE	CLOSED SUBSTATION BREAKER	FIELD INSPECTION	NO
9/8/98 12:14 PM	70	3935	UNKNOWN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
9/8/98 1:42 PM	113	176	WEATHER - LIGHTNING	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
9/9/98 2:11 AM	101	304	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
9/9/98 10:21 AM	399	65	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
9/9/98 1:27 PM	43	59	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
9/9/98 2:49 PM	37	50	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	PROTECTIVE RELAY	CLOSED SUBSTATION BREAKER	FIELD INSPECTION	NO
9/9/98 2:57 PM	61	1031	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
9/9/98 4:43 PM	47	15	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
9/10/98 12:43 PM	87	156	PUBLIC - DIG-IN BY OTHERS	CABLE	TEMPORARY SWITCHING	NO ACTION NEEDED	NO
9/10/98 2:00 PM	196	14	OVERHEAD EQUIPMENT - MALFUNCTION	FUSE/CUTOUT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
9/10/98 7:51 PM	144	99	UNKNOWN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
9/10/98 8:05 PM	100	52	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
9/11/98 8:30 AM	25	141	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
9/12/98 6:55 AM	60	2614	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
9/12/98 4:39 PM	501	290	OTHER	UNDERGROUND TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
9/12/98 10:47 PM	93	11	PUBLIC - VEHICLES	PHASE WIRE	TEMPORARY SWITCHING	NO ACTION NEEDED	NO
9/13/98 7:48 AM	44	20	WILDLIFE	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
9/13/98 11:05 AM	1470	15	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	YES
9/13/98 6:06 PM	414	22	OTHER	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
9/13/98 6:13 PM	52	666	OTHER	SWITCH/DISCONNECT/LTD	TEMPORARY SWITCHING	FIELD INSPECTION	NO
9/14/98 6:59 AM	66	20	PUBLIC - VEHICLES	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	NO ACTION NEEDED	NO
9/14/98 8:35 AM	65	1367	PUBLIC - DIG-IN BY OTHERS	CABLE	TEMPORARY SWITCHING	NO ACTION NEEDED	NO
9/14/98 3:08 PM	57	487	INTENTIONAL - SCHEDULED CONSTRUCTION, MAINTENANCE, OR REPAIR	CAPACITOR	REPLACED EQUIPMENT	NO ACTION NEEDED	NO
9/14/98 4:40 PM	260	21	WEATHER - LIGHTNING	FUSE/CUTOUT	REPAIRED EQUIPMENT	FIELD INSPECTION	NO
9/14/98 5:47 PM	48	467	WEATHER - FLOODING/RAIN	ARRESTER	CLOSED SUBSTATION BREAKER	FIELD INSPECTION	NO
9/14/98 9:27 PM	143	310	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
9/14/98 9:38 PM	759	174	TREE LIMB BROKEN - PRIMARY	POLE	OTHER	TREE TRIMMING	NO
9/14/98 9:49 PM	281	1287	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
9/14/98 11:48 PM	255	97	WILDLIFE	SWITCH/DISCONNECT/LTD	TEMPORARY SWITCHING	ANIMAL GUARD CHECK	NO
9/15/98 12:47 AM	58	836	COMED/CONTRACTOR - ACCIDENT BY COMED	OTHER	CLOSED SUBSTATION BREAKER	TRAINING	NO
9/15/98 2:28 AM	145	79	WEATHER - WIND	CROSS/ALLEY ARM	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
9/15/98 3:29 AM	431	99	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
9/15/98 7:24 AM	246	49	UNKNOWN	OTHER EQUIPMENT	TEMPORARY FUSE OR CUTOUT	FIELD INSPECTION	NO
9/15/98 12:12 PM	155	792	WEATHER - FLOODING/RAIN	INSULATOR	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
9/15/98 1:02 PM	598	384	UNKNOWN	POLE	REPLACED EQUIPMENT	FIELD INSPECTION	NO
9/15/98 7:53 PM	282	20	UNKNOWN	OTHER EQUIPMENT	REPLACED TRANSFORMER	FIELD INSPECTION	NO
9/16/98 7:11 AM	112	276	WILDLIFE	PHASE WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
9/16/98 7:41 AM	199	11	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
9/16/98 4:13 PM	7	38	INTENTIONAL - EMERGENCY REPAIRS	FUSE/CUTOUT	TREE TRIMMED	FIELD INSPECTION	NO
9/16/98 7:34 PM	3	49	UNKNOWN	OTHER EQUIPMENT	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
9/17/98 9:43 AM	60	55	OTHER	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
9/17/98 4:23 PM	107	199	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
9/17/98 5:45 PM	15	123	INTENTIONAL - PROTECTION OF SYSTEM INTEGRITY	SECTIONALIZER	CLOSED SECTIONALIZER	NO ACTION NEEDED	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
9/17/98 6:34 PM	26	76	OTHER	TAP WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
9/18/98 3:01 AM	66	573	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
9/18/98 8:59 AM	46	1196	TREE CONTACT - PRIMARY	PHASE WIRE	TREE REMOVED	TREE TRIMMING	NO
9/18/98 1:54 PM	91	205	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
9/18/98 3:12 PM	48	204	INTENTIONAL - EMERGENCY REPAIRS	SWITCH/DISCONNECT/LTD	TEMPORARY SWITCHING	FIELD INSPECTION	NO
9/19/98 7:42 PM	1958	109	WEATHER - FLOODING/RAIN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
9/20/98 10:46 AM	151	14	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
9/20/98 11:08 AM	376	230	WEATHER - WIND	POLE	CLOSED SWITCH/DISCONNECT/LT	FIELD INSPECTION	NO
9/20/98 2:10 PM	155	231	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
9/20/98 2:14 PM	406	79	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
9/20/98 2:23 PM	531	35	WEATHER - LIGHTNING	OTHER TRANSFORMER	REPLACED EQUIPMENT	FIELD INSPECTION	NO
9/20/98 2:31 PM	393	465	WEATHER - LIGHTNING	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
9/20/98 2:35 PM	610	72	WEATHER - LIGHTNING	UNDERGROUND TRANSFORMER	REPLACED EQUIPMENT	FIELD INSPECTION	NO
9/20/98 3:29 PM	406	35	UNKNOWN	OTHER EQUIPMENT	CLOSED EQUIPMENT	FIELD INSPECTION	NO
9/20/98 3:44 PM	196	58	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
9/20/98 3:49 PM	1151	175	TREE CONTACT - PRIMARY	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
9/20/98 3:50 PM	668	203	WEATHER - FLOODING/RAIN	ARRESTER	OTHER	FIELD INSPECTION	NO
9/20/98 3:53 PM	992	80	TREE CONTACT - PRIMARY	OVERHEAD TRANSFORMER	TREE TRIMMED	TREE TRIMMING	NO
9/20/98 4:01 PM	109	312	WEATHER - LIGHTNING	FUSE/CUTOUT	REPAIRED EQUIPMENT	FIELD INSPECTION	NO
9/20/98 4:01 PM	354	452	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
9/20/98 4:28 PM	887	35	WEATHER - LIGHTNING	OVERHEAD TRANSFORMER	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
9/20/98 4:58 PM	302	38	TREE CONTACT - PRIMARY	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	TREE TRIMMING	NO
9/20/98 4:59 PM	301	154	TREE CONTACT - PRIMARY	CROSS/ALLEY ARM	CLOSED FUSE OR CUTOUT	TREE TRIMMING	NO
9/20/98 4:59 PM	481	143	TREE CONTACT - PRIMARY	TAP WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
9/20/98 5:01 PM	734	76	WEATHER - FLOODING/RAIN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
9/20/98 5:01 PM	1049	73	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
9/20/98 5:03 PM	522	99	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
9/20/98 5:03 PM	742	38	WEATHER - LIGHTNING	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
9/20/98 5:08 PM	772	20	WEATHER - LIGHTNING	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
9/20/98 5:11 PM	320	2159	WEATHER - FLOODING/RAIN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
9/20/98 5:13 PM	677	172	WEATHER - FLOODING/RAIN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
9/20/98 5:18 PM	162	488	TREE CONTACT - PRIMARY	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	TREE TRIMMING	NO
9/20/98 5:26 PM	609	38	WEATHER - LIGHTNING	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
9/20/98 6:58 PM	377	66	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
9/20/98 7:56 PM	579	61	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
9/20/98 10:37 PM	420	366	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
9/20/98 10:45 PM	630	54	WEATHER - LIGHTNING	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
9/21/98 12:10 AM	1235	69	TREE CONTACT - PRIMARY	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
9/21/98 1:08 AM	232	43	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
9/21/98 5:38 AM	162	250	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OTHER	TREE TRIMMING	NO
9/21/98 6:00 AM	325	24	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED EQUIPMENT	FIELD INSPECTION	NO
9/21/98 6:27 AM	533	22	TREE CONTACT - SECONDARY	AERIAL CABLE	TREE TRIMMED	TREE TRIMMING	NO
9/21/98 7:59 AM	106	57	WILDLIFE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	ANIMAL GUARD CHECK	NO
9/21/98 8:15 AM	109	50	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED OVERHEAD MATERIAL	TREE TRIMMING	NO
9/21/98 8:48 AM	153	192	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
9/21/98 9:27 AM	423	24	TREE CONTACT - SECONDARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
9/21/98 9:50 AM	150	232	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
9/21/98 11:31 AM	89	36	WEATHER - WIND	AERIAL CABLE	TREE TRIMMED	FIELD INSPECTION	NO
9/21/98 1:08 PM	202	61	WEATHER - WIND	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
9/21/98 3:01 PM	179	16	WEATHER - WIND	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
9/21/98 3:46 PM	134	23	TREE LIMB BROKEN - SECONDARY	AERIAL CABLE	REPAIRED OTHER	TREE TRIMMING	NO
9/21/98 3:47 PM	133	42	TREE LIMB BROKEN - SECONDARY	AERIAL CABLE	OTHER	TREE TRIMMING	NO
9/21/98 3:49 PM	131	37	TREE LIMB BROKEN - SECONDARY	FUSE/CUTOUT	TREE REMOVED	TREE TRIMMING	NO
9/21/98 4:01 PM	119	24	TREE LIMB BROKEN - SECONDARY	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
9/21/98 4:44 PM	76	36	TREE LIMB BROKEN - SECONDARY	AERIAL CABLE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
9/21/98 4:59 PM	61	18	TREE LIMB BROKEN - SECONDARY	AERIAL CABLE	TREE REMOVED	TREE TRIMMING	NO
9/21/98 5:52 PM	348	50	WEATHER - WIND	CONNECTOR/SLEEVE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
9/21/98 11:51 PM	131	476	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
9/22/98 7:02 AM	138	296	TREE CONTACT - PRIMARY	PHASE WIRE	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
9/22/98 11:00 AM	105	2029	PUBLIC - DIG-IN BY OTHERS	CABLE	TEMPORARY SWITCHING	NO ACTION NEEDED	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
9/22/98 11:16 AM	224	36	OTHER	CONNECTOR/SLEEVE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
9/22/98 2:20 PM	59	27	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
9/22/98 8:30 PM	197	44	OTHER	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
9/23/98 3:21 AM	244	137	PUBLIC - FIRE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
9/23/98 4:00 AM	44	141	OTHER	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
9/23/98 7:52 AM	148	609	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	SUBSTATION BREAKER	REPAIRED EQUIPMENT	FIELD INSPECTION	NO
9/23/98 8:20 AM	56	115	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
9/23/98 9:19 AM	96	110	TREE CONTACT - PRIMARY	PHASE WIRE	TREE TRIMMED	TREE TRIMMING	NO
9/23/98 10:14 AM	58	149	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
9/23/98 5:39 PM	152	14	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
9/23/98 5:50 PM	74	384	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
9/23/98 7:13 PM	12	115	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
9/24/98 12:58 AM	67	2134	UNKNOWN	CABLE JOINT/SPLICE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
9/24/98 3:55 PM	104	15	WILDLIFE	TAP WIRE	CHANGED OTHER	ANIMAL GUARD CHECK	NO
9/25/98 8:44 AM	71	51	UNKNOWN	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
9/25/98 2:00 PM	85	23	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
9/25/98 2:43 PM	87	80	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
9/25/98 5:23 PM	87	97	UNKNOWN	NEUTRAL WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
9/25/98 8:20 PM	89	34	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
9/25/98 9:31 PM	99	544	UNKNOWN	CABLE JOINT/SPLICE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
9/26/98 8:16 AM	59	103	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
9/26/98 8:19 AM	91	54	INTENTIONAL - SCHEDULED CONSTRUCTION, MAINTENANCE, OR REPAIR	PHASE WIRE	OTHER	NO ACTION NEEDED	NO
9/26/98 10:40 AM	5	150	INTENTIONAL - SCHEDULED CONSTRUCTION, MAINTENANCE, OR REPAIR	SWITCH/DISCONNECT/LTD	CLOSED SWITCH/DISCONNECT/LT	NO ACTION NEEDED	NO
9/26/98 11:20 AM	80	19	TREE CONTACT - PRIMARY	CROSS/ALLEY ARM	CLOSED FUSE OR CUTOUT	TREE TRIMMING	NO
9/26/98 11:59 AM	68	1158	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
9/26/98 1:56 PM	79	60	OTHER	POLE	TEMPORARY JUMPER TO RESTORE	FIELD INSPECTION	NO
9/26/98 4:29 PM	88	251	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
9/26/98 4:51 PM	59	214	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
9/26/98 10:40 PM	130	14	OTHER	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
9/27/98 9:29 AM	111	12	WEATHER - WIND	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
9/27/98 9:31 AM	99	26	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
9/27/98 6:40 PM	217	12	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
9/27/98 8:45 PM	390	83	UNKNOWN	OTHER EQUIPMENT	TEMPORARY SWITCHING	FIELD INSPECTION	NO
9/28/98 8:15 AM	116	26	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
9/28/98 11:23 AM	327	47	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
9/28/98 5:58 PM	77	444	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	SWITCHGEAR	CLOSED SWITCHGEAR	FIELD INSPECTION	NO
9/28/98 9:38 PM	92	22	UNKNOWN	TAP WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
9/29/98 4:40 AM	285	32	PUBLIC - FIRE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
9/29/98 7:23 AM	112	22	WILDLIFE	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
9/29/98 8:10 AM	90	74	WILDLIFE	PHASE WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
9/29/98 1:39 PM	137	20448	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
9/29/98 4:38 PM	82	29	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
9/29/98 6:50 PM	105	402	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	OTHER TRANSFORMER	TEMPORARY SWITCHING	FIELD INSPECTION	NO
9/30/98 5:04 AM	86	60	WILDLIFE	FUSE/CUTOUT	REPLACED EQUIPMENT	ANIMAL GUARD CHECK	NO
9/30/98 2:07 PM	78	294	PUBLIC - FOREIGN OBJECT	FUSE/CUTOUT	OTHER	NO ACTION NEEDED	NO
9/30/98 3:13 PM	482	53	TREE LIMB BROKEN - SECONDARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
9/30/98 3:22 PM	113	237	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
9/30/98 3:24 PM	51	54	TREE CONTACT - PRIMARY	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	TREE TRIMMING	NO
9/30/98 3:30 PM	140	25	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
9/30/98 3:38 PM	108	142	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
9/30/98 3:40 PM	115	20	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
9/30/98 4:05 PM	60	163	WEATHER - LIGHTNING	CROSS/ALLEY ARM	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
10/1/98 8:15 AM	100	456	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
10/1/98 1:21 PM	69	2366	PUBLIC - DIG-IN BY OTHERS	CABLE	TEMPORARY SWITCHING	NO ACTION NEEDED	NO
10/1/98 1:26 PM	59	715	PUBLIC - DIG-IN BY OTHERS	CABLE	TEMPORARY SWITCHING	NO ACTION NEEDED	NO
10/1/98 3:41 PM	121	16	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
10/1/98 4:10 PM	90	18	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
10/1/98 6:08 PM	96	56	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
10/1/98 11:02 PM	83	388	OTHER	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
10/2/98 1:38 AM	97	13	PUBLIC - FIRE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	NO ACTION NEEDED	NO
10/2/98 7:17 AM	328	16	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
10/2/98 9:40 AM	13	17	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	SUBSTATION BREAKER	CLOSED SUBSTATION BREAKER	FIELD INSPECTION	NO
10/2/98 10:42 AM	103	85	PUBLIC - ACCIDENT BY OTHERS	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
10/2/98 12:18 PM	92	64	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
10/2/98 9:44 PM	91	160	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
10/2/98 10:01 PM	409	26	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
10/3/98 7:03 AM	27	869	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
10/3/98 7:31 AM	6	864	WILDLIFE	SECTIONALIZER	CLOSED SUBSTATION BREAKER	ANIMAL GUARD CHECK	NO
10/3/98 8:29 AM	54	110	OVERHEAD EQUIPMENT - CONTAMINATION	SWITCHGEAR	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
10/3/98 9:11 AM	139	63	INTENTIONAL - SCHEDULED CONSTRUCTION, MAINTENANCE, OR REPAIR	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	NO ACTION NEEDED	NO
10/3/98 9:57 AM	208	19	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
10/3/98 2:42 PM	238	156	OTHER	SWITCH/DISCONNECT/LTD	TEMPORARY SWITCHING	FIELD INSPECTION	NO
10/3/98 3:32 PM	293	48	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
10/3/98 7:24 PM	201	1810	OTHER	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
10/3/98 8:56 PM	29	101	UNKNOWN	OTHER EQUIPMENT	CLOSED SUBSTATION BREAKER	FIELD INSPECTION	NO
10/3/98 11:39 PM	126	17	OTHER	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
10/4/98 2:55 AM	241	169	UNDERGROUND EQUIPMENT - UG FAILURE	CABLE JOINT/SPLICE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
10/4/98 8:55 AM	122	39	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
10/5/98 9:55 AM	50	233	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
10/5/98 10:30 AM	151	11	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
10/5/98 11:43 AM	422	18	PUBLIC - DIG-IN BY OTHERS	CABLE JOINT/SPLICE	REPAIRED UNDERGROUND MATERIAL	NO ACTION NEEDED	NO
10/5/98 11:48 AM	117	15	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
10/5/98 12:27 PM	33	37	OTHER	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
10/5/98 4:03 PM	77	7414	PUBLIC - DIG-IN BY OTHERS	CABLE	TEMPORARY SWITCHING	NO ACTION NEEDED	NO
10/6/98 5:55 AM	285	16338	WEATHER - FLOODING/RAIN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
10/6/98 8:16 AM	8	2765	WEATHER - FLOODING/RAIN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
10/6/98 9:10 AM	175	242	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
10/6/98 9:55 AM	40	71	UNKNOWN	OTHER EQUIPMENT	TEMPORARY SWITCHING	FIELD INSPECTION	NO
10/6/98 10:15 AM	85	124	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
10/6/98 10:53 AM	301	388	WEATHER - FLOODING/RAIN	INSULATOR	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
10/6/98 11:03 AM	62	50	OTHER	FUSE/CUTOUT	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
10/6/98 11:42 AM	14	1264	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
10/6/98 2:18 PM	279	43	TREE CONTACT - PRIMARY	PHASE WIRE	TREE TRIMMED	TREE TRIMMING	NO
10/6/98 2:26 PM	88	2897	PUBLIC - DIG-IN BY OTHERS	CABLE	OTHER	NO ACTION NEEDED	NO
10/6/98 4:13 PM	247	524	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
10/6/98 6:27 PM	30	633	OTHER	CABLE	OTHER	FIELD INSPECTION	NO
10/6/98 7:14 PM	162	275	OTHER	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
10/7/98 8:13 AM	72	98	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
10/7/98 10:25 AM	60	22	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
10/7/98 11:45 AM	45	118	UNKNOWN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
10/7/98 12:07 PM	93	23	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
10/7/98 2:04 PM	71	49	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
10/7/98 6:26 PM	59	83	TREE CONTACT - PRIMARY	PHASE WIRE	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
10/8/98 3:30 AM	82	273	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
10/8/98 10:12 AM	58	26	INTENTIONAL - SCHEDULED CONSTRUCTION, MAINTENANCE, OR REPAIR	OTHER EQUIPMENT	REPLACED EQUIPMENT	NO ACTION NEEDED	NO
10/8/98 12:40 PM	50	35	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
10/8/98 2:12 PM	43	57	UNKNOWN	FUSE/CUTOUT	CHANGED OTHER	FIELD INSPECTION	NO
10/8/98 2:17 PM	58	11	WILDLIFE	FUSE/CUTOUT	CHANGED OTHER	ANIMAL GUARD CHECK	NO
10/9/98 9:17 AM	28	2871	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
10/9/98 11:54 AM	82	180	OTHER	TAP WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
10/10/98 6:57 AM	33	901	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
10/10/98 8:11 AM	119	28	WILDLIFE	FUSE/CUTOUT	REPAIRED OVERHEAD MATERIAL	ANIMAL GUARD CHECK	NO
10/10/98 10:51 AM	319	29	OTHER	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
10/10/98 12:22 PM	61	14	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
10/10/98 12:39 PM	141	36	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
10/10/98 3:46 PM	69	1145	OTHER	PHASE WIRE	CLOSED SUBSTATION BREAKER	FIELD INSPECTION	NO
10/10/98 10:48 PM	182	339	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
10/10/98 10:52 PM	79	593	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
10/11/98 9:34 AM	77	91	WILDLIFE	PHASE WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
10/11/98 12:15 PM	140	176	WILDLIFE	PHASE WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
10/11/98 12:19 PM	71	401	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
10/11/98 1:47 PM	48	3452	WILDLIFE	PHASE WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
10/11/98 11:51 PM	99	30	TREE CONTACT - PRIMARY	FUSE/CUTOUT	TREE TRIMMED	TREE TRIMMING	NO
10/12/98 8:51 AM	54	1463	OTHER	SWITCHGEAR	TEMPORARY SWITCHING	FIELD INSPECTION	NO
10/12/98 12:33 PM	42	374	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
10/12/98 7:14 PM	111	479	PUBLIC - FOREIGN OBJECT	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	NO ACTION NEEDED	NO
10/13/98 8:29 AM	61	240	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
10/13/98 8:39 AM	81	32	WILDLIFE	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
10/13/98 9:21 AM	144	41	TREE CONTACT - SECONDARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
10/13/98 11:18 AM	120	131	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
10/13/98 2:08 PM	1387	56	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	YES
10/13/98 2:28 PM	92	33	UNKNOWN	FUSE/CUTOUT	CHANGED OTHER	FIELD INSPECTION	NO
10/13/98 3:17 PM	61	397	WILDLIFE	PHASE WIRE	CHANGED OTHER	ANIMAL GUARD CHECK	NO
10/13/98 3:47 PM	68	12	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
10/13/98 4:48 PM	102	14	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
10/13/98 4:59 PM	111	864	UNKNOWN	OTHER EQUIPMENT	OTHER	FIELD INSPECTION	NO
10/14/98 7:48 AM	42	1241	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
10/14/98 8:39 AM	91	63	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
10/14/98 11:06 AM	129	14	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
10/14/98 1:34 PM	136	21	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
10/15/98 7:16 AM	104	35	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
10/15/98 7:21 AM	99	1862	WILDLIFE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	ANIMAL GUARD CHECK	NO
10/15/98 8:37 AM	48	161	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
10/15/98 9:25 AM	87	52	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
10/15/98 3:38 PM	67	56	UNKNOWN	TAP WIRE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
10/15/98 7:03 PM	77	266	OTHER	SWITCH/DISCONNECT/LTD	CHANGED OTHER	FIELD INSPECTION	NO
10/16/98 5:02 AM	78	65	OTHER	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
10/16/98 10:08 AM	117	66	UNKNOWN	OTHER EQUIPMENT	TEMPORARY SWITCHING	FIELD INSPECTION	NO
10/16/98 1:02 PM	931	145	PUBLIC - DIG-IN BY OTHERS	CABLE	REPAIRED UNDERGROUND MATERIAL	NO ACTION NEEDED	NO
10/16/98 2:19 PM	105	1105	UNDERGROUND EQUIPMENT - MALFUNCTION	OTHER EQUIPMENT	CLOSED SWITCH/DISCONNECT/LT	FIELD INSPECTION	NO
10/16/98 2:26 PM	54	798	UNKNOWN	SECTIONALIZER	TEMPORARY SWITCHING	FIELD INSPECTION	NO
10/17/98 12:49 PM	131	44	TREE CONTACT - PRIMARY	PHASE WIRE	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
10/17/98 4:16 PM	194	128	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
10/17/98 8:31 PM	124	419	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
10/17/98 10:51 PM	105	1414	UNKNOWN	PHASE WIRE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
10/17/98 11:00 PM	120	1087	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
10/17/98 11:34 PM	154	18	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
10/18/98 12:10 AM	115	51	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
10/18/98 1:59 AM	460	412	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
10/18/98 2:30 AM	117	97	TREE CONTACT - PRIMARY	PHASE WIRE	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
10/18/98 3:09 AM	91	65	WEATHER - LIGHTNING	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
10/18/98 3:30 AM	254	29	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED OVERHEAD MATERIAL	TREE TRIMMING	NO
10/18/98 5:24 AM	91	17	WEATHER - FLOODING/RAIN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
10/18/98 5:56 AM	994	18	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	YES
10/18/98 8:23 AM	1147	138	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
10/18/98 9:40 AM	155	40	WEATHER - WIND	ARRESTER	TEMPORARY SWITCHING	FIELD INSPECTION	NO
10/18/98 10:49 AM	61	99	WEATHER - FLOODING/RAIN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
10/18/98 11:01 AM	179	190	TREE CONTACT - PRIMARY	CROSS/ALLEY ARM	REPLACED EQUIPMENT	TREE TRIMMING	NO
10/18/98 11:27 AM	208	12	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
10/19/98 6:49 AM	67	4415	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
10/19/98 3:44 PM	91	3670	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
10/19/98 6:49 PM	106	181	UNKNOWN	OTHER EQUIPMENT	TEMPORARY SWITCHING	FIELD INSPECTION	NO
10/19/98 11:08 PM	47	55	PUBLIC - VANDALISM	METER ENTRANCE	REPAIRED EQUIPMENT	NO ACTION NEEDED	NO
10/20/98 7:11 AM	314	38	UNKNOWN	CONNECTOR/SLEEVE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
10/20/98 1:12 PM	109	42	PUBLIC - FOREIGN OBJECT	PHASE WIRE	REPLACED FUSE OR CUTOUT	NO ACTION NEEDED	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
10/20/98 8:33 PM	57	1885	UNKNOWN	CABLE	OTHER	FIELD INSPECTION	NO
10/21/98 1:08 AM	69	34	OTHER	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
10/21/98 1:08 AM	169	155	OTHER	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
10/21/98 4:49 AM	90	802	OTHER	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
10/21/98 9:05 AM	58	4914	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
10/21/98 9:18 AM	67	147	UNKNOWN	TAP WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
10/21/98 1:24 PM	151	27	TREE CONTACT - PRIMARY	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
10/22/98 9:23 AM	85	221	PUBLIC - ACCIDENT BY OTHERS	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	NO ACTION NEEDED	NO
10/22/98 12:07 PM	108	252	UNKNOWN	CABLE JOINT/SPLICE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
10/23/98 1:30 AM	80	51	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
10/23/98 10:56 AM	87	49	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
10/23/98 3:44 PM	121	26	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
10/23/98 5:03 PM	127	20	WILDLIFE	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
10/24/98 12:15 AM	26	542	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
10/24/98 8:27 AM	153	45	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
10/24/98 2:48 PM	132	28	UNKNOWN	CROSS/ALLEY ARM	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
10/25/98 4:43 AM	64	32	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
10/25/98 7:13 AM	2	361	UNKNOWN	OTHER EQUIPMENT	TEMPORARY SWITCHING	FIELD INSPECTION	NO
10/25/98 7:13 AM	72	353	WILDLIFE	PHASE WIRE	TEMPORARY SWITCHING	ANIMAL GUARD CHECK	NO
10/25/98 10:49 AM	176	20	WILDLIFE	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
10/25/98 3:45 PM	120	1240	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
10/25/98 3:56 PM	24	687	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
10/25/98 6:39 PM	431	41	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
10/25/98 6:58 PM	77	53	UNKNOWN	FUSE/CUTOUT	REPAIRED EQUIPMENT	FIELD INSPECTION	NO
10/26/98 6:53 AM	57	417	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
10/26/98 7:09 AM	81	35	WILDLIFE	PHASE WIRE	CLOSED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
10/26/98 8:25 AM	55	319	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	OTHER TRANSFORMER	TEMPORARY SWITCHING	FIELD INSPECTION	NO
10/26/98 8:34 AM	46	957	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	OTHER TRANSFORMER	TEMPORARY SWITCHING	FIELD INSPECTION	NO
10/26/98 8:35 AM	49	1613	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	OTHER TRANSFORMER	TEMPORARY SWITCHING	FIELD INSPECTION	NO
10/26/98 8:35 AM	153	729	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	OTHER TRANSFORMER	TEMPORARY SWITCHING	FIELD INSPECTION	NO
10/26/98 8:37 AM	141	1095	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	OTHER TRANSFORMER	TEMPORARY SWITCHING	FIELD INSPECTION	NO
10/26/98 9:16 AM	74	24	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
10/26/98 2:18 PM	7	32	WILDLIFE	PHASE WIRE	CLOSED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
10/26/98 2:40 PM	175	2440	OTHER	SUBSTATION BREAKER	TEMPORARY SWITCHING	FIELD INSPECTION	NO
10/26/98 3:01 PM	119	606	UNDERGROUND EQUIPMENT - UG FAILURE	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
10/27/98 7:06 AM	64	43	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
10/27/98 3:30 PM	110	288	WEATHER - LIGHTNING	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
10/27/98 4:02 PM	73	36	UNKNOWN	LINE RECLOSER	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
10/27/98 5:56 PM	74	90	PUBLIC - FOREIGN OBJECT	PHASE WIRE	REPLACED FUSE OR CUTOUT	NO ACTION NEEDED	NO
10/28/98 3:05 AM	76	2312	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
10/28/98 3:09 AM	196	4651	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
10/28/98 8:26 AM	87	662	UNKNOWN	OTHER EQUIPMENT	CONTRACTOR WARNED	FIELD INSPECTION	NO
10/28/98 9:32 AM	54	146	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
10/28/98 3:01 PM	149	39	OTHER	UNDERGROUND TRANSFORMER	REPLACED UNDERGROUND MATERIAL	FIELD INSPECTION	NO
10/29/98 7:08 AM	112	169	OTHER	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
10/29/98 8:59 AM	67	1462	PUBLIC - DIG-IN BY OTHERS	CABLE	TEMPORARY SWITCHING	NO ACTION NEEDED	NO
10/29/98 10:03 AM	55	1081	PUBLIC - DIG-IN BY OTHERS	CABLE	TEMPORARY SWITCHING	NO ACTION NEEDED	NO
10/29/98 1:06 PM	39	583	PUBLIC - DIG-IN BY OTHERS	CABLE	TEMPORARY SWITCHING	NO ACTION NEEDED	NO
10/29/98 2:56 PM	54	59	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
10/29/98 6:03 PM	177	122	TREE CONTACT - PRIMARY	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	TREE TRIMMING	NO
10/29/98 6:14 PM	62	2119	TREE CONTACT - PRIMARY	SUBSTATION RECLOSER	TREE TRIMMED	TREE TRIMMING	NO
10/29/98 6:16 PM	84	167	OTHER	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
10/29/98 6:32 PM	128	136	WEATHER - LIGHTNING	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
10/29/98 6:54 PM	116	21	WEATHER - LIGHTNING	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
10/29/98 7:57 PM	66	7636	OTHER	SWITCHGEAR	TEMPORARY SWITCHING	FIELD INSPECTION	NO
10/29/98 8:20 PM	146	26	WEATHER - LIGHTNING	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
10/29/98 10:00 PM	540	20	OTHER	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
10/29/98 10:21 PM	457	263	WEATHER - FLOODING/RAIN	SWITCHGEAR	TEMPORARY SWITCHING	FIELD INSPECTION	NO
10/29/98 11:44 PM	104	14	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
10/30/98 2:58 AM	80	124	WEATHER - LIGHTNING	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
10/30/98 8:37 AM	203	98	OTHER	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
10/30/98 9:29 AM	76	29	UNKNOWN	TAP WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
10/30/98 9:31 AM	89	40	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
10/30/98 9:34 AM	166	21	UNKNOWN	OVERHEAD TRANSFORMER	TEMPORARY JUMPER TO RESTORE	FIELD INSPECTION	NO
10/30/98 9:58 AM	17	86	UNKNOWN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
10/30/98 10:13 AM	7	22	INTENTIONAL - PROTECTION OF SYSTEM INTEGRITY	ARRESTER	REPLACED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
10/30/98 11:55 AM	330	29	WEATHER - FLOODING/RAIN	PHASE WIRE	REPLACED EQUIPMENT	FIELD INSPECTION	NO
10/30/98 12:07 PM	123	23	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
10/30/98 12:48 PM	37	69	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
10/30/98 11:05 PM	84	16	UNKNOWN	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
10/31/98 9:00 AM	60	290	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
10/31/98 9:49 AM	86	76	WILDLIFE	PHASE WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
10/31/98 6:37 PM	38	2425	TREE CONTACT - PRIMARY	TAP WIRE	REPLACED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/1/98 1:52 PM	104	2783	UNKNOWN	CABLE JOINT/SPLICE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
11/1/98 10:55 PM	64	33	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
11/2/98 9:29 AM	61	26	WILDLIFE	PHASE WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
11/2/98 12:41 PM	48	16	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
11/2/98 1:21 PM	122	21	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
11/2/98 2:08 PM	327	56	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/2/98 4:56 PM	154	930	OTHER	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
11/2/98 6:16 PM	59	100	UNKNOWN	STATIC WIRE	OTHER	FIELD INSPECTION	NO
11/2/98 7:04 PM	156	31	TREE CONTACT - PRIMARY	PHASE WIRE	TREE TRIMMED	TREE TRIMMING	NO
11/3/98 7:55 AM	47	21	WILDLIFE	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
11/3/98 11:23 AM	27	7602	PUBLIC - DIG-IN BY OTHERS	CABLE	TEMPORARY SWITCHING	NO ACTION NEEDED	NO
11/3/98 12:43 PM	117	21	UNKNOWN	OTHER EQUIPMENT	TREE REMOVED	FIELD INSPECTION	NO
11/4/98 1:10 PM	70	53	WILDLIFE	PHASE WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
11/4/98 5:05 PM	63	1847	OTHER	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
11/4/98 5:23 PM	123	45	WEATHER - FLOODING/RAIN	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
11/4/98 5:53 PM	67	2843	TREE CONTACT - PRIMARY	PHASE WIRE	TREE TRIMMED	TREE TRIMMING	NO
11/5/98 7:32 PM	468	62	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
11/6/98 8:13 PM	72	78	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
11/6/98 11:39 PM	36	1048	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
11/7/98 4:44 AM	66	63	UNKNOWN	CABLE JOINT/SPLICE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
11/7/98 11:38 AM	102	22	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
11/7/98 2:44 PM	81	24	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
11/7/98 2:51 PM	42	16	INTENTIONAL - EMERGENCY REPAIRS	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
11/8/98 1:46 AM	44	52	WEATHER - LIGHTNING	ARRESTER	TEMPORARY SWITCHING	FIELD INSPECTION	NO
11/8/98 7:49 AM	90	10	WILDLIFE	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
11/8/98 8:27 AM	153	34	UNKNOWN	OVERHEAD TRANSFORMER	TEMPORARY JUMPER TO RESTORE	FIELD INSPECTION	NO
11/8/98 9:23 AM	102	10	WILDLIFE	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
11/8/98 12:34 PM	68	22	WILDLIFE	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
11/8/98 1:14 PM	81	12	WILDLIFE	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
11/9/98 1:26 PM	274	17	UNKNOWN	FUSE/CUTOUT	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/9/98 4:13 PM	99	339	WEATHER - ICE	INSULATOR	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/9/98 6:54 PM	81	190	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/9/98 11:30 PM	170	897	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/9/98 11:39 PM	93	484	WEATHER - WIND	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
11/9/98 11:52 PM	92	38	WEATHER - FLOODING/RAIN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
11/10/98 1:41 AM	129	136	TREE CONTACT - PRIMARY	FUSE/CUTOUT	TREE TRIMMED	TREE TRIMMING	NO
11/10/98 3:18 AM	152	12	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
11/10/98 4:32 AM	174	30	WILDLIFE	SECTIONALIZER	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
11/10/98 4:36 AM	140	72	WEATHER - LIGHTNING	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
11/10/98 5:25 AM	105	334	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 6:05 AM	225	30	WEATHER - WIND	NEUTRAL WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 6:22 AM	148	31	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 6:25 AM	131	135	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
11/10/98 6:38 AM	152	365	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/10/98 6:40 AM	177	82	WEATHER - WIND	CROSS/ALLEY ARM	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 6:57 AM	280	141	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/10/98 7:05 AM	295	51	WEATHER - WIND	OTHER EQUIPMENT	TREE TRIMMED	FIELD INSPECTION	NO
11/10/98 7:07 AM	173	38	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/10/98 7:10 AM	1865	1188	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 7:15 AM	210	4434	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/10/98 7:29 AM	271	32	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	OTHER EQUIPMENT	TEMPORARY SWITCHING	FIELD INSPECTION	NO
11/10/98 7:31 AM	224	99	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/10/98 7:31 AM	314	287	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 7:36 AM	414	94	WEATHER - WIND	PHASE WIRE	REPAIRED EQUIPMENT	FIELD INSPECTION	NO
11/10/98 7:38 AM	57	69	WEATHER - WIND	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
11/10/98 7:39 AM	283	167	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 7:44 AM	181	277	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 7:53 AM	117	140	TREE LIMB BROKEN - PRIMARY	POLE	REPAIRED EQUIPMENT	TREE TRIMMING	NO
11/10/98 8:09 AM	341	264	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/10/98 8:22 AM	252	64	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 8:32 AM	3733	31	WEATHER - WIND	PHASE WIRE	REPLACED EQUIPMENT	FIELD INSPECTION	NO
11/10/98 8:50 AM	2244	211	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 8:55 AM	55	47	WEATHER - WIND	INSULATOR	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 8:58 AM	77	232	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/10/98 9:07 AM	1598	79	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 9:16 AM	104	79	WEATHER - WIND	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
11/10/98 9:37 AM	373	281	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 9:48 AM	70	48	TREE LIMB BROKEN - SECONDARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/10/98 9:50 AM	550	37	WEATHER - WIND	CONNECTOR/SLEEVE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 10:22 AM	1788	157	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
11/10/98 10:38 AM	112	412	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/10/98 10:40 AM	430	28	TREE LIMB BROKEN - SECONDARY	CONNECTOR/SLEEVE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/10/98 10:50 AM	80	855	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 10:53 AM	1027	126	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	YES
11/10/98 10:58 AM	377	418	WEATHER - WIND	SECTIONALIZER	REPAIRED EQUIPMENT	FIELD INSPECTION	NO
11/10/98 10:59 AM	266	67	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 11:12 AM	173	160	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/10/98 11:15 AM	195	95	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 11:15 AM	525	48	WEATHER - WIND	CONNECTOR/SLEEVE	TEMPORARY JUMPER TO RESTORE	FIELD INSPECTION	NO
11/10/98 11:17 AM	79	860	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 11:19 AM	148	83	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/10/98 11:21 AM	391	2412	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPLACED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/10/98 11:24 AM	160	270	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/10/98 11:25 AM	2080	55	WEATHER - WIND	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 11:26 AM	219	47	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 11:30 AM	285	4393	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/10/98 11:31 AM	229	210	WEATHER - WIND	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
11/10/98 11:46 AM	274	172	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 11:48 AM	582	41	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 11:52 AM	1568	41	WEATHER - FLOODING/RAIN	CONNECTOR/SLEEVE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 11:56 AM	424	64	CUSTOMER - OVERLOAD	CONNECTOR/SLEEVE	TEMPORARY JUMPER TO RESTORE	NO ACTION NEEDED	NO
11/10/98 12:00 PM	190	694	UNKNOWN	OTHER EQUIPMENT	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 12:05 PM	1605	144	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 12:11 PM	409	26	WEATHER - WIND	CONNECTOR/SLEEVE	TEMPORARY JUMPER TO RESTORE	FIELD INSPECTION	NO
11/10/98 12:11 PM	629	1759	WEATHER - WIND	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
11/10/98 12:17 PM	353	353	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
11/10/98 12:17 PM	1873	45	TREE LIMB BROKEN - SECONDARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/10/98 12:18 PM	92	4168	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 12:22 PM	133	1363	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 12:22 PM	418	375	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 12:24 PM	951	857	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/10/98 12:25 PM	500	33	WEATHER - WIND	CONNECTOR/SLEEVE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 12:25 PM	759	781	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
11/10/98 12:38 PM	292	361	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 12:52 PM	1428	36	WEATHER - WIND	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 1:00 PM	2205	419	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/10/98 1:03 PM	232	665	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 1:04 PM	476	1908	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/10/98 1:09 PM	71	592	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/10/98 1:12 PM	288	26	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 1:13 PM	407	500	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 1:14 PM	396	36	WEATHER - WIND	CONNECTOR/SLEEVE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 1:19 PM	521	45	WEATHER - WIND	CONNECTOR/SLEEVE	TEMPORARY JUMPER TO RESTORE	FIELD INSPECTION	NO
11/10/98 1:24 PM	441	624	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 1:26 PM	184	578	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/10/98 1:33 PM	60	285	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 1:47 PM	373	70	WEATHER - WIND	CONNECTOR/SLEEVE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 2:14 PM	376	58	TREE CONTACT - PRIMARY	PHASE WIRE	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
11/10/98 2:28 PM	931	94	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
11/10/98 2:31 PM	211	15	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
11/10/98 2:31 PM	1259	40	WEATHER - WIND	CONNECTOR/SLEEVE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 2:34 PM	1396	66	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 2:51 PM	349	3293	WEATHER - WIND	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
11/10/98 2:52 PM	1313	32	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 2:53 PM	1687	184	WEATHER - WIND	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 3:03 PM	117	126	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/10/98 3:07 PM	293	1367	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/10/98 3:07 PM	369	1100	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/10/98 3:23 PM	1467	58	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 3:29 PM	1341	168	WEATHER - WIND	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
11/10/98 3:30 PM	1260	25	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	YES
11/10/98 3:31 PM	119	433	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 3:41 PM	1699	31	WEATHER - WIND	PHASE WIRE	REPLACED EQUIPMENT	FIELD INSPECTION	NO
11/10/98 3:42 PM	1032	1219	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 3:45 PM	220	989	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/10/98 3:47 PM	268	448	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 4:05 PM	1705	370	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 4:09 PM	771	2029	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 4:22 PM	368	1793	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/10/98 4:22 PM	1378	94	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 4:35 PM	367	1391	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/10/98 4:35 PM	1113	586	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 4:38 PM	1192	187	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 4:41 PM	1429	258	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 4:48 PM	1481	143	WEATHER - WIND	NEUTRAL WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 4:50 PM	1355	208	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 4:53 PM	817	55	WEATHER - WIND	POLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
11/10/98 4:53 PM	1327	36	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	OTHER EQUIPMENT	TEMPORARY JUMPER TO RESTORE	FIELD INSPECTION	NO
11/10/98 4:57 PM	1228	19	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 4:59 PM	781	276	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	YES
11/10/98 5:00 PM	1345	695	WEATHER - WIND	CROSS/ALLEY ARM	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
11/10/98 5:11 PM	425	1467	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/10/98 5:11 PM	1884	458	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/10/98 5:13 PM	1123	31	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 5:18 PM	732	16	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 5:20 PM	1520	51	WEATHER - WIND	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
11/10/98 5:20 PM	2095	19	TREE CONTACT - PRIMARY	PHASE WIRE	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
11/10/98 5:26 PM	1440	92	TREE CONTACT - PRIMARY	FUSE/CUTOUT	TREE REMOVED	TREE TRIMMING	NO
11/10/98 5:29 PM	1236	80	TREE CONTACT - PRIMARY	PHASE WIRE	CLOSED SUBSTATION BREAKER	TREE TRIMMING	NO
11/10/98 5:31 PM	1024	1951	WEATHER - WIND	CROSS/ALLEY ARM	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
11/10/98 5:50 PM	1605	169	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 5:52 PM	928	233	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	YES
11/10/98 5:53 PM	1686	265	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
11/10/98 5:55 PM	1605	61	WEATHER - WIND	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
11/10/98 5:57 PM	2388	90	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/10/98 6:11 PM	1309	319	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 6:12 PM	1653	135	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/10/98 6:14 PM	1251	2614	WEATHER - WIND	CONNECTOR/SLEEVE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 6:15 PM	105	1139	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 6:17 PM	1148	1248	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/10/98 6:20 PM	1390	225	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 6:31 PM	3269	87	WEATHER - WIND	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 6:34 PM	1611	147	WEATHER - WIND	PHASE WIRE	TREE REMOVED	FIELD INSPECTION	NO
11/10/98 6:35 PM	987	182	WEATHER - WIND	CROSS/ALLEY ARM	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 6:38 PM	272	54	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/10/98 6:38 PM	3087	30	UNKNOWN	PHASE WIRE	OTHER	FIELD INSPECTION	YES
11/10/98 6:42 PM	2598	24	TREE LIMB BROKEN - SECONDARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/10/98 6:46 PM	969	226	WEATHER - WIND	3:1 TRANSFORMER	REPAIRED TRANSFORMER	FIELD INSPECTION	NO
11/10/98 6:47 PM	1913	32	WEATHER - WIND	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
11/10/98 6:51 PM	939	121	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 6:55 PM	779	220	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 6:59 PM	366	2134	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 7:00 PM	395	689	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	SUBSTATION BREAKER	CLOSED SUBSTATION BREAKER	FIELD INSPECTION	NO
11/10/98 7:01 PM	617	700	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/10/98 7:05 PM	1495	2897	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/10/98 7:08 PM	2572	17	WEATHER - WIND	CONNECTOR/SLEEVE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 7:09 PM	1931	64	TREE CONTACT - PRIMARY	PHASE WIRE	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
11/10/98 7:11 PM	716	860	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 7:14 PM	1007	664	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 7:14 PM	1711	60	WEATHER - WIND	PHASE WIRE	REPAIRED EQUIPMENT	FIELD INSPECTION	NO
11/10/98 7:19 PM	653	1367	WEATHER - WIND	POLE	OTHER	FIELD INSPECTION	NO
11/10/98 7:20 PM	965	18	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	YES
11/10/98 7:26 PM	1263	1012	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	YES
11/10/98 7:27 PM	1233	922	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 7:28 PM	2792	48	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 7:32 PM	893	2728	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 7:36 PM	1269	245	TREE CONTACT - PRIMARY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
11/10/98 7:39 PM	2021	37	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 7:41 PM	2554	30	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 7:43 PM	982	106	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 7:48 PM	1442	663	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/10/98 7:50 PM	910	290	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 8:05 PM	1345	26	WEATHER - WIND	PHASE WIRE	REPLACED EQUIPMENT	FIELD INSPECTION	NO
11/10/98 8:06 PM	789	1788	WEATHER - LIGHTNING	SWITCH/DISCONNECT/LTD	TEMPORARY SWITCHING	FIELD INSPECTION	NO
11/10/98 8:12 PM	1758	64	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	YES
11/10/98 8:13 PM	222	992	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 8:19 PM	1481	26	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 8:20 PM	1120	270	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/10/98 8:20 PM	2465	19	WEATHER - WIND	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
11/10/98 8:36 PM	1109	489	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	YES
11/10/98 8:47 PM	1493	339	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	YES
11/10/98 8:50 PM	1108	4673	WEATHER - WIND	3:1 TRANSFORMER	TEMPORARY SWITCHING	FIELD INSPECTION	NO
11/10/98 9:01 PM	1059	122	WEATHER - WIND	CROSS/ALLEY ARM	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
11/10/98 9:40 PM	935	108	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 9:41 PM	1379	31	TREE CONTACT - PRIMARY	PHASE WIRE	REPLACED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/10/98 10:00 PM	300	976	TREE CONTACT - PRIMARY	PHASE WIRE	TREE TRIMMED	TREE TRIMMING	NO
11/10/98 10:00 PM	1320	85	WEATHER - WIND	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 10:08 PM	1222	33	WEATHER - WIND	NEUTRAL WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 10:09 PM	231	385	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/10/98 10:17 PM	833	71	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	YES
11/10/98 10:28 PM	2372	27	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/10/98 10:34 PM	1376	664	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/10/98 10:41 PM	1159	124	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
11/10/98 11:00 PM	405	468	INTENTIONAL - PROTECTION OF SYSTEM INTEGRITY	FUSE/CUTOUT	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
11/10/98 11:02 PM	833	106	WEATHER - WIND	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
11/10/98 11:09 PM	2541	51	TREE LIMB BROKEN - SECONDARY	NEUTRAL WIRE	REPLACED OTHER	TREE TRIMMING	NO
11/10/98 11:28 PM	1352	67	UNKNOWN	OTHER EQUIPMENT	REPLACED CIRCUIT SWITCHER	FIELD INSPECTION	YES
11/11/98 12:01 AM	509	181	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/11/98 12:05 AM	695	157	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/11/98 12:18 AM	1379	20	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/11/98 12:28 AM	1277	769	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/11/98 12:29 AM	2656	18	WEATHER - WIND	CONNECTOR/SLEEVE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/11/98 12:38 AM	742	84	WEATHER - WIND	CONNECTOR/SLEEVE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/11/98 12:41 AM	859	1407	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/11/98 1:05 AM	1105	907	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	TREE TRIMMED	TREE TRIMMING	NO
11/11/98 1:35 AM	2235	82	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/11/98 2:19 AM	1151	357	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/11/98 3:06 AM	1949	330	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/11/98 3:33 AM	687	43	WEATHER - WIND	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
11/11/98 3:41 AM	2134	483	WEATHER - WIND	PHASE WIRE	REPLACED EQUIPMENT	FIELD INSPECTION	NO
11/11/98 5:30 AM	950	114	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	YES
11/11/98 5:36 AM	1344	98	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/11/98 5:42 AM	488	83	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/11/98 5:46 AM	209	1793	WEATHER - LIGHTNING	SWITCH/DISCONNECT/LTD	TEMPORARY SWITCHING	FIELD INSPECTION	NO
11/11/98 6:29 AM	181	15	UNKNOWN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/11/98 7:11 AM	709	87	WEATHER - WIND	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/11/98 7:28 AM	557	30	UNKNOWN	OTHER EQUIPMENT	CHANGED OTHER	FIELD INSPECTION	NO
11/11/98 7:39 AM	2091	52	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/11/98 8:07 AM	2273	114	WEATHER - WIND	PHASE WIRE	TREE TRIMMED	FIELD INSPECTION	NO
11/11/98 8:17 AM	633	91	WEATHER - WIND	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
11/11/98 8:28 AM	2207	20	WEATHER - WIND	NEUTRAL WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/11/98 8:32 AM	2088	52	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/11/98 8:43 AM	1652	12	OVERHEAD EQUIPMENT - BROKEN FUSE	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
11/11/98 8:51 AM	1124	35	TREE CONTACT - PRIMARY	PHASE WIRE	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
11/11/98 8:52 AM	1497	94	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/11/98 9:02 AM	1858	57	TREE LIMB BROKEN - SECONDARY	PHASE WIRE	REPLACED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/11/98 9:22 AM	2248	22	WEATHER - WIND	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/11/98 10:07 AM	2333	19	WEATHER - WIND	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/11/98 10:23 AM	1479	92	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/11/98 10:42 AM	2073	18	WEATHER - WIND	CONNECTOR/SLEEVE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/11/98 10:52 AM	1862	23	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/11/98 10:58 AM	1381	14	TREE LIMB BROKEN - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/11/98 11:03 AM	1687	26	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/11/98 11:08 AM	562	39	WEATHER - WIND	TAP WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/11/98 11:14 AM	2141	115	WEATHER - LIGHTNING	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
11/11/98 11:24 AM	2016	74	TREE LIMB BROKEN - SECONDARY	CONNECTOR/SLEEVE	REPLACED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/11/98 11:28 AM	1207	80	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	YES
11/11/98 11:29 AM	626	28	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
11/11/98 11:57 AM	1623	51	WEATHER - WIND	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/11/98 12:09 PM	321	291	WEATHER - WIND	FUSE/CUTOUT	CHANGED OTHER	FIELD INSPECTION	NO
11/11/98 12:09 PM	696	312	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/11/98 12:16 PM	1094	39	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/11/98 12:31 PM	1409	48	WEATHER - WIND	CONNECTOR/SLEEVE	TEMPORARY JUMPER TO RESTORE	FIELD INSPECTION	NO
11/11/98 12:43 PM	1607	32	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/11/98 12:51 PM	159	13	WEATHER - WIND	PHASE WIRE	REPLACED EQUIPMENT	FIELD INSPECTION	NO
11/11/98 12:53 PM	472	153	WEATHER - WIND	PHASE WIRE	TREE TRIMMED	FIELD INSPECTION	NO
11/11/98 1:05 PM	1735	51	TREE CONTACT - SECONDARY	CONNECTOR/SLEEVE	CLOSED OTHER	TREE TRIMMING	NO
11/11/98 1:27 PM	423	42	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/11/98 1:37 PM	223	1014	WEATHER - LIGHTNING	FUSE/CUTOUT	CHANGED OTHER	FIELD INSPECTION	NO
11/11/98 1:43 PM	1887	31	WEATHER - WIND	CONNECTOR/SLEEVE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/11/98 2:16 PM	844	52	TREE CONTACT - PRIMARY	PHASE WIRE	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
11/11/98 2:39 PM	459	72	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/11/98 2:41 PM	434	26	WEATHER - WIND	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
11/11/98 2:53 PM	1567	38	TREE LIMB BROKEN - SECONDARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/11/98 3:16 PM	619	64	WEATHER - WIND	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
11/11/98 3:50 PM	865	59	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/11/98 3:50 PM	1345	21	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/11/98 3:55 PM	1495	48	TREE LIMB BROKEN - SECONDARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/11/98 4:10 PM	340	1108	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/11/98 4:13 PM	247	202	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/11/98 4:38 PM	262	14	UNKNOWN	SWITCH/DISCONNECT/LTD	REPAIRED EQUIPMENT	FIELD INSPECTION	NO
11/11/98 4:47 PM	1573	34	UNKNOWN	CONNECTOR/SLEEVE	REPLACED EQUIPMENT	FIELD INSPECTION	YES
11/11/98 4:47 PM	1733	41	TREE CONTACT - SECONDARY	NEUTRAL WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/11/98 4:50 PM	1675	68	WEATHER - WIND	NEUTRAL WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/11/98 5:22 PM	1433	11	TREE LIMB BROKEN - SECONDARY	NEUTRAL WIRE	REPLACED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/11/98 6:07 PM	1237	33	WEATHER - WIND	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/11/98 6:13 PM	457	782	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/11/98 6:29 PM	346	135	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/11/98 7:00 PM	1140	42	TREE LIMB BROKEN - SECONDARY	PHASE WIRE	OTHER	TREE TRIMMING	NO
11/11/98 7:33 PM	1032	21	UNKNOWN	CONNECTOR/SLEEVE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	YES
11/11/98 8:37 PM	1198	175	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/11/98 10:13 PM	1152	19	WEATHER - WIND	PHASE WIRE	CHANGED OTHER	FIELD INSPECTION	NO
11/11/98 11:16 PM	1094	52	TREE LIMB BROKEN - SECONDARY	NEUTRAL WIRE	REPLACED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/12/98 12:42 AM	738	17	WEATHER - WIND	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
11/12/98 3:45 AM	845	14	TREE LIMB BROKEN - SECONDARY	NEUTRAL WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/12/98 5:33 AM	747	55	TREE LIMB BROKEN - SECONDARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/12/98 5:37 AM	473	150	OTHER	TAP WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/12/98 6:40 AM	280	35	WEATHER - WIND	CONNECTOR/SLEEVE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/12/98 6:50 AM	140	253	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
11/12/98 7:10 AM	145	289	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/12/98 7:12 AM	768	18	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/12/98 7:58 AM	397	205	UNKNOWN	TAP WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/12/98 8:40 AM	590	21	TREE CONTACT - SECONDARY	PHASE WIRE	TREE REMOVED	TREE TRIMMING	NO
11/12/98 8:59 AM	121	46	WEATHER - WIND	CONNECTOR/SLEEVE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/12/98 9:06 AM	689	38	TREE CONTACT - PRIMARY	CONNECTOR/SLEEVE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/12/98 9:14 AM	706	42	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/12/98 9:50 AM	631	36	WEATHER - WIND	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/12/98 10:32 AM	118	34	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/12/98 10:54 AM	66	85	WEATHER - WIND	CONNECTOR/SLEEVE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/12/98 10:54 AM	791	50	WEATHER - WIND	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/12/98 11:30 AM	320	30	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/12/98 11:49 AM	191	87	WEATHER - WIND	CONNECTOR/SLEEVE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/12/98 12:29 PM	331	39	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/12/98 12:39 PM	141	56	WEATHER - WIND	CONNECTOR/SLEEVE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/12/98 1:02 PM	408	39	WEATHER - WIND	CONNECTOR/SLEEVE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/12/98 1:39 PM	286	31	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/12/98 1:51 PM	634	10	WEATHER - WIND	PHASE WIRE	REPLACED EQUIPMENT	FIELD INSPECTION	NO
11/12/98 1:56 PM	39	401	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/12/98 2:06 PM	624	28	WEATHER - WIND	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/12/98 2:31 PM	89	31	WEATHER - WIND	CONNECTOR/SLEEVE	REPAIRED OTHER	FIELD INSPECTION	NO
11/12/98 2:47 PM	133	23	WEATHER - WIND	NEUTRAL WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/12/98 3:20 PM	220	218	WEATHER - WIND	PHASE WIRE	CHANGED OTHER	FIELD INSPECTION	NO
11/12/98 3:40 PM	250	23	WEATHER - WIND	NEUTRAL WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/12/98 3:55 PM	65	17	TREE LIMB BROKEN - SECONDARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/12/98 4:07 PM	403	122	WEATHER - WIND	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/12/98 4:29 PM	91	37	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/12/98 4:46 PM	74	35	TREE CONTACT - SECONDARY	PHASE WIRE	TREE TRIMMED	TREE TRIMMING	NO
11/12/98 4:57 PM	273	41	TREE CONTACT - SECONDARY	NEUTRAL WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/12/98 6:22 PM	158	34	WEATHER - WIND	CONNECTOR/SLEEVE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/12/98 6:31 PM	105	19	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/12/98 7:03 PM	307	25	WEATHER - WIND	CONNECTOR/SLEEVE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/12/98 7:07 PM	113	55	WEATHER - WIND	CONNECTOR/SLEEVE	REPAIRED TRANSFORMER	FIELD INSPECTION	NO
11/12/98 7:15 PM	60	34	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/12/98 7:28 PM	77	58	WEATHER - WIND	NEUTRAL WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
11/12/98 7:53 PM	112	23	TREE LIMB BROKEN - SECONDARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/12/98 8:49 PM	281	27	TREE LIMB BROKEN - SECONDARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/12/98 9:05 PM	199	40	WEATHER - WIND	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/12/98 9:24 PM	176	18	TREE LIMB BROKEN - SECONDARY	PHASE WIRE	REPLACED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/12/98 9:53 PM	172	20	TREE LIMB BROKEN - SECONDARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/12/98 9:53 PM	197	51	TREE LIMB BROKEN - SECONDARY	PHASE WIRE	REPLACED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/12/98 9:59 PM	151	96	WEATHER - WIND	PHASE WIRE	REPLACED EQUIPMENT	FIELD INSPECTION	NO
11/12/98 10:13 PM	77	61	WEATHER - WIND	CONNECTOR/SLEEVE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/13/98 1:18 AM	82	100	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/13/98 9:36 AM	90	16	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
11/13/98 10:53 PM	99	94	WEATHER - WIND	LLC	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/13/98 11:29 PM	681	21	OTHER	CONNECTOR/SLEEVE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/14/98 9:11 PM	39	49	PUBLIC - FIRE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
11/15/98 12:33 AM	184	240	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/15/98 7:54 AM	121	3916	OTHER	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
11/15/98 12:30 PM	360	9410	UNKNOWN	SUBSTATION TRANSFORMER	REPAIRED UNDERGROUND MATERIAL	FIELD INSPECTION	NO
11/15/98 2:00 PM	90	49	WILDLIFE	PHASE WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
11/16/98 6:34 AM	56	35	UNKNOWN	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
11/16/98 2:35 PM	15	40	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/16/98 3:35 PM	45	601	UNKNOWN	POLE	CLOSED FUSE OR CUTOUT	FIELD INSPECTION	NO
11/17/98 9:52 AM	13	44	INTENTIONAL - PROTECTION OF SYSTEM INTEGRITY	CROSS/ALLEY ARM	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
11/17/98 11:22 AM	58	35	WILDLIFE	CROSS/ALLEY ARM	CLOSED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
11/17/98 1:22 PM	68	166	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
11/17/98 1:44 PM	136	52	UNKNOWN	ARRESTER	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
11/18/98 5:25 AM	50	149	WEATHER - WIND	PHASE WIRE	OTHER	FIELD INSPECTION	NO
11/18/98 6:28 AM	43	5637	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	SUBSTATION BREAKER	CLOSED SUBSTATION BREAKER	FIELD INSPECTION	NO
11/18/98 10:36 AM	103	239	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/18/98 2:36 PM	134	151	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
11/18/98 6:34 PM	131	233	TREE CONTACT - PRIMARY	PHASE WIRE	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
11/18/98 11:57 PM	63	14	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
11/19/98 10:17 AM	1	301	INTENTIONAL - EMERGENCY REPAIRS	SWITCH/DISCONNECT/LTD	CLOSED SUBSTATION BREAKER	FIELD INSPECTION	NO
11/19/98 10:18 AM	1	989	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
11/19/98 1:19 PM	57	64	WILDLIFE	PHASE WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
11/19/98 2:29 PM	191	1079	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
11/19/98 6:56 PM	184	34	UNKNOWN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/19/98 7:33 PM	7	671	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
11/20/98 6:30 AM	30	1169	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
11/20/98 6:54 AM	743	73	UNKNOWN	CABLE	REPAIRED UNDERGROUND MATERIAL	FIELD INSPECTION	YES
11/21/98 7:44 AM	54	583	INTENTIONAL - SCHEDULED CONSTRUCTION, MAINTENANCE, OR REPAIR	SUBSTATION BREAKER	CLOSED SUBSTATION BREAKER	NO ACTION NEEDED	NO
11/21/98 10:11 AM	136	30	WILDLIFE	PHASE WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
11/21/98 12:08 PM	53	11	OTHER	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
11/21/98 1:03 PM	157	86	WILDLIFE	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
11/21/98 3:57 PM	68	26	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/22/98 9:40 AM	175	47	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
11/22/98 11:41 AM	229	30	CUSTOMER - EQUIPMENT	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	NO ACTION NEEDED	NO
11/22/98 8:59 PM	781	67	WILDLIFE	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	YES
11/22/98 9:49 PM	190	25	UNKNOWN	OTHER EQUIPMENT	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/22/98 11:07 PM	101	325	UNKNOWN	CABLE JOINT/SPLICE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
11/23/98 6:46 AM	124	3761	OTHER	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
11/23/98 6:48 AM	327	149	PUBLIC - FOREIGN OBJECT	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	NO ACTION NEEDED	NO
11/23/98 7:04 AM	106	3856	OTHER	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
11/23/98 8:46 AM	89	50	WILDLIFE	PHASE WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
11/23/98 1:27 PM	53	37	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/23/98 2:56 PM	24	305	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
11/23/98 9:39 PM	381	40	OTHER	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
11/24/98 11:34 AM	36	24	WILDLIFE	PHASE WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
11/24/98 6:52 PM	118	23	WEATHER - WIND	FUSE/CUTOUT	REPAIRED EQUIPMENT	FIELD INSPECTION	NO
11/24/98 6:53 PM	122	25	OTHER	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
11/25/98 8:57 AM	63	334	PUBLIC - FOREIGN OBJECT	PHASE WIRE	REPLACED FUSE OR CUTOUT	NO ACTION NEEDED	NO
11/25/98 11:32 AM	65	24	PUBLIC - DIG-IN BY OTHERS	CABLE	CONTRACTOR WARNED	NO ACTION NEEDED	NO
11/25/98 11:33 AM	64	8425	UNDERGROUND EQUIPMENT - UG FAILURE	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
11/25/98 12:02 PM	4306	10	UNKNOWN	AERIAL CABLE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	YES
11/25/98 1:09 PM	111	38	TREE CONTACT - PRIMARY	CROSS/ALLEY ARM	CLOSED FUSE OR CUTOUT	TREE TRIMMING	NO
11/25/98 1:21 PM	34	203	TREE CONTACT - PRIMARY	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	TREE TRIMMING	NO
11/26/98 8:04 AM	51	336	WILDLIFE	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
11/27/98 6:20 AM	75	47	UNKNOWN	FUSE/CUTOUT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/27/98 8:26 AM	59	10	WILDLIFE	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
11/27/98 9:14 AM	296	19	UNKNOWN	OTHER EQUIPMENT	TEMPORARY SWITCHING	FIELD INSPECTION	NO
11/27/98 12:23 PM	67	534	OTHER	POLE	OTHER	FIELD INSPECTION	NO
11/27/98 10:27 PM	140	601	OTHER	POLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
11/28/98 7:55 AM	95	52	WILDLIFE	ARRESTER	REPLACED OVERHEAD MATERIAL	ANIMAL GUARD CHECK	NO
11/28/98 8:00 AM	100	488	WILDLIFE	PHASE WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
11/28/98 8:49 AM	141	118	OTHER	TAP WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/28/98 10:12 AM	105	80	WILDLIFE	CROSS/ALLEY ARM	CLOSED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
11/28/98 1:14 PM	134	62	PUBLIC - FOREIGN OBJECT	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	NO ACTION NEEDED	NO
11/28/98 3:11 PM	282	38	TREE LIMB BROKEN - SECONDARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
11/28/98 8:22 PM	92	27	PUBLIC - VEHICLES	PHASE WIRE	REPLACED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
11/29/98 7:09 AM	231	22	WILDLIFE	PHASE WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
11/29/98 10:54 AM	56	384	WILDLIFE	PHASE WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
11/29/98 5:42 PM	418	37	PUBLIC - FOREIGN OBJECT	PHASE WIRE	REPLACED FUSE OR CUTOUT	NO ACTION NEEDED	NO
11/30/98 8:11 AM	149	329	OTHER	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
11/30/98 9:22 AM	73	162	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/30/98 10:22 AM	158	21	TREE CONTACT - PRIMARY	PHASE WIRE	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
11/30/98 10:30 AM	215	357	INTENTIONAL - EMERGENCY REPAIRS	SWITCH/DISCONNECT/LTD	TREE TRIMMED	FIELD INSPECTION	NO
11/30/98 11:22 AM	173	60	WEATHER - WIND	LLC	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/30/98 11:25 AM	120	220	WEATHER - WIND	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/30/98 11:30 AM	195	16	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
11/30/98 1:09 PM	26	115	INTENTIONAL - EMERGENCY REPAIRS	SWITCH/DISCONNECT/LTD	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
11/30/98 1:54 PM	151	23	TREE LIMB BROKEN - PRIMARY	NEUTRAL WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
12/2/98 7:26 PM	74	245	UNKNOWN	CONNECTOR/SLEEVE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
12/2/98 9:20 PM	245	93	UNKNOWN	CONNECTOR/SLEEVE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
12/2/98 9:28 PM	62	2700	WILDLIFE	SUBSTATION BREAKER	TEMPORARY SWITCHING	ANIMAL GUARD CHECK	NO
12/2/98 9:33 PM	172	116	PUBLIC - VEHICLES	POLE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
12/2/98 10:18 PM	152	565	TREE CONTACT - PRIMARY	CROSS/ALLEY ARM	REPLACED OVERHEAD MATERIAL	TREE TRIMMING	NO
12/2/98 11:12 PM	252	26	UNKNOWN	CROSS/ALLEY ARM	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
12/3/98 6:54 AM	480	21	PUBLIC - ACCIDENT BY OTHERS	OVERHEAD TRANSFORMER	TEMPORARY SWITCHING	NO ACTION NEEDED	NO
12/3/98 9:56 AM	128	74	PUBLIC - ACCIDENT BY OTHERS	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
12/3/98 10:38 AM	2	260	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
12/3/98 8:33 PM	107	95	CUSTOMER - OVERLOAD	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
12/4/98 4:22 AM	258	12	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
12/4/98 7:23 AM	417	29	UNKNOWN	FUSE/CUTOUT	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
12/4/98 11:41 AM	229	485	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
12/4/98 12:39 PM	6	45	OVERHEAD EQUIPMENT - MALFUNCTION	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
12/4/98 2:41 PM	59	30	OTHER	PHASE WIRE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
12/4/98 4:22 PM	173	78	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
12/4/98 11:02 PM	24	154	INTENTIONAL - PROTECTION OF SYSTEM INTEGRITY	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	NO ACTION NEEDED	NO
12/5/98 3:42 AM	378	55	PUBLIC - FIRE	PHASE WIRE	REPLACED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
12/5/98 6:33 AM	87	1378	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
12/5/98 5:14 PM	206	18	WILDLIFE	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
12/5/98 11:38 PM	67	3375	OTHER	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
12/6/98 1:29 AM	156	1847	PUBLIC - FOREIGN OBJECT	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
12/6/98 7:34 AM	86	209	UNKNOWN	SWITCH/DISCONNECT/LTD	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
12/6/98 10:26 AM	139	218	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
12/6/98 10:55 AM	260	224	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
12/6/98 11:17 AM	146	38	TREE CONTACT - PRIMARY	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TREE TRIMMING	NO
12/6/98 11:52 AM	1261	27	WEATHER - LIGHTNING	FUSE/CUTOUT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
12/6/98 3:06 PM	189	200	TREE CONTACT - PRIMARY	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
12/6/98 5:03 PM	272	70	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
12/6/98 6:14 PM	141	14872	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
12/6/98 6:37 PM	448	40	TREE CONTACT - PRIMARY	PHASE WIRE	TEMPORARY SWITCHING	TREE TRIMMING	NO
12/6/98 6:38 PM	232	61	TREE CONTACT - PRIMARY	PHASE WIRE	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
12/6/98 7:21 PM	674	187	TREE LIMB BROKEN - PRIMARY	POLE	REPAIRED EQUIPMENT	TREE TRIMMING	NO
12/6/98 9:17 PM	696	15	OTHER	CONNECTOR/SLEEVE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
12/6/98 10:32 PM	106	182	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
12/6/98 10:37 PM	73	557	UNKNOWN	OTHER EQUIPMENT	TEMPORARY SWITCHING	FIELD INSPECTION	NO
12/7/98 7:42 AM	168	87	TREE CONTACT - PRIMARY	PHASE WIRE	REPLACED FUSE OR CUTOUT	TREE TRIMMING	NO
12/7/98 9:14 AM	706	128	UNKNOWN	ARRESTER	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
12/7/98 9:38 AM	162	467	TREE CONTACT - PRIMARY	PHASE WIRE	TREE TRIMMED	TREE TRIMMING	NO
12/7/98 10:23 AM	102	419	UNKNOWN	OTHER EQUIPMENT	TEMPORARY SWITCHING	FIELD INSPECTION	NO
12/7/98 10:41 AM	139	1237	OTHER	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
12/7/98 2:47 PM	91	1010	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
12/7/98 5:03 PM	957	42	COMED/CONTRACTOR - UNCLASSIFIED ERROR	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	TRAINING	YES
12/8/98 8:54 AM	166	143	INTENTIONAL - SCHEDULED CONSTRUCTION, MAINTENANCE, OR REPAIR	SWITCH/DISCONNECT/LTD	TREE REMOVED	NO ACTION NEEDED	NO
12/8/98 4:42 PM	93	37	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
12/8/98 10:43 PM	152	32	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
12/9/98 10:29 AM	16	31	OTHER	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
12/9/98 1:52 PM	68	40	WILDLIFE	PHASE WIRE	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
12/9/98 9:16 PM	44	229	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
12/9/98 9:54 PM	48	773	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
12/10/98 4:46 PM	20	449	OTHER	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
12/10/98 9:16 PM	33	53	INTENTIONAL - EMERGENCY REPAIRS	SWITCH/DISCONNECT/LTD	CLOSED SWITCH/DISCONNECT/LT	FIELD INSPECTION	NO
12/11/98 10:20 AM	115	13	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
12/11/98 10:37 AM	118	642	COMED/CONTRACTOR - ACCIDENT BY CONTRACTOR	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	TRAINING	NO
12/11/98 12:00 PM	60	28	UNKNOWN	OTHER EQUIPMENT	REPLACED EQUIPMENT	FIELD INSPECTION	NO
12/12/98 7:06 AM	24	391	UNKNOWN	OTHER EQUIPMENT	CLOSED SWITCH/DISCONNECT/LT	FIELD INSPECTION	NO
12/12/98 9:13 AM	347	83	OTHER	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
12/12/98 5:10 PM	135	6780	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
12/13/98 3:27 AM	15	583	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
12/13/98 9:46 AM	309	13	INTENTIONAL - EMERGENCY REPAIRS	SWITCH/DISCONNECT/LTD	CLOSED SWITCH/DISCONNECT/LT	FIELD INSPECTION	NO
12/13/98 9:59 AM	113	70	UNKNOWN	OTHER EQUIPMENT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
12/13/98 2:20 PM	220	44	UNKNOWN	CONNECTOR/SLEEVE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
12/13/98 3:12 PM	130	2532	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
12/13/98 3:14 PM	56	575	UNKNOWN	SWITCH/DISCONNECT/LTD	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
12/13/98 11:24 PM	51	4173	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
12/14/98 5:02 AM	13	999	UNKNOWN	OTHER EQUIPMENT	CLOSED SUBSTATION BREAKER	FIELD INSPECTION	NO
12/14/98 11:25 AM	85	96	WILDLIFE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
12/15/98 7:05 AM	17	2489	INTENTIONAL - SCHEDULED CONSTRUCTION, MAINTENANCE, OR REPAIR	SWITCH/DISCONNECT/LTD	CHANGED OTHER	NO ACTION NEEDED	NO
12/15/98 8:02 AM	18	689	INTENTIONAL - SCHEDULED CONSTRUCTION, MAINTENANCE, OR REPAIR	SWITCH/DISCONNECT/LTD	CHANGED OTHER	NO ACTION NEEDED	NO
12/15/98 9:02 AM	13	869	INTENTIONAL - SCHEDULED CONSTRUCTION, MAINTENANCE, OR REPAIR	SWITCH/DISCONNECT/LTD	CHANGED OTHER	NO ACTION NEEDED	NO
12/15/98 9:57 AM	15	60	UNKNOWN	OTHER EQUIPMENT	CLOSED SUBSTATION BREAKER	FIELD INSPECTION	NO
12/15/98 4:34 PM	59	1850	UNKNOWN	CABLE JOINT/SPLICE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
12/16/98 1:11 AM	49	96	PUBLIC - FOREIGN OBJECT	OVERHEAD TRANSFORMER	REPLACED FUSE OR CUTOUT	NO ACTION NEEDED	NO
12/16/98 3:59 AM	136	1929	OTHER	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
12/16/98 5:45 AM	1	180	COMED/CONTRACTOR - SWITCHING ERROR	SUBSTATION BREAKER	CLOSED SUBSTATION BREAKER	TRAINING	NO
12/16/98 3:51 PM	54	2604	UNKNOWN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
12/16/98 11:44 PM	40	125	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
12/17/98 4:04 AM	29	1753	UNKNOWN	SUBSTATION BREAKER	TEMPORARY SWITCHING	FIELD INSPECTION	NO
12/17/98 1:06 PM	69	63	OTHER	TAP WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
12/17/98 1:39 PM	78	4055	WILDLIFE	CABLE	TEMPORARY SWITCHING	ANIMAL GUARD CHECK	NO
12/17/98 3:12 PM	1329	14	UNKNOWN	CONNECTOR/SLEEVE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	YES
12/18/98 1:06 AM	44	139	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
12/18/98 5:31 AM	24	7391	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
12/18/98 7:57 AM	113	12	UNKNOWN	CONNECTOR/SLEEVE	REPLACED OVERHEAD MATERIAL	FIELD INSPECTION	NO
12/18/98 10:11 AM	89	114	UNKNOWN	LLC	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.

APPENDIX (SECTION 411.210(b)(1) OF COMED'S 1998 ELECTRIC POWER DELIVERY RELIABILITY REPORT)

Chicago

START DATE/TIME	INTERRUPTION DURATION (MIN)	NUMBER OF CUSTOMERS AFFECTED	CAUSE OF INTERRUPTION	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION MEASURES	PREVENTION MEASURES	FIXED CHARGE WAIVED / REMUNERATION
12/19/98 9:32 AM	148	23	INTENTIONAL - SCHEDULED CONSTRUCTION, MAINTENANCE, OR REPAIR	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
12/19/98 10:20 AM	31	34	UNKNOWN	OVERHEAD TRANSFORMER	REPLACED TRANSFORMER	FIELD INSPECTION	NO
12/19/98 1:19 PM	86	119	TRANSMISSION AND SUBSTATION EQUIPMENT - SUBSTATION EQUIPMENT	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
12/20/98 7:13 AM	124	106	UNKNOWN	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
12/20/98 9:09 PM	221	40	PUBLIC - FOREIGN OBJECT	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
12/21/98 2:13 PM	641	73	OTHER	CABLE JOINT/SPLICE	REPAIRED UNDERGROUND MATERIAL	FIELD INSPECTION	NO
12/22/98 1:31 AM	199	33	WEATHER - EXTREME COLD	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
12/22/98 2:05 AM	145	40	WEATHER - EXTREME COLD	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
12/22/98 6:39 AM	146	31	UNKNOWN	ARRESTER	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
12/22/98 8:54 AM	99	1563	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
12/23/98 9:14 AM	107	18	UNKNOWN	PHASE WIRE	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
12/26/98 5:56 AM	139	80	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
12/26/98 12:51 PM	19	16	UNKNOWN	OTHER EQUIPMENT	TEMPORARY SWITCHING	FIELD INSPECTION	NO
12/26/98 4:19 PM	181	387	OTHER	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
12/27/98 11:36 PM	59	41	PUBLIC - ACCIDENT BY OTHERS	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	NO ACTION NEEDED	NO
12/28/98 8:32 AM	63	568	PUBLIC - DIG-IN BY OTHERS	CABLE	TEMPORARY SWITCHING	NO ACTION NEEDED	NO
12/28/98 9:26 AM	129	335	WILDLIFE	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	ANIMAL GUARD CHECK	NO
12/28/98 3:30 PM	47	24	WILDLIFE	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	ANIMAL GUARD CHECK	NO
12/28/98 8:45 PM	435	73	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
12/28/98 9:52 PM	118	1153	COMED/CONTRACTOR - SWITCHING ERROR	SWITCH/DISCONNECT/LTD	CLOSED SWITCH/DISCONNECT/LT	TRAINING	NO
12/29/98 3:18 AM	152	207	UNKNOWN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
12/29/98 6:17 AM	164	92	UNKNOWN	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
12/29/98 7:30 AM	60	53	UNKNOWN	NEUTRAL WIRE	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
12/29/98 7:32 AM	156	76	WEATHER - ICE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
12/29/98 10:02 AM	118	241	INTENTIONAL - SCHEDULED CONSTRUCTION, MAINTENANCE, OR REPAIR	OVERHEAD TRANSFORMER	TEMPORARY SWITCHING	NO ACTION NEEDED	NO
12/29/98 11:28 AM	77	11	WEATHER - ICE	FUSE/CUTOUT	REPAIRED EQUIPMENT	FIELD INSPECTION	NO
12/29/98 11:49 AM	185	78	UNKNOWN	FUSE/CUTOUT	REPAIRED OVERHEAD MATERIAL	FIELD INSPECTION	NO
12/29/98 12:00 PM	75	118	PUBLIC - FOREIGN OBJECT	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
12/29/98 12:06 PM	85	223	WEATHER - ICE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
12/29/98 12:06 PM	85	1200	WEATHER - ICE	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
12/29/98 8:09 PM	91	1105	UNKNOWN	SUBSTATION TRANSFORMER	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
12/29/98 10:57 PM	40	73	UNKNOWN	CABLE	REPAIRED UNDERGROUND MATERIAL	FIELD INSPECTION	NO
12/30/98 9:38 PM	187	131	OTHER	FUSE/CUTOUT	REPLACED FUSE OR CUTOUT	FIELD INSPECTION	NO
12/31/98 1:28 AM	282	10	PUBLIC - FIRE	OVERHEAD TRANSFORMER	CLOSED FUSE OR CUTOUT	NO ACTION NEEDED	NO
12/31/98 8:23 AM	53	2979	PUBLIC - FOREIGN OBJECT	PHASE WIRE	REPAIRED OVERHEAD MATERIAL	NO ACTION NEEDED	NO
12/31/98 12:02 PM	48	1161	UNKNOWN	CABLE	TEMPORARY SWITCHING	FIELD INSPECTION	NO
12/31/98 1:20 PM	55	381	PUBLIC - FOREIGN OBJECT	FUSE/CUTOUT	CLOSED FUSE OR CUTOUT	NO ACTION NEEDED	NO

Duration is the period of time beginning when ComEd was notified or became aware of the interruption and ending when all customers who had been interrupted were restored; not all customers necessarily experienced the full duration.